

**FOURTH QUARTER 2008 REASONABLE POTENTIAL ANALYSIS SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

1. The following Reasonable Potential Analysis (RPA) provides the analytical results as performed by the procedures outlined in "Reasonable Potential Analysis Methodology Technical Memo, (MWH and Flow Science, 2006).
2. The monitoring data set utilized to conduct the RPA consists of all applicable and relevant data from August 2004 through the present reporting quarter.
3. As directed by the CTR and the Regional Water Control Board 2,3,7,8-TCDD (Dioxin) values are to be expressed in NPDES permitting and this RPA as TCDD Total Equivalence units (TEQs). A TCDD TEQ is determined by multiplying each of the seventeen dioxin and furan congeners by their respective total equivalence factor (TEF), and summing the results of those products. For the purposes of this RPA, the resulting TCDD TEQ does not include those congener concentrations that are reported as DNQ, as specified on Page 46, Section D of the NPDES Permit Effective April 28, 2006, and Page 56, Section D of the NPDES Permit Effective December 20, 2007.
4. In calculating the average, standard deviation, coefficient of variation, and projected maximum effluent concentration (99/99), one-half of the MDL was used for concentration results reported as ND. Data reported with qualifiers were not included in this RPA as Boeing believes qualified data are not "appropriate, valid, relevant, (nor) representative"¹ of storm water constituents and are therefore not utilized in its RPA.
5. All of the following abbreviations and/or notes may not occur on every table.

Definition of Acronyms, Abbreviations, and Terminology Used

>=	Greater than or equal to
*	Freshwater aquatic life criteria for metals are expressed as a function of total hardness (mg/L) in the water body. The equations are provided in the CTR, (US EPA, 2000). Values displayed correspond to a total hardness of 100 mg/l.
µg/L	Concentration units, micrograms per liter
All Data Qualified	All available monitoring data are qualified and no statistical analysis is performed.
Annually	The 2007 NPDES Permit requires annual monitoring.
Available Data < DL	All available monitoring data that are not qualified are below detection limits.
B	Background
C	Concentration
CCC	Criterion Continuous Concentration
CMC	Criterion Maximum Concentration
CTR	California Toxics Rule
CV	Coefficient of Variation
DL	Detection Limit
EPA TSD	EPA's Technical Support Document for Water Quality Based Toxics Control, (see references).

¹ SIP, p. 5.

**FOURTH QUARTER 2008 REASONABLE POTENTIAL ANALYSIS SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

Definition of Acronyms, Abbreviations, and Terminology Used (Continued)

Fibers/L	Units for asbestos concentration, fibers per liter
HH O	Human Health criteria for consumption of Organisms only
HH W&O	Human Health criteria for consumption of Water and Organisms
MEC	Maximum Observed Effluent Concentration
Min	Minimum
NA	Not Applicable
Narrative	Water quality criteria are expressed as a narrative objective rather than a numeric objective, and therefore are not part of the statistical RPA calculations.
None	No available CTR or Basin Plan criteria.
pH Dependent	CTR Criteria are based on pH.
Once Per Discharge	The 2007 NPDES Permit requires monitoring once per discharge event.
Qualified Data	Data qualifier definitions are: (a) J- The reported result is an estimate. The value is less than the minimum calibration level but greater than the estimated detection limit (EDL), (b) U/UJ- The analyte was not detected in the sample at the detection limit /estimated detection limit (EDL), (c) B- Analyte found in sample and associated blank, and (d) DNQ- Detected Not Quantified.
Reserved	EPA has reserved the CTR criteria.
RPA	Reasonable Potential Analysis
SIP	The State Water Resources Control Board "Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California," (see references).
Tot	Total

Priority Pollutant RPA Column Explanation

CTR	Provides CTR constituent reference number.
Constituent	Provides CTR constituent common name.
Units	Provides the data set's concentration units as referenced by 2007 NPDES Permit.
MEC	Provides the outfall monitoring group's maximum value from the applicable data set.
CV	Equal to the standard deviation divided by the average of the applicable data set. If the number of samples is less than 10, the CV is assumed to be 0.6.
<i>Step 1 identifies all applicable water quality criteria.</i>	
CTR Criteria	Concentration criteria as listed in the CTR.
CMC = Acute	The Freshwater CMC is listed as the acute concentration criterion.
CCC = Chronic	The Freshwater CCC is listed as the chronic concentration criterion.
HH W& O(Not App)	The HH W&O is deemed not applicable based on past Regional Board RPAs.
HH O = HH	The HH O is listed as the CTR human health concentration criterion.
Basin Plan Criteria	Applicable Basin Plan Criteria are listed for the Los Angeles River and/or Calleguas Creek watersheds.

**FOURTH QUARTER 2008 REASONABLE POTENTIAL ANALYSIS SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

C = Lowest Criteria	The comparison concentration (C) is equal to the lowest criterion for a constituent based on the CMC, CCC, HH O, and Basin Plan Criteria listed.
---------------------	--

Priority Pollutant RPA Column Explanation (Continued)

<i>Step 2 defines the applicable data set.</i>	
Is Effluent Data Available	If there is available monitoring data that is not qualified and above DL, then YES. If not, then NO.
<i>Step 3 determines the maximum observed effluent concentration.</i>	
Was Constituent Detected in Effluent Data	If the constituent was detected, then YES. If all monitoring data are non-detect or qualified then NO.
Are all DL >C	If constituent was detected in effluent data then not applicable (NA). If constituent was not detected and all analysis detection limits are less than the comparison concentration, then YES, if not then NO.
If DL > C MEC = Min (DL)	If the previous cell answer was yes, then the MEC is equal to the minimum detection limit. If not, then NA.
<i>Step 4 compares the MEC to the lowest applicable water quality criteria.</i>	
MEC >= C	If the MEC is greater than or equal to the comparison concentration then YES, if not then NO.
Tier 1 – Need limit?	If the preceding cell was YES, then YES.

Note: Steps 5 and 6 of the Priority Pollutant RPA do not apply to Boeing SSFL because the Regional Board gives no consideration for receiving water background constituent concentrations. Furthermore, Boeing SSFL defers the application of best professional judgment in Step 7 and final determination of reasonable potential in Step 8 to the Regional Board Staff.

Nonpriority Pollutant RPA Column Explanation

Constituent	Provides the Non Priority Pollutant constituent common name
Monitoring	Provides the 2007 NPDES Permit directed monitoring frequency
Units	Provides the data set's concentration units as referenced by 2007 NPDES Permit
Number of Samples	Provides the number of available samples that are not qualified
MEC	Provides the outfall monitoring group's maximum value from the applicable data set
CV	Equal to the standard deviation divided by the average of the applicable data set. If the number of samples is less than 10, the CV is assumed to be 0.6.
Multiplier	Utilizes the EPA's TSD calculation to determine multiplier for which the maximum effluent concentration is calculated. (MWH and Flow Science, 2006, or EPA TSD, 1991)
Projected Maximum Effluent Concentration	Utilizes the product of the multiplier and the MEC as an estimate for the projected maximum effluent concentration.
Dilution Ratio	The Regional Board allocates no dilution ratio to Boeing SSFL.
Background Concentration	The Regional Board allocates no background concentration to Boeing SSFL.
Projected Maximum Receiving Water Concentration	The Regional Board estimates the projected maximum receiving water concentration as equal to the projected maximum effluent concentration.

**FOURTH QUARTER 2008 REASONABLE POTENTIAL ANALYSIS SUMMARY
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

Nonpriority Pollutant RPA Column Explanation (Continued)

Step 1, Determine Water Quality Objectives	The water quality objective is based on appropriate Basin Plan criteria.
BU – Beneficial Use Protection, NC – Human noncarcinogen, AP- Aquatic Life Protection, TMDL – Total Maximum Daily Load	This is the Regional Board’s Basis for determining if reasonable potential should be evaluated for a non-priority pollutant.

Note: Boeing SSFL has completed appropriate statistical calculations, but defers the application of best professional judgment and the final determination of reasonable potential to the Regional Board Staff.

References

Los Angeles Regional Water Quality Control Board, “Basin Plan for the Coastal Watersheds of Los Angeles and Ventura Counties, (Basin Plan).” June 13, 1994.

MWH and Flow Science, “Reasonable Potential Analysis Methodology Technical Memo- Version 1, Final, Santa Susan Field Laboratory, Ventura County, California.” April 28, 2006.

State Water Resources Control Board, “Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California, (SIP)” Resolution No. 2005-0019, February 24, 2005.

US EPA, *40CFR part 131, Water Quality Standards; Establishment of numeric Criteria for Priority Toxic Pollutants for the State of California*,(CTR) Federal Registry, May 18, 2000, pp. 31682-31719.

US EPA, “Technical Support Document for Water Quality-based Toxics Control.” EPA/505/2-90-001, PB-91-127415, March 1991.

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
3_7, 10	001	Antimony	ug/L	0.67	0.60	NONE	NONE	14	4300	6	6	Yes	Yes	NA	NA	No		
3_7, 10	002	Arsenic	ug/L	All Data Qualified	0.60	340	150	NONE	NONE	50	50	No	No	No	NA	No		
3_7, 10	003	Beryllium	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	4	4	No	No	No	NA	No		
3_7, 10	004	Cadmium	ug/L	0.64	0.60	NONE	2.5	Narrative	Narrative	5	2.5	Yes	Yes	NA	NA	No		
3_7, 10	005a	Chromium	ug/L	All Data Qualified	0.60	NONE	207.0	Narrative	Narrative	NONE	207.0	No	No	No	NA	No		
3_7, 10	005b	Chromium VI	ug/L	All Data Qualified	0.60	16.3	11.4	Narrative	Narrative	50	11.4	No	No	No	NA	No		
3_7, 10	006	Copper	ug/L	12	0.60	NONE	9.3	1300	NONE	NONE	9.3	Yes	Yes	NA	NA	Yes		
3_7, 10	007	Lead	ug/L	19	0.60	NONE	3.2	Narrative	Narrative	NONE	3.2	Yes	Yes	NA	NA	Yes		
3_7, 10	008	Mercury	ug/L	All Data Qualified	0.60	Reserved	Reserved	0.05	0.051	2	0.1	No	No	No	NA	No		
3_7, 10	009	Nickel	ug/L	All Data Qualified	0.60	NONE	52.2	610	4600	100	52.2	No	No	No	NA	No		
3_7, 10	010	Selenium	ug/L	All Data Qualified	0.60	Reserved	5	Narrative	Narrative	50	5	No	No	No	NA	No		
3_7, 10	011	Silver	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	4.06	No	No	No	NA	No		
3_7, 10	012	Thallium	ug/L	Available Data <DL	0.60	NONE	NONE	1.7	6.3	2	2	Yes	No	No	NA	No		
3_7, 10	013	Zinc	ug/L	All Data Qualified	0.60	NONE	119.8	none	NONE	NONE	119.8	No	No	No	NA	No		
3_7, 10	014	Total Cyanide	ug/L	All Data Qualified	0.60	22	5.2	700	220000	200	5.2	No	No	No	NA	No		
3_7, 10	015	Asbestos	Fibers/L	All Data Qualified	0.60	NONE	NONE	7000000	NONE	7x10^6	700000	No	No	No	NA	No		
3_7, 10	016	TCDD TEQ_NoDNQ	ug/L	1.83E-06	0.60	NONE	NONE	1.3e-008	1.4e-008	3x10^-5	1.40E-08	Yes	Yes	NA	NA	Yes		
3_7, 10	017	Acrolein	ug/L	All Data Qualified	0.60	NONE	NONE	320	780	NONE	780	No	No	No	NA	No		
3_7, 10	018	Acrylonitrile	ug/L	All Data Qualified	0.60	NONE	NONE	0.059	0.66	NONE	0.66	No	No	No	NA	No		
3_7, 10	019	Benzene	ug/L	All Data Qualified	0.60	NONE	NONE	1.2	71	1	1	No	No	No	NA	No		
3_7, 10	020	Bromoform	ug/L	All Data Qualified	0.60	NONE	NONE	4.3	360	NONE	360	No	No	No	NA	No		
3_7, 10	021	Carbon Tetrachloride	ug/L	All Data Qualified	0.60	NONE	NONE	0.25	4.4	600	4.4	No	No	No	NA	No		

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
3_7, 10	022	Chlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	680	21000	NONE	21000	No	No	No	NA	No		
3_7, 10	023	Dibromochloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.401	34	NONE	34	No	No	No	NA	No		
3_7, 10	024	Chloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
3_7, 10	025	2-Chloroethylvinylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
3_7, 10	026	Chloroform	ug/L	All Data Qualified	0.60	NONE	NONE	Reserved	Reserved	NONE	NONE	No	No	No	NA	No		
3_7, 10	027	Bromodichloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.56	46	NONE	46	No	No	No	NA	No		
3_7, 10	028	1,1-Dichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	5	5	No	No	No	NA	No		
3_7, 10	029	1,2-Dichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.38	99	0.5	0.5	No	No	No	NA	No		
3_7, 10	030	1,1-Dichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	0.057	3.2	6	3.2	No	No	No	NA	No		
3_7, 10	031	1,2-Dichloropropane	ug/L	All Data Qualified	0.60	NONE	NONE	0.52	39	5	5	No	No	No	NA	No		
3_7, 10	032	1,3-Dichloropropene (Total)	ug/L	All Data Qualified	0.60	NONE	NONE	10	1700	0.5	0.5	No	No	No	NA	No		
3_7, 10	033	Ethylbenzene	ug/L	All Data Qualified	0.60	NONE	NONE	3100	29000	0.7	0.7	No	No	No	NA	No		
3_7, 10	034	Bromomethane	ug/L	All Data Qualified	0.60	NONE	NONE	48	4000	NONE	4000	No	No	No	NA	No		
3_7, 10	035	Chloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	NONE	NONE	No	No	No	NA	No		
3_7, 10	036	Methylene chloride	ug/L	All Data Qualified	0.60	NONE	NONE	4.7	1600	NONE	1600	No	No	No	NA	No		
3_7, 10	037	1,1,1,2,2-Tetrachloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.17	11	1	1	No	No	No	NA	No		
3_7, 10	038	Tetrachloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	0.8	8.85	5	5	No	No	No	NA	No		
3_7, 10	039	Toluene	ug/L	All Data Qualified	0.60	NONE	NONE	6800	200000	150	150	No	No	No	NA	No		
3_7, 10	040	trans-1,2-Dichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	700	140000	10	10	No	No	No	NA	No		
3_7, 10	041	1,1,1-Trichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	200	200	No	No	No	NA	No		
3_7, 10	042	1,1,2-trichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.6	42	5	5	No	No	No	NA	No		
3_7, 10	043	Trichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	2.7	81	5	5	No	No	No	NA	No		

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C					Step 2	Step 3			Step 4	
						CTR CRITERIA				Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
Outfall	CTR	Constituent	Units	MEC	CV	Freshwater		Human Health								
						CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH							
3_7, 10	044	Vinyl chloride	ug/L	All Data Qualified	0.60	NONE	NONE	2	525	0.5	0.5	No	No	No	NA	No
3_7, 10	045	2-chlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	120	400	NONE	400	No	No	No	NA	No
3_7, 10	046	2,4-Dichlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	93	790	NONE	790	No	No	No	NA	No
3_7, 10	047	2,4-dimethylphenol	ug/L	All Data Qualified	0.60	NONE	NONE	540	2300	NONE	2300	No	No	No	NA	No
3_7, 10	048	2-Methyl-4,6-dinitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	13.4	765	NONE	765	No	No	No	NA	No
3_7, 10	049	2,4-dinitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	70	14000	NONE	14000	No	No	No	NA	No
3_7, 10	050	2-nitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	051	4-nitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	052	4-Chloro-3-methylphenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	053	Pentachlorophenol	ug/L	All Data Qualified	0.60	pH dependent	pH dependent	0.28	8.2	1	1	No	No	No	NA	No
3_7, 10	054	Phenol	ug/L	All Data Qualified	0.60	NONE	NONE	21000	4600000	NONE	4600000	No	No	No	NA	No
3_7, 10	055	2,4,6-Trichlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	2.1	6.5	NONE	6.5	No	No	No	NA	No
3_7, 10	056	Acenaphthene	ug/L	All Data Qualified	0.60	NONE	NONE	1200	2700	NONE	2700	No	No	No	NA	No
3_7, 10	057	Acenaphthylene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	058	Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	9600	110000	NONE	110000	No	No	No	NA	No
3_7, 10	059	Benzidine	ug/L	All Data Qualified	0.60	NONE	NONE	0.00012	0.00054	NONE	0.00054	No	No	No	NA	No
3_7, 10	060	Benzo(a)Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
3_7, 10	061	Benzo(a)Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
3_7, 10	062	Benzo(b)Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
3_7, 10	063	Benzo(g,h,i)Perylene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	064	Benzo(k)Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
3_7, 10	065	Bis(2-Chloroethoxy) methane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
3_7, 10	066	bis (2-Chloroethyl) ether	ug/L	All Data Qualified	0.60	NONE	NONE	0.031	1.4	NONE	1.4	No	No	No	NA	No		
3_7, 10	067	Bis(2-Chloroisopropyl) Ether	ug/L	All Data Qualified	0.60	NONE	NONE	1400	170000	NONE	170000	No	No	No	NA	No		
3_7, 10	068	bis (2-ethylhexyl) Phthalate	ug/L	All Data Qualified	0.60	NONE	NONE	1.8	5.9	4	4	No	No	No	NA	No		
3_7, 10	069	4-Bromophenylphenylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
3_7, 10	070	Butylbenzylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	3000	5200	NONE	5200	No	No	No	NA	No		
3_7, 10	071	2-Chloronaphthalene	ug/L	All Data Qualified	0.60	NONE	NONE	1700	4300	NONE	4300	No	No	No	NA	No		
3_7, 10	072	4-Chlorophenylphenylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
3_7, 10	073	Chrysene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
3_7, 10	074	Dibenzo(a,h)Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
3_7, 10	075	1,2-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	2700	17000	600	600	No	No	No	NA	No		
3_7, 10	076	1,3-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	400	2600	NONE	2600	No	No	No	NA	No		
3_7, 10	077	1,4-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	400	2600	5	5	No	No	No	NA	No		
3_7, 10	078	3,3'-Dichlorobenzidine	ug/L	All Data Qualified	0.60	NONE	NONE	0.04	0.077	NONE	0.077	No	No	No	NA	No		
3_7, 10	079	Diethylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	23000	120000	NONE	120000	No	No	No	NA	No		
3_7, 10	080	Dimethylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	313000	2900000	NONE	2900000	No	No	No	NA	No		
3_7, 10	081	Di-n-butylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	2700	12000	NONE	12000	No	No	No	NA	No		
3_7, 10	082	2,4-Dinitrotoluene	ug/L	All Data Qualified	0.60	NONE	NONE	0.11	9.1	NONE	9.1	No	No	No	NA	No		
3_7, 10	083	2,6-Dinitrotoluene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
3_7, 10	084	Di-n-octylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
3_7, 10	085	1,2-Diphenylhydrazine	ug/L	All Data Qualified	0.60	NONE	NONE	0.04	0.54	NONE	0.54	No	No	No	NA	No		
3_7, 10	086	Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	300	370	NONE	370	No	No	No	NA	No		
3_7, 10	087	Fluorene	ug/L	All Data Qualified	0.60	NONE	NONE	1300	14000	NONE	14000	No	No	No	NA	No		

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C					Step 2	Step 3			Step 4	
						CTR CRITERIA				Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
Outfall	CTR	Constituent	Units	MEC	CV	Freshwater		Human Health								
						CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH							
3_7, 10	088	Hexachlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	0.00075	0.00077	NONE	0.00077	No	No	No	NA	No
3_7, 10	089	Hexachlorobutadiene	ug/L	All Data Qualified	0.60	NONE	NONE	0.44	50	NONE	50	No	No	No	NA	No
3_7, 10	090	Hexachlorocyclopentadiene	ug/L	All Data Qualified	0.60	NONE	NONE	240	17000	NONE	17000	No	No	No	NA	No
3_7, 10	091	Hexachloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	1.9	8.9	NONE	8.9	No	No	No	NA	No
3_7, 10	092	Indeno(1,2,3-cd)Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
3_7, 10	093	Isophorone	ug/L	All Data Qualified	0.60	NONE	NONE	8.4	600	NONE	600	No	No	No	NA	No
3_7, 10	094	Naphthalene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	095	Nitrobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	17	1900	NONE	1900	No	No	No	NA	No
3_7, 10	096	N-Nitrosodimethylamine	ug/L	All Data Qualified	0.60	NONE	NONE	0.00069	8.1	NONE	8.1	No	No	No	NA	No
3_7, 10	097	n-Nitroso-di-n-propylamine	ug/L	All Data Qualified	0.60	NONE	NONE	0.005	1.4	NONE	1.4	No	No	No	NA	No
3_7, 10	098	N-Nitrosodiphenylamine	ug/L	All Data Qualified	0.60	NONE	NONE	5	16	NONE	16	No	No	No	NA	No
3_7, 10	099	Phenanthrene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	100	Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	960	11000	NONE	11000	No	No	No	NA	No
3_7, 10	101	1,2,4-Trichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	102	Aldrin	ug/L	All Data Qualified	0.60	3	NONE	0.00013	0.00014	NONE	0.00014	No	No	No	NA	No
3_7, 10	103	alpha-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	0.0039	0.013	NONE	0.013	No	No	No	NA	No
3_7, 10	104	beta-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	0.014	0.046	NONE	0.046	No	No	No	NA	No
3_7, 10	105	Lindane (gamma-BHC)	ug/L	All Data Qualified	0.60	0.95	NONE	0.019	0.063	0.2	0.063	No	No	No	NA	No
3_7, 10	106	delta-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
3_7, 10	107	Chlordane	ug/L	All Data Qualified	0.60	2.4	0.0043	0.00057	0.00059	NONE	0.00059	No	No	No	NA	No
3_7, 10	108	4,4'-DDT	ug/L	All Data Qualified	0.60	1.1	0.001	0.00059	0.00059	NONE	0.00059	No	No	No	NA	No
3_7, 10	109	4,4'-DDE	ug/L	All Data Qualified	0.60	NONE	NONE	0.00059	0.00059	NONE	0.00059	No	No	No	NA	No

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
3_7, 10	110	4,4'-DDD	ug/L	All Data Qualified	0.60	NONE	NONE	0.00083	0.00084	NONE	0.00084	No	No	No	NA	No		
3_7, 10	111	Dieldrin	ug/L	All Data Qualified	0.60	0.24	0.056	0.00014	0.00014	NONE	0.00014	No	No	No	NA	No		
3_7, 10	112	Endosulfan I	ug/L	All Data Qualified	0.60	0.22	0.056	110	240	NONE	0.056	No	No	No	NA	No		
3_7, 10	113	Endosulfan II	ug/L	All Data Qualified	0.60	0.22	0.056	110	240	NONE	0.056	No	No	No	NA	No		
3_7, 10	114	Endosulfan Sulfate	ug/L	All Data Qualified	0.60	NONE	NONE	110	240	NONE	240	No	No	No	NA	No		
3_7, 10	115	Endrin	ug/L	All Data Qualified	0.60	0.086	0.036	0.76	0.81	NONE	0.036	No	No	No	NA	No		
3_7, 10	116	Endrin Aldehyde	ug/L	All Data Qualified	0.60	NONE	NONE	0.76	0.81	NONE	0.81	No	No	No	NA	No		
3_7, 10	117	Heptachlor	ug/L	All Data Qualified	0.60	0.52	0.0038	0.00021	0.00021	NONE	0.00021	No	No	No	NA	No		
3_7, 10	118	Heptachlor Epoxide	ug/L	All Data Qualified	0.60	0.52	0.0038	0.0001	0.00011	NONE	0.00011	No	No	No	NA	No		
3_7, 10	119	Aroclor-1016	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
3_7, 10	120	Aroclor-1221	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
3_7, 10	121	Aroclor-1232	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
3_7, 10	122	Aroclor-1242	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
3_7, 10	123	Aroclor-1248	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
3_7, 10	124	Aroclor-1254	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
3_7, 10	125	Aroclor-1260	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
3_7, 10	126	Toxaphene	ug/L	All Data Qualified	0.60	0.73	0.0002	0.0073	0.00075	NONE	0.0002	No	No	No	NA	No		
8	001	Antimony	ug/L	All Data Qualified	0.60	NONE	NONE	14	4300	6	6	No	No	No	NA	No		
8	002	Arsenic	ug/L	All Data Qualified	0.60	340	150	NONE	NONE	50	50	No	No	No	NA	No		
8	003	Beryllium	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	4	4	No	No	No	NA	No		
8	004	Cadmium	ug/L	All Data Qualified	0.60	NONE	2.5	Narrative	Narrative	5	2.5	No	No	No	NA	No		
8	005a	Chromium	ug/L	All Data Qualified	0.60	NONE	207.0	Narrative	Narrative	NONE	207.0	No	No	No	NA	No		

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C					Step 2	Step 3			Step 4	
						CTR CRITERIA				Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
Outfall	CTR	Constituent	Units	MEC	CV	Freshwater		Human Health								
						CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH							
8	005b	Chromium VI	ug/L	All Data Qualified	0.60	16.3	11.4	Narrative	Narrative	50	11.4	No	No	No	NA	No
8	006	Copper	ug/L	All Data Qualified	0.60	NONE	9.3	1300	NONE	NONE	9.3	No	No	No	NA	No
8	007	Lead	ug/L	All Data Qualified	0.60	NONE	3.2	Narrative	Narrative	NONE	3.2	No	No	No	NA	No
8	008	Mercury	ug/L	All Data Qualified	0.60	Reserved	Reserved	0.05	0.051	2	0.1	No	No	No	NA	No
8	009	Nickel	ug/L	All Data Qualified	0.60	NONE	52.2	610	4600	100	52.2	No	No	No	NA	No
8	010	Selenium	ug/L	All Data Qualified	0.60	Reserved	5	Narrative	Narrative	50	5	No	No	No	NA	No
8	011	Silver	ug/L	All Data Qualified	0.60	NONE	none	NONE	NONE	NONE	4.06	No	No	No	NA	No
8	012	Thallium	ug/L	All Data Qualified	0.60	NONE	NONE	1.7	6.3	2	2	No	No	No	NA	No
8	013	Zinc	ug/L	All Data Qualified	0.60	NONE	119.8	none	NONE	NONE	119.8	No	No	No	NA	No
8	014	Total Cyanide	ug/L	All Data Qualified	0.60	22	5.2	700	220000	200	5.2	No	No	No	NA	No
8	015	Asbestos	Fibers/L	All Data Qualified	0.60	NONE	NONE	7000000	NONE	7x10^6	700000	No	No	No	NA	No
8	016	TCDD TEQ_NoDNQ	ug/L	All Data Qualified	0.60	NONE	NONE	1.3e-008	1.4e-008	3x10^-5	1.40E-08	No	No	No	NA	No
8	017	Acrolein	ug/L	All Data Qualified	0.60	NONE	NONE	320	780	NONE	780	No	No	No	NA	No
8	018	Acrylonitrile	ug/L	All Data Qualified	0.60	NONE	NONE	0.059	0.66	NONE	0.66	No	No	No	NA	No
8	019	Benzene	ug/L	All Data Qualified	0.60	NONE	NONE	1.2	71	1	1	No	No	No	NA	No
8	020	Bromoform	ug/L	All Data Qualified	0.60	NONE	NONE	4.3	360	NONE	360	No	No	No	NA	No
8	021	Carbon Tetrachloride	ug/L	All Data Qualified	0.60	NONE	NONE	0.25	4.4	600	4.4	No	No	No	NA	No
8	022	Chlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	680	21000	NONE	21000	No	No	No	NA	No
8	023	Dibromochloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.401	34	NONE	34	No	No	No	NA	No
8	024	Chloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	025	2-Chloroethylvinylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	026	Chloroform	ug/L	All Data Qualified	0.60	NONE	NONE	Reserved	Reserved	NONE	NONE	No	No	No	NA	No

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C					Step 2	Step 3			Step 4	
						CTR CRITERIA				Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
Outfall	CTR	Constituent	Units	MEC	CV	Freshwater		Human Health								
						CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH							
8	027	Bromodichloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.56	46	NONE	46	No	No	No	NA	No
8	028	1,1-Dichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	5	5	No	No	No	NA	No
8	029	1,2-Dichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.38	99	0.5	0.5	No	No	No	NA	No
8	030	1,1-Dichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	0.057	3.2	6	3.2	No	No	No	NA	No
8	031	1,2-Dichloropropane	ug/L	All Data Qualified	0.60	NONE	NONE	0.52	39	5	5	No	No	No	NA	No
8	032	1,3-Dichloropropene (Total)	ug/L	All Data Qualified	0.60	NONE	NONE	10	1700	0.5	0.5	No	No	No	NA	No
8	033	Ethylbenzene	ug/L	All Data Qualified	0.60	NONE	NONE	3100	29000	0.7	0.7	No	No	No	NA	No
8	034	Bromomethane	ug/L	All Data Qualified	0.60	NONE	NONE	48	4000	NONE	4000	No	No	No	NA	No
8	035	Chloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	NONE	NONE	No	No	No	NA	No
8	036	Methylene chloride	ug/L	All Data Qualified	0.60	NONE	NONE	4.7	1600	NONE	1600	No	No	No	NA	No
8	037	1,1,2,2-Tetrachloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.17	11	1	1	No	No	No	NA	No
8	038	Tetrachloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	0.8	8.85	5	5	No	No	No	NA	No
8	039	Toluene	ug/L	All Data Qualified	0.60	NONE	NONE	6800	200000	150	150	No	No	No	NA	No
8	040	trans-1,2-Dichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	700	140000	10	10	No	No	No	NA	No
8	041	1,1,1-Trichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	200	200	No	No	No	NA	No
8	042	1,1,2-trichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.6	42	5	5	No	No	No	NA	No
8	043	Trichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	2.7	81	5	5	No	No	No	NA	No
8	044	Vinyl chloride	ug/L	All Data Qualified	0.60	NONE	NONE	2	525	0.5	0.5	No	No	No	NA	No
8	045	2-chlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	120	400	NONE	400	No	No	No	NA	No
8	046	2,4-Dichlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	93	790	NONE	790	No	No	No	NA	No
8	047	2,4-dimethylphenol	ug/L	All Data Qualified	0.60	NONE	NONE	540	2300	NONE	2300	No	No	No	NA	No
8	048	2-Methyl-4,6-dinitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	13.4	765	NONE	765	No	No	No	NA	No

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C					Step 2	Step 3			Step 4	
						CTR CRITERIA				Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
Outfall	CTR	Constituent	Units	MEC	CV	Freshwater		Human Health								
						CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH							
8	049	2,4-dinitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	70	14000	NONE	14000	No	No	No	NA	No
8	050	2-nitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	051	4-nitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	052	4-Chloro-3-methylphenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	053	Pentachlorophenol	ug/L	All Data Qualified	0.60	pH dependent	pH dependent	0.28	8.2	1	1	No	No	No	NA	No
8	054	Phenol	ug/L	All Data Qualified	0.60	NONE	NONE	21000	4600000	NONE	4600000	No	No	No	NA	No
8	055	2,4,6-Trichlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	2.1	6.5	NONE	6.5	No	No	No	NA	No
8	056	Acenaphthene	ug/L	All Data Qualified	0.60	NONE	NONE	1200	2700	NONE	2700	No	No	No	NA	No
8	057	Acenaphthylene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	058	Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	9600	110000	NONE	110000	No	No	No	NA	No
8	059	Benizidine	ug/L	All Data Qualified	0.60	NONE	NONE	0.00012	0.00054	NONE	0.00054	No	No	No	NA	No
8	060	Benzo(a)Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
8	061	Benzo(a)Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
8	062	Benzo(b)Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
8	063	Benzo(g,h,i)Perylene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	064	Benzo(k)Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
8	065	Bis(2-Chloroethoxy) methane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	066	bis (2-Chloroethyl) ether	ug/L	All Data Qualified	0.60	NONE	NONE	0.031	1.4	NONE	1.4	No	No	No	NA	No
8	067	Bis(2-Chloroisopropyl) Ether	ug/L	All Data Qualified	0.60	NONE	NONE	1400	170000	NONE	170000	No	No	No	NA	No
8	068	bis (2-ethylhexyl) Phthalate	ug/L	All Data Qualified	0.60	NONE	NONE	1.8	5.9	4	4	No	No	No	NA	No
8	069	4-Bromophenylphenylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	070	Butylbenzylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	3000	5200	NONE	5200	No	No	No	NA	No

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C					Step 2	Step 3			Step 4	
						CTR CRITERIA				Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
Outfall	CTR	Constituent	Units	MEC	CV	Freshwater		Human Health								
						CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH							
8	071	2-Chloronaphthalene	ug/L	All Data Qualified	0.60	NONE	NONE	1700	4300	NONE	4300	No	No	No	NA	No
8	072	4-Chlorophenylphenylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	073	Chrysene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
8	074	Dibenzo(a,h)Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No
8	075	1,2-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	2700	17000	600	600	No	No	No	NA	No
8	076	1,3-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	400	2600	NONE	2600	No	No	No	NA	No
8	077	1,4-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	400	2600	5	5	No	No	No	NA	No
8	078	3,3'-Dichlorobenzidine	ug/L	All Data Qualified	0.60	NONE	NONE	0.04	0.077	NONE	0.077	No	No	No	NA	No
8	079	Diethylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	23000	120000	NONE	120000	No	No	No	NA	No
8	080	Dimethylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	313000	2900000	NONE	2900000	No	No	No	NA	No
8	081	Di-n-butylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	2700	12000	NONE	12000	No	No	No	NA	No
8	082	2,4-Dinitrotoluene	ug/L	All Data Qualified	0.60	NONE	NONE	0.11	9.1	NONE	9.1	No	No	No	NA	No
8	083	2,6-Dinitrotoluene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	084	Di-n-octylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	085	1,2-Diphenylhydrazine	ug/L	All Data Qualified	0.60	NONE	NONE	0.04	0.54	NONE	0.54	No	No	No	NA	No
8	086	Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	300	370	NONE	370	No	No	No	NA	No
8	087	Fluorene	ug/L	All Data Qualified	0.60	NONE	NONE	1300	14000	NONE	14000	No	No	No	NA	No
8	088	Hexachlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	0.00075	0.00077	NONE	0.00077	No	No	No	NA	No
8	089	Hexachlorobutadiene	ug/L	All Data Qualified	0.60	NONE	NONE	0.44	50	NONE	50	No	No	No	NA	No
8	090	Hexachlorocyclopentadiene	ug/L	All Data Qualified	0.60	NONE	NONE	240	17000	NONE	17000	No	No	No	NA	No
8	091	Hexachloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	1.9	8.9	NONE	8.9	No	No	No	NA	No
8	092	Indeno(1,2,3-cd)Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C					Step 2	Step 3			Step 4	
						CTR CRITERIA				Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
Outfall	CTR	Constituent	Units	MEC	CV	Freshwater		Human Health								
						CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH							
8	093	Isophorone	ug/L	All Data Qualified	0.60	NONE	NONE	8.4	600	NONE	600	No	No	No	NA	No
8	094	Naphthalene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	095	Nitrobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	17	1900	NONE	1900	No	No	No	NA	No
8	096	N-Nitrosodimethylamine	ug/L	All Data Qualified	0.60	NONE	NONE	0.00069	8.1	NONE	8.1	No	No	No	NA	No
8	097	n-Nitroso-di-n-propylamine	ug/L	All Data Qualified	0.60	NONE	NONE	0.005	1.4	NONE	1.4	No	No	No	NA	No
8	098	N-Nitrosodiphenylamine	ug/L	All Data Qualified	0.60	NONE	NONE	5	16	NONE	16	No	No	No	NA	No
8	099	Phenanthrene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	100	Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	960	11000	NONE	11000	No	No	No	NA	No
8	101	1,2,4-Trichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	102	Aldrin	ug/L	All Data Qualified	0.60	3	NONE	0.00013	0.00014	NONE	0.00014	No	No	No	NA	No
8	103	alpha-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	0.0039	0.013	NONE	0.013	No	No	No	NA	No
8	104	beta-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	0.014	0.046	NONE	0.046	No	No	No	NA	No
8	105	Lindane (gamma-BHC)	ug/L	All Data Qualified	0.60	0.95	NONE	0.019	0.063	0.2	0.063	No	No	No	NA	No
8	106	delta-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No
8	107	Chlordane	ug/L	All Data Qualified	0.60	2.4	0.0043	0.00057	0.00059	NONE	0.00059	No	No	No	NA	No
8	108	4,4'-DDT	ug/L	All Data Qualified	0.60	1.1	0.001	0.00059	0.00059	NONE	0.00059	No	No	No	NA	No
8	109	4,4'-DDE	ug/L	All Data Qualified	0.60	NONE	NONE	0.00059	0.00059	NONE	0.00059	No	No	No	NA	No
8	110	4,4'-DDD	ug/L	All Data Qualified	0.60	NONE	NONE	0.00083	0.00084	NONE	0.00084	No	No	No	NA	No
8	111	Dieldrin	ug/L	All Data Qualified	0.60	0.24	0.056	0.00014	0.00014	NONE	0.00014	No	No	No	NA	No
8	112	Endosulfan I	ug/L	All Data Qualified	0.60	0.22	0.056	110	240	NONE	0.056	No	No	No	NA	No
8	113	Endosulfan II	ug/L	All Data Qualified	0.60	0.22	0.056	110	240	NONE	0.056	No	No	No	NA	No
8	114	Endosulfan Sulfate	ug/L	All Data Qualified	0.60	NONE	NONE	110	240	NONE	240	No	No	No	NA	No

**Table F1
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 003-007, 010, 008)**

**FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C					Step 2	Step 3			Step 4	
						CTR CRITERIA				Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
Outfall	CTR	Constituent	Units	MEC	CV	Freshwater		Human Health								
						CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH							
8	115	Endrin	ug/L	All Data Qualified	0.60	0.086	0.036	0.76	0.81	NONE	0.036	No	No	No	NA	No
8	116	Endrin Aldehyde	ug/L	All Data Qualified	0.60	NONE	NONE	0.76	0.81	NONE	0.81	No	No	No	NA	No
8	117	Heptachlor	ug/L	All Data Qualified	0.60	0.52	0.0038	0.00021	0.00021	NONE	0.00021	No	No	No	NA	No
8	118	Heptachlor Epoxide	ug/L	All Data Qualified	0.60	0.52	0.0038	0.0001	0.00011	NONE	0.00011	No	No	No	NA	No
8	119	Aroclor-1016	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No
8	120	Aroclor-1221	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No
8	121	Aroclor-1232	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No
8	122	Aroclor-1242	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No
8	123	Aroclor-1248	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No
8	124	Aroclor-1254	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No
8	125	Aroclor-1260	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No
8	126	Toxaphene	ug/L	All Data Qualified	0.60	0.73	0.0002	0.0073	0.00075	NONE	0.0002	No	No	No	NA	No

Table F2
REASONABLE POTENTIAL ANALYSIS FOR SECONDARY POLLUTANTS, (OUTFALLS 003 - 007, 010, and 008)

FOURTH QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309

Outfall	Constituent	Monitoring	Units	Number of Samples	MEC	CV	Multiplier	Projected Maximum Effluent Concentration (99/99)	Dilution Ratio	Background Concentration	Projected Maximum Receiving Water Concentration	Step 1, Determine Water Quality Objectives	BU - Beneficial use protection NC-Human noncarcinogen AP-Aquatic life protection
3_7, 10	Boron	Annual	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	1	BU
3_7, 10	Chloride	Discharge	mg/L	7	44	0.60	3.54	155.90	0	0	155.90	150	BU
3_7, 10	Fluoride	Annual	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	1.6	BU
3_7, 10	Nitrate + Nitrite as Nitrogen (N)	Discharge	mg/L	7	6.4	0.60	3.54	22.68	0	0	22.68	8	BU/TMDL
3_7, 10	Oil & Grease	Discharge	mg/L	7	3.9	0.60	3.54	13.82	0	0	13.82	10	BU
3_7, 10	Sulfate	Discharge	mg/L	7	47	0.60	3.54	166.53	0	0	166.53	300	BU
3_7, 10	Total Dissolved Solids	Discharge	mg/L	7	310	0.60	3.54	1098.40	0	0	1098.40	150	BU
3_7, 10	Total Suspended Solids	Annual	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	45	BU
8	Boron	Annual	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	1	BU
8	Chloride	Discharge	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	150	BU
8	Fluoride	Annual	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	1.6	BU
8	Nitrate + Nitrite as Nitrogen (N)	Discharge	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	8	BU/TMDL
8	Oil & Grease	Discharge	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	10	BU
8	Sulfate	Discharge	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	300	BU
8	Total Dissolved Solids	Discharge	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	150	BU
8	Total Suspended Solids	Annual	mg/L	0	All Data Qualified	0.60	All Data Qualified	All Qualified Data	0	0	NA	45	BU

**Table F3
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 012, 013 014)**

**FIRST QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
12_14	001	Antimony	ug/L	All Data Qualified	0.60	NONE	NONE	14	4300	6	6	No	No	No	NA	No		
12_14	002	Arsenic	ug/L	All Data Qualified	0.60	340	150	NONE	NONE	50	50	No	No	No	NA	No		
12_14	003	Beryllium	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	4	4	No	No	No	NA	No		
12_14	004	Cadmium	ug/L	2.5	0.60	NONE	2.5	Narrative	Narrative	5	2.5	Yes	Yes	NA	NA	Yes		
12_14	005a	Chromium	ug/L	All Data Qualified	0.60	NONE	207.0	Narrative	Narrative	NONE	207.0	No	No	No	NA	No		
12_14	005b	Chromium VI	ug/L	All Data Qualified	0.60	16.3	11.4	Narrative	Narrative	50	11.4	No	No	No	NA	No		
12_14	006	Copper	ug/L	4.9	0.60	NONE	9.3	1300	NONE	NONE	9.3	Yes	Yes	NA	NA	No		
12_14	007	Lead	ug/L	2.2	0.60	NONE	3.2	Narrative	Narrative	NONE	3.2	Yes	Yes	NA	NA	No		
12_14	008	Mercury	ug/L	All Data Qualified	0.60	Reserved	Reserved	0.05	0.051	2	0.051	No	No	No	NA	No		
12_14	009	Nickel	ug/L	All Data Qualified	0.60	NONE	52.2	610	4600	100	52.2	No	No	No	NA	No		
12_14	010	Selenium	ug/L	0.32	0.60	Reserved	5	Narrative	Narrative	50	5	Yes	Yes	NA	NA	No		
12_14	011	Silver	ug/L	All Data Qualified	0.60	NONE	none	NONE	NONE	NONE	4.06	No	No	No	NA	No		
12_14	012	Thallium	ug/L	All Data Qualified	0.60	NONE	NONE	1.7	6.3	2	2	No	No	No	NA	No		
12_14	013	Zinc	ug/L	79	0.60	NONE	119.8	none	NONE	NONE	119.8	Yes	Yes	NA	NA	No		
12_14	014	Total Cyanide	ug/L	All Data Qualified	0.60	22	5.2	700	220000	200	5.2	No	No	No	NA	No		
12_14	015	Asbestos	Fibers/L	All Data Qualified	0.60	NONE	NONE	7000000	NONE	7x10^6	700000	No	No	No	NA	No		
12_14	016	TCDD TEQ_NoDNQ	ug/L	2.78E-08	0.60	NONE	NONE	1.3e-008	1.4e-008	3x10^-5	1.40E-08	Yes	Yes	NA	NA	Yes		
12_14	017	Acrolein	ug/L	All Data Qualified	0.60	NONE	NONE	320	780	NONE	780	No	No	No	NA	No		
12_14	018	Acrylonitrile	ug/L	All Data Qualified	0.60	NONE	NONE	0.059	0.66	NONE	0.66	No	No	No	NA	No		
12_14	019	Benzene	ug/L	All Data Qualified	0.60	NONE	NONE	1.2	71	1	1	No	No	No	NA	No		
12_14	020	Bromoform	ug/L	All Data Qualified	0.60	NONE	NONE	4.3	360	NONE	360	No	No	No	NA	No		
12_14	021	Carbon Tetrachloride	ug/L	All Data Qualified	0.60	NONE	NONE	0.25	4.4	600	4.4	No	No	No	NA	No		

**Table F3
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 012, 013 014)**

**FIRST QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
12_14	022	Chlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	680	21000	NONE	21000	No	No	No	NA	No		
12_14	023	Dibromochloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.401	34	NONE	34	No	No	No	NA	No		
12_14	024	Chloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	025	2-Chloroethylvinylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	026	Chloroform	ug/L	All Data Qualified	0.60	NONE	NONE	Reserved	Reserved	NONE	NONE	No	No	No	NA	No		
12_14	027	Bromodichloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.56	46	NONE	46	No	No	No	NA	No		
12_14	028	1,1-Dichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	5	5	No	No	No	NA	No		
12_14	029	1,2-Dichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.38	99	0.5	0.5	No	No	No	NA	No		
12_14	030	1,1-Dichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	0.057	3.2	6	3.2	No	No	No	NA	No		
12_14	031	1,2-Dichloropropane	ug/L	All Data Qualified	0.60	NONE	NONE	0.52	39	5	5	No	No	No	NA	No		
12_14	032	1,3-Dichloropropene (Total)	ug/L	All Data Qualified	0.60	NONE	NONE	10	1700	0.5	0.5	No	No	No	NA	No		
12_14	033	Ethylbenzene	ug/L	All Data Qualified	0.60	NONE	NONE	3100	29000	0.7	0.7	No	No	No	NA	No		
12_14	034	Bromomethane	ug/L	All Data Qualified	0.60	NONE	NONE	48	4000	NONE	4000	No	No	No	NA	No		
12_14	035	Chloromethane	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	NONE	NONE	No	No	No	NA	No		
12_14	036	Methylene chloride	ug/L	All Data Qualified	0.60	NONE	NONE	4.7	1600	NONE	1600	No	No	No	NA	No		
12_14	037	1,1,2,2-Tetrachloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.17	11	1	1	No	No	No	NA	No		
12_14	038	Tetrachloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	0.8	8.85	5	5	No	No	No	NA	No		
12_14	039	Toluene	ug/L	All Data Qualified	0.60	NONE	NONE	6800	200000	150	150	No	No	No	NA	No		
12_14	040	trans-1,2-Dichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	700	140000	10	10	No	No	No	NA	No		
12_14	041	1,1,1-Trichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	Narrative	Narrative	200	200	No	No	No	NA	No		
12_14	042	1,1,2-trichloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	0.6	42	5	5	No	No	No	NA	No		
12_14	043	Trichloroethene	ug/L	All Data Qualified	0.60	NONE	NONE	2.7	81	5	5	No	No	No	NA	No		

**Table F3
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 012, 013 014)**

**FIRST QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
12_14	044	Vinyl chloride	ug/L	All Data Qualified	0.60	NONE	NONE	2	525	0.5	0.5	No	No	No	NA	No		
12_14	045	2-chlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	120	400	NONE	400	No	No	No	NA	No		
12_14	046	2,4-Dichlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	93	790	NONE	790	No	No	No	NA	No		
12_14	047	2,4-dimethylphenol	ug/L	All Data Qualified	0.60	NONE	NONE	540	2300	NONE	2300	No	No	No	NA	No		
12_14	048	2-Methyl-4,6-dinitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	13.4	765	NONE	765	No	No	No	NA	No		
12_14	049	2,4-dinitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	70	14000	NONE	14000	No	No	No	NA	No		
12_14	050	2-nitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	051	4-nitrophenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	052	4-Chloro-3-methylphenol	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	053	Pentachlorophenol	ug/L	All Data Qualified	0.60	pH dependent	pH dependent	0.28	8.2	1	1	No	No	No	NA	No		
12_14	054	Phenol	ug/L	All Data Qualified	0.60	NONE	NONE	21000	4600000	NONE	4600000	No	No	No	NA	No		
12_14	055	2,4,6-Trichlorophenol	ug/L	All Data Qualified	0.60	NONE	NONE	2.1	6.5	NONE	6.5	No	No	No	NA	No		
12_14	056	Acenaphthene	ug/L	All Data Qualified	0.60	NONE	NONE	1200	2700	NONE	2700	No	No	No	NA	No		
12_14	057	Acenaphthylene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	058	Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	9600	110000	NONE	110000	No	No	No	NA	No		
12_14	059	Benzidine	ug/L	All Data Qualified	0.60	NONE	NONE	0.00012	0.00054	NONE	0.00054	No	No	No	NA	No		
12_14	060	Benzo(a)Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
12_14	061	Benzo(a)Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
12_14	062	Benzo(b)Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
12_14	063	Benzo(g,h,i)Perylene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	064	Benzo(k)Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
12_14	065	Bis(2-Chloroethoxy) methane	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		

**Table F3
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 012, 013 014)**

**FIRST QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
12_14	066	bis (2-Chloroethyl) ether	ug/L	All Data Qualified	0.60	NONE	NONE	0.031	1.4	NONE	1.4	No	No	No	NA	No		
12_14	067	Bis(2-Chloroisopropyl) Ether	ug/L	All Data Qualified	0.60	NONE	NONE	1400	170000	NONE	170000	No	No	No	NA	No		
12_14	068	bis (2-ethylhexyl) Phthalate	ug/L	All Data Qualified	0.60	NONE	NONE	1.8	5.9	4	4	No	No	No	NA	No		
12_14	069	4-Bromophenylphenylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	070	Butylbenzylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	3000	5200	NONE	5200	No	No	No	NA	No		
12_14	071	2-Chloronaphthalene	ug/L	All Data Qualified	0.60	NONE	NONE	1700	4300	NONE	4300	No	No	No	NA	No		
12_14	072	4-Chlorophenylphenylether	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	073	Chrysene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
12_14	074	Dibenzo(a,h)Anthracene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
12_14	075	1,2-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	2700	17000	600	600	No	No	No	NA	No		
12_14	076	1,3-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	400	2600	NONE	2600	No	No	No	NA	No		
12_14	077	1,4-Dichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	400	2600	5	5	No	No	No	NA	No		
12_14	078	3,3'-Dichlorobenzidine	ug/L	All Data Qualified	0.60	NONE	NONE	0.04	0.077	NONE	0.077	No	No	No	NA	No		
12_14	079	Diethylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	23000	120000	NONE	120000	No	No	No	NA	No		
12_14	080	Dimethylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	313000	2900000	NONE	2900000	No	No	No	NA	No		
12_14	081	Di-n-butylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	2700	12000	NONE	12000	No	No	No	NA	No		
12_14	082	2,4-Dinitrotoluene	ug/L	All Data Qualified	0.60	NONE	NONE	0.11	9.1	NONE	9.1	No	No	No	NA	No		
12_14	083	2,6-Dinitrotoluene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	084	Di-n-octylphthalate	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	085	1,2-Diphenylhydrazine	ug/L	All Data Qualified	0.60	NONE	NONE	0.04	0.54	NONE	0.54	No	No	No	NA	No		
12_14	086	Fluoranthene	ug/L	All Data Qualified	0.60	NONE	NONE	300	370	NONE	370	No	No	No	NA	No		
12_14	087	Fluorene	ug/L	All Data Qualified	0.60	NONE	NONE	1300	14000	NONE	14000	No	No	No	NA	No		

**Table F3
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 012, 013 014)**

**FIRST QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
12_14	088	Hexachlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	0.00075	0.00077	NONE	0.00077	No	No	No	NA	No		
12_14	089	Hexachlorobutadiene	ug/L	All Data Qualified	0.60	NONE	NONE	0.44	50	NONE	50	No	No	No	NA	No		
12_14	090	Hexachlorocyclopentadiene	ug/L	All Data Qualified	0.60	NONE	NONE	240	17000	NONE	17000	No	No	No	NA	No		
12_14	091	Hexachloroethane	ug/L	All Data Qualified	0.60	NONE	NONE	1.9	8.9	NONE	8.9	No	No	No	NA	No		
12_14	092	Indeno(1,2,3-cd)Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	0.0044	0.049	NONE	0.049	No	No	No	NA	No		
12_14	093	Isophorone	ug/L	All Data Qualified	0.60	NONE	NONE	8.4	600	NONE	600	No	No	No	NA	No		
12_14	094	Naphthalene	ug/L	Available Data <DL	0.60	NONE	NONE	NONE	NONE	NONE	NONE	Yes	No	No	NA	No		
12_14	095	Nitrobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	17	1900	NONE	1900	No	No	No	NA	No		
12_14	096	N-Nitrosodimethylamine	ug/L	Available Data <DL	0.60	NONE	NONE	0.00069	8.1	NONE	8.1	Yes	No	No	NA	No		
12_14	097	n-Nitroso-di-n-propylamine	ug/L	All Data Qualified	0.60	NONE	NONE	0.005	1.4	NONE	1.4	No	No	No	NA	No		
12_14	098	N-Nitrosodiphenylamine	ug/L	All Data Qualified	0.60	NONE	NONE	5	16	NONE	16	No	No	No	NA	No		
12_14	099	Phenanthrene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	100	Pyrene	ug/L	All Data Qualified	0.60	NONE	NONE	960	11000	NONE	11000	No	No	No	NA	No		
12_14	101	1,2,4-Trichlorobenzene	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	102	Aldrin	ug/L	All Data Qualified	0.60	3	NONE	0.00013	0.00014	NONE	0.00014	No	No	No	NA	No		
12_14	103	alpha-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	0.0039	0.013	NONE	0.013	No	No	No	NA	No		
12_14	104	beta-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	0.014	0.046	NONE	0.046	No	No	No	NA	No		
12_14	105	Lindane (gamma-BHC)	ug/L	All Data Qualified	0.60	0.95	NONE	0.019	0.063	0.2	0.063	No	No	No	NA	No		
12_14	106	delta-BHC	ug/L	All Data Qualified	0.60	NONE	NONE	NONE	NONE	NONE	NONE	No	No	No	NA	No		
12_14	107	Chlordane	ug/L	All Data Qualified	0.60	2.4	0.0043	0.00057	0.00059	NONE	0.00059	No	No	No	NA	No		
12_14	108	4,4'-DDT	ug/L	All Data Qualified	0.60	1.1	0.001	0.00059	0.00059	NONE	0.00059	No	No	No	NA	No		
12_14	109	4,4'-DDE	ug/L	All Data Qualified	0.60	NONE	NONE	0.00059	0.00059	NONE	0.00059	No	No	No	NA	No		

**Table F3
REASONABLE POTENTIAL ANALYSIS FOR PRIORITY POLLUTANTS, (OUTFALLS 012, 013 014)**

**FIRST QUARTER 2008
THE BOEING COMPANY
SANTA SUSANA FIELD LABORATORY
NPDES PERMIT CA0001309**

						Step 1: Water Quality Criteria, Determine C						Step 2	Step 3			Step 4		
						CTR CRITERIA						Basin Plan Title 22 GWR	C = Lowest Criteria	Is Effluent Data Available	Was Constituent Detected in Effluent Data	Are all Detection Limits > C	If DL > C, MEC = Min (DL)	MEC >= C
						Freshwater			Human Health									
Outfall	CTR	Constituent	Units	MEC	CV	CMC = Acute	CCC = Chronic	HH W&O (Not App)	HH O = HH									
12_14	110	4,4'-DDD	ug/L	All Data Qualified	0.60	NONE	NONE	0.00083	0.00084	NONE	0.00084	No	No	No	NA	No		
12_14	111	Dieldrin	ug/L	All Data Qualified	0.60	0.24	0.056	0.00014	0.00014	NONE	0.00014	No	No	No	NA	No		
12_14	112	Endosulfan I	ug/L	All Data Qualified	0.60	0.22	0.056	110	240	NONE	0.056	No	No	No	NA	No		
12_14	113	Endosulfan II	ug/L	All Data Qualified	0.60	0.22	0.056	110	240	NONE	0.056	No	No	No	NA	No		
12_14	114	Endosulfan Sulfate	ug/L	All Data Qualified	0.60	NONE	NONE	110	240	NONE	240	No	No	No	NA	No		
12_14	115	Endrin	ug/L	All Data Qualified	0.60	0.086	0.036	0.76	0.81	NONE	0.036	No	No	No	NA	No		
12_14	116	Endrin Aldehyde	ug/L	All Data Qualified	0.60	NONE	NONE	0.76	0.81	NONE	0.81	No	No	No	NA	No		
12_14	117	Heptachlor	ug/L	All Data Qualified	0.60	0.52	0.0038	0.00021	0.00021	NONE	0.00021	No	No	No	NA	No		
12_14	118	Heptachlor Epoxide	ug/L	All Data Qualified	0.60	0.52	0.0038	0.0001	0.00011	NONE	0.00011	No	No	No	NA	No		
12_14	119	Aroclor-1016	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
12_14	120	Aroclor-1221	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
12_14	121	Aroclor-1232	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
12_14	122	Aroclor-1242	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
12_14	123	Aroclor-1248	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
12_14	124	Aroclor-1254	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
12_14	125	Aroclor-1260	ug/L	All Data Qualified	0.60	NONE	0.014	0.00017	0.00017	NONE	0.00017	No	No	No	NA	No		
12_14	126	Toxaphene	ug/L	All Data Qualified	0.60	0.73	0.0002	0.0073	0.00075	NONE	0.0002	No	No	No	NA	No		