

APPENDIX G

Section 36

Outfall 011 – December 22 & 23, 2010

Test America Analytical Laboratory Report

THIS PAGE LEFT INTENTIONALLY BLANK

LABORATORY REPORT

Prepared For: MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project: Quarterly Outfall 011 2010
Quarterly Outfall 011

Sampled: 12/22/10-12/23/10
Received: 12/22/10
Issued: 02/06/11 16:56

NELAP #01108CA California ELAP#2706 CSDLAC #10256 AZ #AZ0671 NV #CA01531

*The results listed within this Laboratory Report pertain only to the samples tested in the laboratory. The analyses contained in this report were performed in accordance with the applicable certifications as noted. All soil samples are reported on a wet weight basis unless otherwise noted in the report. This Laboratory Report is confidential and is intended for the sole use of TestAmerica and its client. This report shall not be reproduced, except in full, without written permission from TestAmerica. The Chain(s) of Custody, 3 pages, are included and are an integral part of this report.
This entire report was reviewed and approved for release.*

CASE NARRATIVE

SAMPLE RECEIPT: Samples were received intact, at 2°C, on ice and with chain of custody documentation.

HOLDING TIMES: All samples were analyzed within prescribed holding times and/or in accordance with the TestAmerica Sample Acceptance Policy unless otherwise noted in the report.

PRESERVATION: Samples requiring preservation were verified prior to sample analysis.

QA/QC CRITERIA: All analyses met method criteria, except as noted in the report with data qualifiers.

COMMENTS: Results that fall between the MDL and RL are 'J' flagged.

SUBCONTRACTED: Refer to the last page for specific subcontract laboratory information included in this report.

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

**ADDITIONAL
INFORMATION:**

WATER, 1613B, Dioxins/Furans with Totals

Some analytes in this sample and the associated method blank have an ion abundance ratio that is outside of criteria. The analytes are considered as an "estimated maximum possible concentration" (EMPC) because the quantitation is based on the theoretical ion abundance ratio. Analytical results are reported with a "Q" flag.

The method blank associated with this extraction batch has a detected concentration of OCDD above the reporting limit (RL) indicating a potential high bias in the data. After discussion with the client, the data is reported with a "B" flag and no further action is required for this sample.

The laboratory control sample (LCS) associated with this extraction batch has percent recoveries for 1,2,3,4,6,7,8-HpCDF and OCDD above the established control limits indicating a potential high bias in the data. It was determined that the cause of the elevated recoveries is due the spiking solution used for the LCS had concentrated. The QC Check data is included in the sample extraction section of the raw data. After discussion with the client, the data is reported and no further action is required for this sample.

LABORATORY ID

ITL2272-01
ITL2272-02
ITL2272-03
ITL2272-04

CLIENT ID


Outfall 011 (Grab)
Trip Blanks
Outfall 011 (Composite)
Trip Blank

MATRIX

Water
Water
Water
Water

I certify under penalty of perjury that the information contained in this report and all attachments was produced in accordance with the indicated methods and laboratory standard operating procedures, except as noted, and are complete and accurate to the best of my knowledge and belief. Subcontract laboratory reports that are attached have been evaluated for completeness and quality control acceptability.

Reviewed By:



TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

PURGEABLES BY GC/MS (EPA 624)

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-01 (Outfall 011 (Grab) - Water)					Sampled: 12/22/10				
Reporting Units: ug/l									
Benzene	EPA 624	10L2971	0.28	0.50	ND	1	ALE	12/27/10	
Carbon tetrachloride	EPA 624	10L2971	0.28	0.50	ND	1	ALE	12/27/10	
Chloroform	EPA 624	10L2971	0.33	0.50	ND	1	ALE	12/27/10	
1,1-Dichloroethane	EPA 624	10L2971	0.40	0.50	ND	1	ALE	12/27/10	
1,2-Dichloroethane	EPA 624	10L2971	0.28	0.50	ND	1	ALE	12/27/10	
1,1-Dichloroethene	EPA 624	10L2971	0.42	0.50	ND	1	ALE	12/27/10	
Ethylbenzene	EPA 624	10L2971	0.25	0.50	ND	1	ALE	12/27/10	
Tetrachloroethene	EPA 624	10L2971	0.32	0.50	ND	1	ALE	12/27/10	
Toluene	EPA 624	10L2971	0.36	0.50	ND	1	ALE	12/27/10	
1,1,1-Trichloroethane	EPA 624	10L2971	0.30	0.50	ND	1	ALE	12/27/10	
1,1,2-Trichloroethane	EPA 624	10L2971	0.30	0.50	ND	1	ALE	12/27/10	
Trichloroethene	EPA 624	10L2971	0.26	0.50	ND	1	ALE	12/27/10	
Trichlorofluoromethane	EPA 624	10L2971	0.34	0.50	ND	1	ALE	12/27/10	
Trichlorotrifluoroethane (Freon 113)	EPA 624	10L2971	0.50	5.0	ND	1	ALE	12/27/10	
Vinyl chloride	EPA 624	10L2971	0.40	0.50	ND	1	ALE	12/27/10	
Xylenes, Total	EPA 624	10L2971	0.90	1.5	ND	1	ALE	12/27/10	
<i>Surrogate: 4-Bromofluorobenzene (80-120%)</i>					98 %				
<i>Surrogate: Dibromofluoromethane (80-120%)</i>					108 %				
<i>Surrogate: Toluene-d8 (80-120%)</i>					104 %				
Sample ID: ITL2272-02 (Trip Blanks - Water)					Sampled: 12/22/10				
Reporting Units: ug/l									
Benzene	EPA 624	10L2971	0.28	0.50	ND	1	ALE	12/27/10	
Carbon tetrachloride	EPA 624	10L2971	0.28	0.50	ND	1	ALE	12/27/10	
Chloroform	EPA 624	10L2971	0.33	0.50	ND	1	ALE	12/27/10	
1,1-Dichloroethane	EPA 624	10L2971	0.40	0.50	ND	1	ALE	12/27/10	
1,2-Dichloroethane	EPA 624	10L2971	0.28	0.50	ND	1	ALE	12/27/10	
1,1-Dichloroethene	EPA 624	10L2971	0.42	0.50	ND	1	ALE	12/27/10	
Ethylbenzene	EPA 624	10L2971	0.25	0.50	ND	1	ALE	12/27/10	
Tetrachloroethene	EPA 624	10L2971	0.32	0.50	ND	1	ALE	12/27/10	
Toluene	EPA 624	10L2971	0.36	0.50	ND	1	ALE	12/27/10	
1,1,1-Trichloroethane	EPA 624	10L2971	0.30	0.50	ND	1	ALE	12/27/10	
1,1,2-Trichloroethane	EPA 624	10L2971	0.30	0.50	ND	1	ALE	12/27/10	
Trichloroethene	EPA 624	10L2971	0.26	0.50	ND	1	ALE	12/27/10	
Trichlorofluoromethane	EPA 624	10L2971	0.34	0.50	ND	1	ALE	12/27/10	
Trichlorotrifluoroethane (Freon 113)	EPA 624	10L2971	0.50	5.0	ND	1	ALE	12/27/10	
Vinyl chloride	EPA 624	10L2971	0.40	0.50	ND	1	ALE	12/27/10	
Xylenes, Total	EPA 624	10L2971	0.90	1.5	ND	1	ALE	12/27/10	
<i>Surrogate: 4-Bromofluorobenzene (80-120%)</i>					97 %				
<i>Surrogate: Dibromofluoromethane (80-120%)</i>					105 %				
<i>Surrogate: Toluene-d8 (80-120%)</i>					102 %				

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

ACID & BASE/NEUTRALS BY GC/MS (EPA 625)

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: ug/l									
Bis(2-ethylhexyl)phthalate	EPA 625	10L2936	1.60	4.72	ND	0.943	LB	12/28/10	
2,4-Dinitrotoluene	EPA 625	10L2936	0.189	4.72	ND	0.943	LB	12/28/10	
N-Nitrosodimethylamine	EPA 625	10L2936	0.0943	4.72	ND	0.943	LB	12/28/10	
Pentachlorophenol	EPA 625	10L2936	0.0943	4.72	ND	0.943	LB	12/28/10	
2,4,6-Trichlorophenol	EPA 625	10L2936	0.0943	5.66	ND	0.943	LB	12/28/10	
<i>Surrogate: 2,4,6-Tribromophenol (40-120%)</i>					94 %				
<i>Surrogate: 2-Fluorobiphenyl (50-120%)</i>					78 %				
<i>Surrogate: 2-Fluorophenol (30-120%)</i>					67 %				
<i>Surrogate: Nitrobenzene-d5 (45-120%)</i>					74 %				
<i>Surrogate: Phenol-d6 (35-120%)</i>					72 %				
<i>Surrogate: Terphenyl-d14 (50-125%)</i>					89 %				

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

ORGANOCHLORINE PESTICIDES (EPA 608)

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water) - cont.					Sampled: 12/23/10				
Reporting Units: ug/l									
alpha-BHC	EPA 608	10L3051	0.0024	0.0094	ND	0.943	CN	12/28/10	
<i>Surrogate: Decachlorobiphenyl (45-120%)</i>					83 %				
<i>Surrogate: Tetrachloro-m-xylene (35-115%)</i>					67 %				

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

HEXANE EXTRACTABLE MATERIAL

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-01 (Outfall 011 (Grab) - Water)					Sampled: 12/22/10				
Reporting Units: mg/l									
Hexane Extractable Material (Oil & Grease)	EPA 1664A	10L2996	1.3	4.7	ND	1	LA	12/28/10	

TestAmerica Irvine

Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

ITL2272 <Page 6 of 45>

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METALS

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: mg/l									
Iron	EPA 200.7	10L3131	0.015	0.040	6.4	1	DP	12/28/10	
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: ug/l									
Mercury	EPA 245.1	10L3104	0.10	0.20	ND	1	DB	12/28/10	
Cadmium	EPA 200.8	10L3064	0.10	1.0	0.16	1	RDC	12/29/10	Ja
Zinc	EPA 200.7	10L3131	6.00	20.0	28.3	1	DP	12/28/10	
Copper	EPA 200.8	10L3064	0.500	2.00	6.29	1	RDC	12/29/10	
Lead	EPA 200.8	10L3064	0.200	1.00	4.55	1	RDC	12/29/10	
Manganese	EPA 200.8	10L3064	0.70	1.0	62	1	RDC	12/29/10	
Selenium	EPA 200.8	10L3064	0.50	2.0	ND	1	RDC	12/29/10	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

DISSOLVED METALS

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water) - cont.					Sampled: 12/23/10				
Reporting Units: mg/l									
Iron	EPA 200.7-Diss	10L3118	0.015	0.040	0.37	1	DP	12/28/10	
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: ug/l									
Mercury	EPA 245.1-Diss	10L3103	0.10	0.20	ND	1	DB	12/28/10	
Cadmium	EPA 200.8-Diss	10L3120	0.10	1.0	ND	1	RDC	12/29/10	
Zinc	EPA 200.7-Diss	10L3118	6.00	20.0	ND	1	DP	12/28/10	
Copper	EPA 200.8-Diss	10L3120	0.500	2.00	2.24	1	RDC	12/28/10	
Lead	EPA 200.8-Diss	10L3120	0.200	1.00	ND	1	RDC	12/29/10	
Manganese	EPA 200.8-Diss	10L3120	0.70	1.0	2.7	1	RDC	12/28/10	
Selenium	EPA 200.8-Diss	10L3120	0.50	2.0	ND	1	RDC	12/29/10	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

INORGANICS

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water) - cont.					Sampled: 12/23/10				
Reporting Units: mg/l									
Ammonia-N (Distilled)	SM4500NH3-C	10L3146	0.500	0.500	ND	1	TMK	12/28/10	
Biochemical Oxygen Demand	SM5210B	10L2931	0.50	2.0	1.0	1	XL	12/30/10	Ja
Chloride	EPA 300.0	10L2812	0.25	0.50	4.9	1	NN	12/23/10	
Nitrate-N	EPA 300.0	10L2812	0.060	0.11	0.22	1	NN	12/23/10	
Nitrite-N	EPA 300.0	10L2812	0.090	0.15	ND	1	NN	12/23/10	
Nitrate/Nitrite-N	EPA 300.0	10L2812	0.15	0.26	0.22	1	NN	12/23/10	Ja
Sulfate	EPA 300.0	10L2812	0.20	0.50	5.4	1	NN	12/23/10	
Surfactants (MBAS)	SM5540-C	10L2893	0.050	0.10	ND	1	SLA	12/23/10	
Total Dissolved Solids	SM2540C	10L3089	1.0	10	90	1	DC	12/28/10	
Total Suspended Solids	SM 2540D	10L3164	1.0	10	50	1	DC	12/28/10	

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

INORGANICS

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-01 (Outfall 011 (Grab) - Water)					Sampled: 12/22/10				
Reporting Units: ml/l									
Total Settleable Solids	SM2540F	10L2855	0.10	0.10	ND	1	AC1	12/23/10	
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: NTU									
Turbidity	EPA 180.1	10L2924	0.20	5.0	190	5	AC1	12/24/10	
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: ug/l									
Perchlorate	EPA 314.0	10L3015	0.90	4.0	ND	1	MN	12/28/10	
Total Cyanide	SM4500CN-E	10L3114	2.2	5.0	ND	1	HH	12/28/10	
Sample ID: ITL2272-01 (Outfall 011 (Grab) - Water)					Sampled: 12/22/10				
Reporting Units: umhos/cm @ 25C									
Specific Conductance	EPA 120.1	10L2765	1.0	1.0	120	1	MC	12/23/10	

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

8649

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Uranium, Total	8649	8649		1	0.477	1	CSS	01/20/11	Jb
Sample ID: ITL2272-04 (Trip Blank - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Uranium, Total	8649	8649		1	ND	1	CSS	01/20/11	U

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

900

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Gross Alpha	900	8649		3	5.1	1	KT	01/06/11	
Gross Beta	900	8649		4	5.75	1	KT	01/06/11	
Sample ID: ITL2272-04 (Trip Blank - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Gross Alpha	900	8649		3	0.004	1	KT	01/14/11	U
Gross Beta	900	8649		4	-0.182	1	KT	01/14/11	U

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

901.1

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Cesium-137	901.1	8649		20	ND	1	LS	01/05/11	U
Potassium-40	901.1	8649		25	ND	1	LS	01/05/11	U
Sample ID: ITL2272-04 (Trip Blank - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Cesium-137	901.1	8649		20	ND	1	LS	01/13/11	U
Potassium-40	901.1	8649		25	ND	1	LS	01/13/11	U

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

903.1

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Radium-226	903.1	8649		1	0.888	1	TM	01/22/11	Jb
Sample ID: ITL2272-04 (Trip Blank - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Radium-226	903.1	8649		1	0.158	1	TM	01/22/11	U

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

904

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Radium-228	904	8649		1	0.262	1	ASM	01/24/11	U
Sample ID: ITL2272-04 (Trip Blank - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Radium-228	904	8649		1	0.06	1	ASM	01/26/11	U

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

905

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Strontium-90	905	8649		2	-0.041	1	PAS	01/13/11	U
Sample ID: ITL2272-04 (Trip Blank - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Strontium-90	905	8649		2	0.015	1	ASM	01/24/11	U

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

906

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water)					Sampled: 12/23/10				
Reporting Units: pCi/L									
Tritium	906	8649		500	49.5	1	JO	01/12/11	U

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

EPA-5 1613Bx

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water) - cont.					Sampled: 12/23/10				
Reporting Units: ug/L									
1,2,3,4,6,7,8-HpCDD	EPA-5 1613B	363256	0.0000057	0.00005	3.7e-005	0.97	MO	12/30/10	J, B
1,2,3,4,6,7,8-HpCDF	EPA-5 1613B	363256	0.0000043	0.00005	1.3e-005	0.97	MO	12/30/10	J, Q, B
1,2,3,4,7,8,9-HpCDF	EPA-5 1613B	363256	0.0000059	0.00005	ND	0.97	MO	12/30/10	
1,2,3,4,7,8-HxCDD	EPA-5 1613B	363256	0.0000066	0.00005	ND	0.97	MO	12/30/10	
1,2,3,4,7,8-HxCDF	EPA-5 1613B	363256	0.0000059	0.00005	ND	0.97	MO	12/30/10	
1,2,3,6,7,8-HxCDD	EPA-5 1613B	363256	0.0000054	0.00005	ND	0.97	MO	12/30/10	
1,2,3,6,7,8-HxCDF	EPA-5 1613B	363256	0.0000058	0.00005	ND	0.97	MO	12/30/10	
1,2,3,7,8,9-HxCDD	EPA-5 1613B	363256	0.0000056	0.00005	ND	0.97	MO	12/30/10	
1,2,3,7,8,9-HxCDF	EPA-5 1613B	363256	0.0000065	0.00005	ND	0.97	MO	12/30/10	
1,2,3,7,8-PeCDD	EPA-5 1613B	363256	0.000011	0.00005	ND	0.97	MO	12/30/10	
1,2,3,7,8-PeCDF	EPA-5 1613B	363256	0.0000058	0.00005	ND	0.97	MO	12/30/10	
2,3,4,6,7,8-HxCDF	EPA-5 1613B	363256	0.0000054	0.00005	ND	0.97	MO	12/30/10	
2,3,4,7,8-PeCDF	EPA-5 1613B	363256	0.0000071	0.00005	ND	0.97	MO	12/30/10	
2,3,7,8-TCDD	EPA-5 1613B	363256	0.000003	0.00001	ND	0.97	MO	12/30/10	
2,3,7,8-TCDF	EPA-5 1613B	363256	0.0000021	0.00001	ND	0.97	MO	12/30/10	
OCDD	EPA-5 1613B	363256	0.000011	0.0001	0.00056	0.97	MO	12/30/10	B
OCDF	EPA-5 1613B	363256	0.000012	0.0001	2e-005	0.97	MO	12/30/10	J, Q, B
Total HpCDD	EPA-5 1613B	363256	0.0000057	0.00005	9.2e-005	0.97	MO	12/30/10	J, B
Total HpCDF	EPA-5 1613B	363256	0.000005	0.00005	3.3e-005	0.97	MO	12/30/10	J, Q, B
Total HxCDD	EPA-5 1613B	363256	0.0000054	0.00005	ND	0.97	MO	12/30/10	
Total HxCDF	EPA-5 1613B	363256	0.0000054	0.00005	ND	0.97	MO	12/30/10	
Total PeCDD	EPA-5 1613B	363256	0.000011	0.00005	ND	0.97	MO	12/30/10	
Total PeCDF	EPA-5 1613B	363256	0.0000058	0.00005	ND	0.97	MO	12/30/10	
Total TCDD	EPA-5 1613B	363256	0.000003	0.00001	ND	0.97	MO	12/30/10	
Total TCDF	EPA-5 1613B	363256	0.0000021	0.00001	ND	0.97	MO	12/30/10	

Surrogate: 13C-1,2,3,4,6,7,8-HpCDD (23-140%)	83 %
Surrogate: 13C-1,2,3,4,6,7,8-HpCDF (28-143%)	70 %
Surrogate: 13C-1,2,3,4,7,8,9-HpCDF (26-138%)	74 %
Surrogate: 13C-1,2,3,4,7,8-HxCDD (32-141%)	61 %
Surrogate: 13C-1,2,3,4,7,8-HxCDF (26-152%)	59 %
Surrogate: 13C-1,2,3,6,7,8-HxCDD (28-130%)	72 %
Surrogate: 13C-1,2,3,6,7,8-HxCDF (26-123%)	62 %
Surrogate: 13C-1,2,3,7,8,9-HxCDF (29-147%)	60 %
Surrogate: 13C-1,2,3,7,8-PeCDD (25-181%)	66 %
Surrogate: 13C-1,2,3,7,8-PeCDF (24-185%)	68 %
Surrogate: 13C-2,3,4,6,7,8-HxCDF (28-136%)	61 %
Surrogate: 13C-2,3,4,7,8-PeCDF (21-178%)	62 %
Surrogate: 13C-2,3,7,8-TCDD (25-164%)	61 %
Surrogate: 13C-2,3,7,8-TCDF (24-169%)	57 %
Surrogate: 13C-OCDD (17-157%)	66 %

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

EPA-5 1613Bx

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water) - cont.					Sampled: 12/23/10				
Reporting Units: ug/L									
<i>Surrogate: 37Cl4-2,3,7,8-TCDD (35-197%)</i>					94 %				

TestAmerica Irvine

Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

ITL2272 <Page 19 of 45>

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

SHORT HOLD TIME DETAIL REPORT

	Hold Time (in days)	Date/Time Sampled	Date/Time Received	Date/Time Extracted	Date/Time Analyzed
Sample ID: Outfall 011 (Grab) (ITL2272-01) - Water					
SM2540F	2	12/22/2010 10:45	12/22/2010 18:05	12/23/2010 11:30	12/23/2010 11:30
Sample ID: Outfall 011 (Composite) (ITL2272-03) - Water					
EPA 180.1	2	12/23/2010 10:54	12/22/2010 18:05	12/24/2010 14:00	12/24/2010 14:00
EPA 300.0	2	12/23/2010 10:54	12/22/2010 18:05	12/23/2010 20:00	12/23/2010 20:46
Filtration	1	12/23/2010 10:54	12/22/2010 18:05	12/23/2010 20:42	12/23/2010 20:43
SM5210B	2	12/23/2010 10:54	12/22/2010 18:05	12/25/2010 09:00	12/30/2010 08:00
SM5540-C	2	12/23/2010 10:54	12/22/2010 18:05	12/23/2010 20:00	12/23/2010 21:12

TestAmerica Irvine

Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

ITL2272 <Page 20 of 45>

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2971 Extracted: 12/27/10										
Blank Analyzed: 12/27/2010 (10L2971-BLK1)										
Benzene	ND	0.50	ug/l							
Carbon tetrachloride	ND	0.50	ug/l							
Chloroform	ND	0.50	ug/l							
1,1-Dichloroethane	ND	0.50	ug/l							
1,2-Dichloroethane	ND	0.50	ug/l							
1,1-Dichloroethene	ND	0.50	ug/l							
Ethylbenzene	ND	0.50	ug/l							
Tetrachloroethene	ND	0.50	ug/l							
Toluene	ND	0.50	ug/l							
1,1,1-Trichloroethane	ND	0.50	ug/l							
1,1,2-Trichloroethane	ND	0.50	ug/l							
Trichloroethene	ND	0.50	ug/l							
Trichlorofluoromethane	ND	0.50	ug/l							
Trichlorotrifluoroethane (Freon 113)	ND	5.0	ug/l							
Vinyl chloride	ND	0.50	ug/l							
Xylenes, Total	ND	1.5	ug/l							
<i>Surrogate: 4-Bromofluorobenzene</i>	24.7		ug/l	25.0		99	80-120			
<i>Surrogate: Dibromofluoromethane</i>	26.0		ug/l	25.0		104	80-120			
<i>Surrogate: Toluene-d8</i>	25.4		ug/l	25.0		102	80-120			
LCS Analyzed: 12/27/2010 (10L2971-BS1)										
Benzene	22.9	0.50	ug/l	25.0		92	70-120			
Carbon tetrachloride	28.0	0.50	ug/l	25.0		112	65-140			
Chloroform	25.4	0.50	ug/l	25.0		101	70-130			
1,1-Dichloroethane	26.0	0.50	ug/l	25.0		104	70-125			
1,2-Dichloroethane	27.4	0.50	ug/l	25.0		110	60-140			
1,1-Dichloroethene	23.3	0.50	ug/l	25.0		93	70-125			
Ethylbenzene	25.2	0.50	ug/l	25.0		101	75-125			
Tetrachloroethene	24.7	0.50	ug/l	25.0		99	70-125			
Toluene	23.8	0.50	ug/l	25.0		95	70-120			
1,1,1-Trichloroethane	29.3	0.50	ug/l	25.0		117	65-135			
1,1,2-Trichloroethane	25.0	0.50	ug/l	25.0		100	70-125			
Trichloroethene	25.0	0.50	ug/l	25.0		100	70-125			
Trichlorofluoromethane	28.3	0.50	ug/l	25.0		113	65-145			
Vinyl chloride	20.2	0.50	ug/l	25.0		81	55-135			
Xylenes, Total	74.8	1.5	ug/l	75.0		100	70-125			

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2971 Extracted: 12/27/10										
LCS Analyzed: 12/27/2010 (10L2971-BS1)										
Surrogate: 4-Bromofluorobenzene	25.1		ug/l	25.0		100	80-120			
Surrogate: Dibromofluoromethane	26.0		ug/l	25.0		104	80-120			
Surrogate: Toluene-d8	25.8		ug/l	25.0		103	80-120			
Matrix Spike Analyzed: 12/27/2010 (10L2971-MS1)					Source: ITL2478-02					
Benzene	131	0.50	ug/l	25.0	99.0	128	65-125			M1
Carbon tetrachloride	30.1	0.50	ug/l	25.0	ND	120	65-140			
Chloroform	51.8	0.50	ug/l	25.0	19.8	128	65-135			
1,1-Dichloroethane	31.2	0.50	ug/l	25.0	2.20	116	65-130			
1,2-Dichloroethane	31.0	0.50	ug/l	25.0	1.04	120	60-140			
1,1-Dichloroethene	25.5	0.50	ug/l	25.0	ND	102	60-130			
Ethylbenzene	27.2	0.50	ug/l	25.0	ND	109	65-130			
Tetrachloroethene	26.8	0.50	ug/l	25.0	ND	107	65-130			
Toluene	25.9	0.50	ug/l	25.0	ND	104	70-125			
1,1,1-Trichloroethane	33.4	0.50	ug/l	25.0	ND	134	65-140			
1,1,2-Trichloroethane	27.4	0.50	ug/l	25.0	ND	110	65-130			
Trichloroethene	26.7	0.50	ug/l	25.0	ND	107	65-125			
Trichlorofluoromethane	32.0	0.50	ug/l	25.0	ND	128	60-145			
Vinyl chloride	25.3	0.50	ug/l	25.0	ND	101	45-140			
Xylenes, Total	80.8	1.5	ug/l	75.0	ND	108	60-130			
Surrogate: 4-Bromofluorobenzene	25.0		ug/l	25.0		100	80-120			
Surrogate: Dibromofluoromethane	26.8		ug/l	25.0		107	80-120			
Surrogate: Toluene-d8	25.6		ug/l	25.0		102	80-120			
Matrix Spike Dup Analyzed: 12/27/2010 (10L2971-MSD1)					Source: ITL2478-02					
Benzene	113	0.50	ug/l	25.0	99.0	57	65-125	15	20	M2
Carbon tetrachloride	29.0	0.50	ug/l	25.0	ND	116	65-140	4	25	
Chloroform	46.0	0.50	ug/l	25.0	19.8	105	65-135	12	20	
1,1-Dichloroethane	29.7	0.50	ug/l	25.0	2.20	110	65-130	5	20	
1,2-Dichloroethane	30.8	0.50	ug/l	25.0	1.04	119	60-140	0.6	20	
1,1-Dichloroethene	24.6	0.50	ug/l	25.0	ND	99	60-130	4	20	
Ethylbenzene	26.0	0.50	ug/l	25.0	ND	104	65-130	5	20	
Tetrachloroethene	25.4	0.50	ug/l	25.0	ND	102	65-130	5	20	
Toluene	25.2	0.50	ug/l	25.0	ND	101	70-125	3	20	
1,1,1-Trichloroethane	32.0	0.50	ug/l	25.0	ND	128	65-140	4	20	
1,1,2-Trichloroethane	28.7	0.50	ug/l	25.0	ND	115	65-130	4	25	
Trichloroethene	26.0	0.50	ug/l	25.0	ND	104	65-125	3	20	

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2971 Extracted: 12/27/10										
Matrix Spike Dup Analyzed: 12/27/2010 (10L2971-MSD1)					Source: ITL2478-02					
Trichlorofluoromethane	30.7	0.50	ug/l	25.0	ND	123	60-145	4	25	
Vinyl chloride	24.0	0.50	ug/l	25.0	ND	96	45-140	5	30	
Xylenes, Total	77.6	1.5	ug/l	75.0	ND	103	60-130	4	20	
Surrogate: 4-Bromofluorobenzene	25.4		ug/l	25.0		102	80-120			
Surrogate: Dibromofluoromethane	26.5		ug/l	25.0		106	80-120			
Surrogate: Toluene-d8	25.4		ug/l	25.0		102	80-120			

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

METHOD BLANK/QC DATA

ACID & BASE/NEUTRALS BY GC/MS (EPA 625)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC %REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2936 Extracted: 12/26/10										
Blank Analyzed: 12/28/2010 (10L2936-BLK1)										
Bis(2-ethylhexyl)phthalate	ND	5.00	ug/l							
2,4-Dinitrotoluene	ND	5.00	ug/l							
N-Nitrosodimethylamine	ND	5.00	ug/l							
Pentachlorophenol	ND	5.00	ug/l							
2,4,6-Trichlorophenol	ND	6.00	ug/l							
Surrogate: 2,4,6-Tribromophenol	18.7		ug/l	20.0		94	40-120			
Surrogate: 2-Fluorobiphenyl	7.78		ug/l	10.0		78	50-120			
Surrogate: 2-Fluorophenol	13.3		ug/l	20.0		66	30-120			
Surrogate: Nitrobenzene-d5	7.38		ug/l	10.0		74	45-120			
Surrogate: Phenol-d6	14.0		ug/l	20.0		70	35-120			
Surrogate: Terphenyl-d14	8.98		ug/l	10.0		90	50-125			
LCS Analyzed: 12/28/2010 (10L2936-BS1)										
Bis(2-ethylhexyl)phthalate	9.12	5.00	ug/l	10.0		91	65-130			MNR1
2,4-Dinitrotoluene	8.50	5.00	ug/l	10.0		85	65-120			
N-Nitrosodimethylamine	7.46	5.00	ug/l	10.0		75	45-120			
Pentachlorophenol	6.36	5.00	ug/l	10.0		64	24-121			
2,4,6-Trichlorophenol	9.22	6.00	ug/l	10.0		92	55-120			
Surrogate: 2,4,6-Tribromophenol	19.0		ug/l	20.0		95	40-120			
Surrogate: 2-Fluorobiphenyl	8.12		ug/l	10.0		81	50-120			
Surrogate: 2-Fluorophenol	14.2		ug/l	20.0		71	30-120			
Surrogate: Nitrobenzene-d5	7.98		ug/l	10.0		80	45-120			
Surrogate: Phenol-d6	16.0		ug/l	20.0		80	35-120			
Surrogate: Terphenyl-d14	9.02		ug/l	10.0		90	50-125			
LCS Dup Analyzed: 12/28/2010 (10L2936-BSD1)										
Bis(2-ethylhexyl)phthalate	8.50	5.00	ug/l	10.0		85	65-130	7	20	
2,4-Dinitrotoluene	8.24	5.00	ug/l	10.0		82	65-120	3	20	
N-Nitrosodimethylamine	6.64	5.00	ug/l	10.0		66	45-120	12	20	
Pentachlorophenol	6.04	5.00	ug/l	10.0		60	24-121	5	25	
2,4,6-Trichlorophenol	8.16	6.00	ug/l	10.0		82	55-120	12	30	
Surrogate: 2,4,6-Tribromophenol	18.4		ug/l	20.0		92	40-120			
Surrogate: 2-Fluorobiphenyl	7.50		ug/l	10.0		75	50-120			
Surrogate: 2-Fluorophenol	12.8		ug/l	20.0		64	30-120			
Surrogate: Nitrobenzene-d5	7.18		ug/l	10.0		72	45-120			
Surrogate: Phenol-d6	14.2		ug/l	20.0		71	35-120			
Surrogate: Terphenyl-d14	9.16		ug/l	10.0		92	50-125			

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

ORGANOCHLORINE PESTICIDES (EPA 608)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3051 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3051-BLK1)										
alpha-BHC	ND	0.010	ug/l							
Surrogate: Decachlorobiphenyl	0.430		ug/l	0.500		86	45-120			
Surrogate: Tetrachloro-m-xylene	0.379		ug/l	0.500		76	35-115			
LCS Analyzed: 12/28/2010 (10L3051-BS1)										
alpha-BHC	0.385	0.010	ug/l	0.500		77	45-115			MNR1
Surrogate: Decachlorobiphenyl	0.419		ug/l	0.500		84	45-120			
Surrogate: Tetrachloro-m-xylene	0.360		ug/l	0.500		72	35-115			
LCS Dup Analyzed: 12/28/2010 (10L3051-BSD1)										
alpha-BHC	0.395	0.010	ug/l	0.500		79	45-115	2	30	
Surrogate: Decachlorobiphenyl	0.425		ug/l	0.500		85	45-120			
Surrogate: Tetrachloro-m-xylene	0.363		ug/l	0.500		73	35-115			

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

HEXANE EXTRACTABLE MATERIAL

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2996 Extracted: 12/27/10										
Blank Analyzed: 12/28/2010 (10L2996-BLK1)										
Hexane Extractable Material (Oil & Grease)	ND	5.0	mg/l							
LCS Analyzed: 12/28/2010 (10L2996-BS1)										
Hexane Extractable Material (Oil & Grease)	18.2	5.0	mg/l	20.0		91	78-114			MNR1
LCS Dup Analyzed: 12/28/2010 (10L2996-BSD1)										
Hexane Extractable Material (Oil & Grease)	18.0	5.0	mg/l	20.0		90	78-114	1	11	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3064 Extracted: 12/28/10										
Blank Analyzed: 12/29/2010 (10L3064-BLK1)										
Cadmium	ND	1.0	ug/l							
Copper	ND	2.00	ug/l							
Lead	ND	1.00	ug/l							
Manganese	ND	1.0	ug/l							
Selenium	ND	2.0	ug/l							
LCS Analyzed: 12/29/2010 (10L3064-BS1)										
Cadmium	83.4	1.0	ug/l	80.0		104	85-115			
Copper	83.9	2.00	ug/l	80.0		105	85-115			
Lead	83.4	1.00	ug/l	80.0		104	85-115			
Manganese	85.8	1.0	ug/l	80.0		107	85-115			
Selenium	80.1	2.0	ug/l	80.0		100	85-115			
Matrix Spike Analyzed: 12/29/2010 (10L3064-MS1) Source: ITL2444-01										
Cadmium	78.9	1.0	ug/l	80.0	ND	99	70-130			
Copper	69.9	2.00	ug/l	80.0	0.843	86	70-130			
Lead	73.2	1.00	ug/l	80.0	ND	91	70-130			
Manganese	74.9	1.0	ug/l	80.0	3.17	90	70-130			
Selenium	79.1	2.0	ug/l	80.0	1.25	97	70-130			
Matrix Spike Analyzed: 12/29/2010 (10L3064-MS2) Source: ITL2444-02										
Cadmium	81.7	1.0	ug/l	80.0	ND	102	70-130			
Copper	73.4	2.00	ug/l	80.0	0.584	91	70-130			
Lead	77.7	1.00	ug/l	80.0	ND	97	70-130			
Manganese	1820	1.0	ug/l	80.0	1750	94	70-130			MHA
Selenium	72.3	2.0	ug/l	80.0	ND	90	70-130			
Matrix Spike Dup Analyzed: 12/29/2010 (10L3064-MSD1) Source: ITL2444-01										
Cadmium	80.6	1.0	ug/l	80.0	ND	101	70-130	2	20	
Copper	69.9	2.00	ug/l	80.0	0.843	86	70-130	0.05	20	
Lead	75.3	1.00	ug/l	80.0	ND	94	70-130	3	20	
Manganese	75.1	1.0	ug/l	80.0	3.17	90	70-130	0.3	20	
Selenium	80.8	2.0	ug/l	80.0	1.25	99	70-130	2	20	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3104 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3104-BLK1)										
Mercury	ND	0.20	ug/l							
LCS Analyzed: 12/28/2010 (10L3104-BS1)										
Mercury	8.00	0.20	ug/l	8.00		100	85-115			
Matrix Spike Analyzed: 12/28/2010 (10L3104-MS1)										
					Source: ITL2014-03					
Mercury	7.68	0.20	ug/l	8.00	ND	96	70-130			
Matrix Spike Dup Analyzed: 12/28/2010 (10L3104-MSD1)										
					Source: ITL2014-03					
Mercury	7.81	0.20	ug/l	8.00	ND	98	70-130	2	20	
Batch: 10L3131 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3131-BLK1)										
Iron	ND	0.040	mg/l							
Zinc	ND	20.0	ug/l							
LCS Analyzed: 12/28/2010 (10L3131-BS1)										
Iron	0.512	0.040	mg/l	0.500		102	85-115			
Zinc	497	20.0	ug/l	500		99	85-115			
Matrix Spike Analyzed: 12/28/2010 (10L3131-MS1)										
					Source: ITL2185-01					
Iron	0.501	0.040	mg/l	0.500	ND	100	70-130			
Zinc	498	20.0	ug/l	500	ND	100	70-130			
Matrix Spike Analyzed: 12/28/2010 (10L3131-MS2)										
					Source: ITL2185-02					
Iron	0.537	0.040	mg/l	0.500	ND	107	70-130			
Zinc	535	20.0	ug/l	500	ND	107	70-130			

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

METHOD BLANK/QC DATA

METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC %REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3131 Extracted: 12/28/10										
Matrix Spike Dup Analyzed: 12/28/2010 (10L3131-MSD1)					Source: ITL2185-01					
Iron	0.513	0.040	mg/l	0.500	ND	103	70-130	2	20	
Zinc	509	20.0	ug/l	500	ND	102	70-130	2	20	

TestAmerica Irvine

Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

ITL2272 <Page 29 of 45>

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

DISSOLVED METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3103 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3103-BLK1)										
Mercury	ND	0.20	ug/l							
LCS Analyzed: 12/28/2010 (10L3103-BS1)										
Mercury	8.23	0.20	ug/l	8.00		103	85-115			
Matrix Spike Analyzed: 12/28/2010 (10L3103-MS1)										
Mercury	8.27	0.20	ug/l	8.00	ND	103	70-130			
Matrix Spike Dup Analyzed: 12/28/2010 (10L3103-MSD1)										
Mercury	8.19	0.20	ug/l	8.00	ND	102	70-130	0.9	20	
Batch: 10L3118 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3118-BLK1)										
Iron	ND	0.040	mg/l							
Zinc	ND	20.0	ug/l							
LCS Analyzed: 12/28/2010 (10L3118-BS1)										
Iron	0.519	0.040	mg/l	0.500		104	85-115			
Zinc	498	20.0	ug/l	500		100	85-115			
Matrix Spike Analyzed: 12/28/2010 (10L3118-MS1)										
Iron	0.890	0.040	mg/l	0.500	0.375	103	70-130			
Zinc	510	20.0	ug/l	500	ND	102	70-130			
Matrix Spike Dup Analyzed: 12/28/2010 (10L3118-MSD1)										
Iron	0.887	0.040	mg/l	0.500	0.375	102	70-130	0.3	20	
Zinc	511	20.0	ug/l	500	ND	102	70-130	0.1	20	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

DISSOLVED METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3120 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3120-BLK1)										
Cadmium	ND	1.0	ug/l							
Copper	ND	2.00	ug/l							
Lead	ND	1.00	ug/l							
Manganese	ND	1.0	ug/l							
Selenium	ND	2.0	ug/l							
LCS Analyzed: 12/28/2010 (10L3120-BS1)										
Cadmium	82.5	1.0	ug/l	80.0		103	85-115			
Copper	81.0	2.00	ug/l	80.0		101	85-115			
Lead	84.2	1.00	ug/l	80.0		105	85-115			
Manganese	80.7	1.0	ug/l	80.0		101	85-115			
Selenium	80.5	2.0	ug/l	80.0		101	85-115			
Matrix Spike Analyzed: 12/28/2010 (10L3120-MS1) Source: ITL2486-02										
Cadmium	80.1	1.0	ug/l	80.0	ND	100	70-130			
Copper	79.5	2.00	ug/l	80.0	3.50	95	70-130			
Lead	81.7	1.00	ug/l	80.0	0.379	102	70-130			
Manganese	82.3	1.0	ug/l	80.0	1.69	101	70-130			
Selenium	81.3	2.0	ug/l	80.0	ND	102	70-130			
Matrix Spike Dup Analyzed: 12/28/2010 (10L3120-MSD1) Source: ITL2486-02										
Cadmium	81.2	1.0	ug/l	80.0	ND	102	70-130	1	20	
Copper	79.6	2.00	ug/l	80.0	3.50	95	70-130	0.2	20	
Lead	82.9	1.00	ug/l	80.0	0.379	103	70-130	1	20	
Manganese	83.2	1.0	ug/l	80.0	1.69	102	70-130	1	20	
Selenium	81.0	2.0	ug/l	80.0	ND	101	70-130	0.4	20	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2765 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2765-BLK1)										
Specific Conductance	ND	1.0	umhos/cm @ 25C							
LCS Analyzed: 12/23/2010 (10L2765-BS1)										
Specific Conductance	1380	1.0	umhos/cm @ 25C	1410		98	90-110			
Duplicate Analyzed: 12/23/2010 (10L2765-DUP1)										
Specific Conductance	206	1.0	umhos/cm @ 25C		207			0.5	5	
Source: ITL2336-01										
Batch: 10L2812 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2812-BLK1)										
Chloride	ND	0.50	mg/l							
Nitrate-N	ND	0.11	mg/l							
Nitrite-N	ND	0.15	mg/l							
Nitrate/Nitrite-N	ND	0.26	mg/l							
Sulfate	ND	0.50	mg/l							
LCS Analyzed: 12/23/2010 (10L2812-BS1)										
Chloride	4.72	0.50	mg/l	5.00		94	90-110			
Nitrate-N	1.13	0.11	mg/l	1.13		100	90-110			
Nitrite-N	1.46	0.15	mg/l	1.52		96	90-110			
Sulfate	9.90	0.50	mg/l	10.0		99	90-110			
Matrix Spike Analyzed: 12/23/2010 (10L2812-MS1)										
Chloride	9.65	0.50	mg/l	5.00	4.68	99	80-120			
Nitrate-N	1.12	0.11	mg/l	1.13	0.130	87	80-120			
Nitrite-N	1.98	0.15	mg/l	1.52	0.658	87	80-120			
Sulfate	12.7	0.50	mg/l	10.0	3.35	94	80-120			
Source: ITL2365-02										

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC %REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2812 Extracted: 12/23/10										
Matrix Spike Dup Analyzed: 12/23/2010 (10L2812-MSD1)					Source: ITL2365-02					
Chloride	9.60	0.50	mg/l	5.00	4.68	98	80-120	0.6	20	
Nitrate-N	1.12	0.11	mg/l	1.13	0.130	88	80-120	0.4	20	
Nitrite-N	1.98	0.15	mg/l	1.52	0.658	87	80-120	0.3	20	
Sulfate	13.0	0.50	mg/l	10.0	3.35	97	80-120	3	20	
Batch: 10L2893 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2893-BLK1)										
Surfactants (MBAS)	ND	0.10	mg/l							
LCS Analyzed: 12/23/2010 (10L2893-BS1)										
Surfactants (MBAS)	0.254	0.10	mg/l	0.250		102	90-110			
Matrix Spike Analyzed: 12/23/2010 (10L2893-MS1)					Source: ITL2336-01					
Surfactants (MBAS)	0.271	0.10	mg/l	0.250	ND	109	50-125			
Matrix Spike Dup Analyzed: 12/23/2010 (10L2893-MSD1)					Source: ITL2336-01					
Surfactants (MBAS)	0.278	0.10	mg/l	0.250	ND	111	50-125	2	20	
Batch: 10L2924 Extracted: 12/24/10										
Blank Analyzed: 12/24/2010 (10L2924-BLK1)										
Turbidity	ND	1.0	NTU							
Duplicate Analyzed: 12/24/2010 (10L2924-DUP1)					Source: ITL2272-03					
Turbidity	170	5.0	NTU		192			13	20	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC %REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2931 Extracted: 12/25/10										
Blank Analyzed: 12/30/2010 (10L2931-BLK1)										
Biochemical Oxygen Demand	ND	2.0	mg/l							
LCS Analyzed: 12/30/2010 (10L2931-BS1)										
Biochemical Oxygen Demand	196	100	mg/l	198		99	85-115			
LCS Dup Analyzed: 12/30/2010 (10L2931-BSD1)										
Biochemical Oxygen Demand	186	100	mg/l	198		94	85-115	5	20	
Batch: 10L3015 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3015-BLK1)										
Perchlorate	ND	4.0	ug/l							
LCS Analyzed: 12/28/2010 (10L3015-BS1)										
Perchlorate	22.7	4.0	ug/l	25.0		91	85-115			
Matrix Spike Analyzed: 12/28/2010 (10L3015-MS1)										
Perchlorate	23.1	4.0	ug/l	25.0	Source: ITL2014-03	ND	92	80-120		
Matrix Spike Dup Analyzed: 12/28/2010 (10L3015-MSD1)										
Perchlorate	23.7	4.0	ug/l	25.0	Source: ITL2014-03	ND	95	80-120	3	20
Batch: 10L3089 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3089-BLK1)										
Total Dissolved Solids	ND	10	mg/l							

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC %REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3089 Extracted: 12/28/10										
LCS Analyzed: 12/28/2010 (10L3089-BS1)										
Total Dissolved Solids	992	10	mg/l	1000		99	90-110			
Duplicate Analyzed: 12/28/2010 (10L3089-DUP1)										
Total Dissolved Solids	1650	10	mg/l		1630			2	10	
Source: ITL2438-01										
Batch: 10L3114 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3114-BLK1)										
Total Cyanide	ND	5.0	ug/l							
LCS Analyzed: 12/28/2010 (10L3114-BS1)										
Total Cyanide	190	5.0	ug/l	200		95	90-110			
Matrix Spike Analyzed: 12/28/2010 (10L3114-MS1)										
Total Cyanide	188	5.0	ug/l	200	ND	94	70-115			
Source: ITL2487-02										
Matrix Spike Dup Analyzed: 12/28/2010 (10L3114-MSD1)										
Total Cyanide	188	5.0	ug/l	200	ND	94	70-115	0.3	15	
Source: ITL2487-02										
Batch: 10L3146 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3146-BLK1)										
Ammonia-N (Distilled)	ND	0.500	mg/l							
LCS Analyzed: 12/28/2010 (10L3146-BS1)										
Ammonia-N (Distilled)	9.80	0.500	mg/l	10.0		98	80-115			

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3146 Extracted: 12/28/10										
Matrix Spike Analyzed: 12/28/2010 (10L3146-MS1)					Source: ITL1994-01					
Ammonia-N (Distilled)	10.6	0.500	mg/l	10.0	0.840	98	70-120			
Matrix Spike Dup Analyzed: 12/28/2010 (10L3146-MSD1)					Source: ITL1994-01					
Ammonia-N (Distilled)	10.6	0.500	mg/l	10.0	0.840	98	70-120	0	15	
Batch: 10L3164 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3164-BLK1)										
Total Suspended Solids	ND	10	mg/l							
LCS Analyzed: 12/28/2010 (10L3164-BS1)										
Total Suspended Solids	998	10	mg/l	1000		100	85-115			
Duplicate Analyzed: 12/28/2010 (10L3164-DUP1)					Source: ITL2242-01					
Total Suspended Solids	63.0	10	mg/l		64.0			2	10	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

METHOD BLANK/QC DATA

EPA-5 1613Bx

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 363256 Extracted: 12/29/10										
Blank Analyzed: 12/30/2010 (G0L290000256B)					Source:					
1,2,3,4,6,7,8-HpCDD	1.7e-005	0.00005	ug/L				-			J
1,2,3,4,6,7,8-HpCDF	4.2e-006	0.00005	ug/L				-			J, Q
1,2,3,4,7,8,9-HpCDF	ND	0.00005	ug/L				-			
1,2,3,4,7,8-HxCDD	ND	0.00005	ug/L				-			
1,2,3,4,7,8-HxCDF	9.5e-007	0.00005	ug/L				-			J, Q
1,2,3,6,7,8-HxCDD	ND	0.00005	ug/L				-			
1,2,3,6,7,8-HxCDF	ND	0.00005	ug/L				-			
1,2,3,7,8,9-HxCDD	1.3e-006	0.00005	ug/L				-			J, Q
1,2,3,7,8,9-HxCDF	ND	0.00005	ug/L				-			
1,2,3,7,8-PeCDD	ND	0.00005	ug/L				-			
1,2,3,7,8-PeCDF	ND	0.00005	ug/L				-			
2,3,4,6,7,8-HxCDF	ND	0.00005	ug/L				-			
2,3,4,7,8-PeCDF	ND	0.00005	ug/L				-			
2,3,7,8-TCDD	ND	0.00001	ug/L				-			
2,3,7,8-TCDF	ND	0.00001	ug/L				-			
OCDD	0.00044	0.0001	ug/L				-			
OCDF	2.1e-005	0.0001	ug/L				-			J, Q
Total HpCDD	3.6e-005	0.00005	ug/L				-			J
Total HpCDF	1.4e-005	0.00005	ug/L				-			J, Q
Total HxCDD	1.3e-006	0.00005	ug/L				-			J, Q
Total HxCDF	2e-006	0.00005	ug/L				-			J, Q
Total PeCDD	ND	0.00005	ug/L				-			
Total PeCDF	ND	0.00005	ug/L				-			
Total TCDD	ND	0.00001	ug/L				-			
Total TCDF	ND	0.00001	ug/L				-			
Surrogate: 13C-1,2,3,4,6,7,8-HpCDD	0.0019		ug/L	0.002		96	23-140			
Surrogate: 13C-1,2,3,4,6,7,8-HpCDF	0.0016		ug/L	0.002		80	28-143			
Surrogate: 13C-1,2,3,4,7,8,9-HpCDF	0.0017		ug/L	0.002		87	26-138			
Surrogate: 13C-1,2,3,4,7,8-HxCDD	0.0015		ug/L	0.002		74	32-141			
Surrogate: 13C-1,2,3,4,7,8-HxCDF	0.0014		ug/L	0.002		70	26-152			
Surrogate: 13C-1,2,3,6,7,8-HxCDD	0.0018		ug/L	0.002		89	28-130			
Surrogate: 13C-1,2,3,6,7,8-HxCDF	0.0014		ug/L	0.002		71	26-123			
Surrogate: 13C-1,2,3,7,8,9-HxCDF	0.0014		ug/L	0.002		68	29-147			
Surrogate: 13C-1,2,3,7,8-PeCDD	0.0016		ug/L	0.002		79	25-181			
Surrogate: 13C-1,2,3,7,8-PeCDF	0.0016		ug/L	0.002		80	24-185			
Surrogate: 13C-2,3,4,6,7,8-HxCDF	0.0015		ug/L	0.002		73	28-136			

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

EPA-5 1613Bx

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 363256 Extracted: 12/29/10										
Blank Analyzed: 12/30/2010 (G0L290000256B)					Source:					
Surrogate: 13C-2,3,4,7,8-PeCDF	0.0015		ug/L	0.002		75	21-178			
Surrogate: 13C-2,3,7,8-TCDD	0.0015		ug/L	0.002		73	25-164			
Surrogate: 13C-2,3,7,8-TCDF	0.0013		ug/L	0.002		64	24-169			
Surrogate: 13C-OCDD	0.0031		ug/L	0.004		78	17-157			
Surrogate: 37Cl4-2,3,7,8-TCDD	0.00077		ug/L	0.0008		96	35-197			
LCS Analyzed: 12/30/2010 (G0L290000256C)					Source:					
1,2,3,4,6,7,8-HpCDD	0.00116	0.00005	ug/L	0.001		116	70-140			
1,2,3,4,6,7,8-HpCDF	0.00125	0.00005	ug/L	0.001		125	82-122			a
1,2,3,4,7,8,9-HpCDF	0.0012	0.00005	ug/L	0.001		120	78-138			
1,2,3,4,7,8-HxCDD	0.00126	0.00005	ug/L	0.001		126	70-164			
1,2,3,4,7,8-HxCDF	0.00113	0.00005	ug/L	0.001		113	72-134			
1,2,3,6,7,8-HxCDD	0.00108	0.00005	ug/L	0.001		108	76-134			
1,2,3,6,7,8-HxCDF	0.00118	0.00005	ug/L	0.001		118	84-130			
1,2,3,7,8,9-HxCDD	0.0012	0.00005	ug/L	0.001		120	64-162			
1,2,3,7,8,9-HxCDF	0.00121	0.00005	ug/L	0.001		121	78-130			
1,2,3,7,8-PeCDD	0.00118	0.00005	ug/L	0.001		118	70-142			
1,2,3,7,8-PeCDF	0.00113	0.00005	ug/L	0.001		113	80-134			
2,3,4,6,7,8-HxCDF	0.00117	0.00005	ug/L	0.001		117	70-156			
2,3,4,7,8-PeCDF	0.00112	0.00005	ug/L	0.001		112	68-160			
2,3,7,8-TCDD	0.000227	0.00001	ug/L	0.0002		114	67-158			
2,3,7,8-TCDF	0.000218	0.00001	ug/L	0.0002		109	75-158			
OCDD	0.00297	0.0001	ug/L	0.002		149	78-144			a
OCDF	0.00208	0.0001	ug/L	0.002		104	63-170			
Surrogate: 13C-1,2,3,4,6,7,8-HpCDD	0.002		ug/L	0.002		100	26-166			
Surrogate: 13C-1,2,3,4,6,7,8-HpCDF	0.00166		ug/L	0.002		83	21-158			
Surrogate: 13C-1,2,3,4,7,8,9-HpCDF	0.00183		ug/L	0.002		92	20-186			
Surrogate: 13C-1,2,3,4,7,8-HxCDD	0.00144		ug/L	0.002		72	21-193			
Surrogate: 13C-1,2,3,4,7,8-HxCDF	0.00134		ug/L	0.002		67	19-202			
Surrogate: 13C-1,2,3,6,7,8-HxCDD	0.00168		ug/L	0.002		84	25-163			
Surrogate: 13C-1,2,3,6,7,8-HxCDF	0.00135		ug/L	0.002		67	21-159			
Surrogate: 13C-1,2,3,7,8,9-HxCDF	0.00139		ug/L	0.002		70	17-205			
Surrogate: 13C-1,2,3,7,8-PeCDD	0.00165		ug/L	0.002		82	21-227			
Surrogate: 13C-1,2,3,7,8-PeCDF	0.00162		ug/L	0.002		81	21-192			
Surrogate: 13C-2,3,4,6,7,8-HxCDF	0.00139		ug/L	0.002		70	22-176			
Surrogate: 13C-2,3,4,7,8-PeCDF	0.00154		ug/L	0.002		77	13-328			

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

METHOD BLANK/QC DATA

EPA-5 1613Bx

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 363256 Extracted: 12/29/10										
LCS Analyzed: 12/30/2010 (G0L290000256C)										
Surrogate: 13C-2,3,7,8-TCDD	0.00144		ug/L	0.002		72	20-175			
Surrogate: 13C-2,3,7,8-TCDF	0.00125		ug/L	0.002		63	22-152			
Surrogate: 13C-OCDD	0.00348		ug/L	0.004		87	13-199			
Surrogate: 37Cl4-2,3,7,8-TCDD	0.000761		ug/L	0.0008		95	31-191			

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits appear in bold on this page.

LabNumber	Analysis	Analyte	Units	Result	MRL	Compliance Limit
ITL2272-01	1664-HEM	Hexane Extractable Material (Oil & Greas	mg/l	0.38	4.7	15
ITL2272-01	624-Boeing 001/002Q (Fr113+X+Fr1,1-Dichloroethene		ug/l	0	0.50	6
ITL2272-01	624-Boeing 001/002Q (Fr113+X+Fr1,2-Dichloroethene		ug/l	0	0.50	0.5
ITL2272-01	624-Boeing 001/002Q (Fr113+X+FrTrichloroethene		ug/l	0	0.50	5
ITL2272-01	Settleable Solids - SM2540F	Total Settleable Solids	ml/l	0	0.10	0.3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits appear in bold on this page.

LabNumber	Analysis	Analyte	Units	Result	MRL	Compliance Limit
ITL2272-02	624-Boeing 001/002Q (Fr113+X+Fr1,1-Dichloroethene		ug/l	0	0.50	6
ITL2272-02	624-Boeing 001/002Q (Fr113+X+Fr1,2-Dichloroethene		ug/l	0	0.50	0.5
ITL2272-02	624-Boeing 001/002Q (Fr113+X+FrTrichloroethene		ug/l	0	0.50	5

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits appear in bold on this page.

LabNumber	Analysis	Analyte	Units	Result	MRL	Compliance Limit
ITL2272-03	608-Pest Boeing 001/002 Q (LL)	alpha-BHC	ug/l	0	0.0094	0.03
ITL2272-03	625-Boeing 001/002 Q-LL	2,4,6-Trichlorophenol	ug/l	0	5.66	13
ITL2272-03	625-Boeing 001/002 Q-LL	2,4-Dinitrotoluene	ug/l	0	4.72	18
ITL2272-03	625-Boeing 001/002 Q-LL	Bis(2-ethylhexyl)phthalate	ug/l	0.26	4.72	4
ITL2272-03	625-Boeing 001/002 Q-LL	N-Nitrosodimethylamine	ug/l	0	4.72	16
ITL2272-03	625-Boeing 001/002 Q-LL	Pentachlorophenol	ug/l	0	4.72	16.5
ITL2272-03	Ammonia-N, Titr 4500NH3-C (w/di:Ammonia-N (Distilled)		mg/l	0	0.500	10.1
ITL2272-03	BOD - SM5210B	Biochemical Oxygen Demand	mg/l	1.02	2.0	30
ITL2272-03	Cadmium-200.8	Cadmium	ug/l	0.16	1.0	3.1
ITL2272-03	Chloride - 300.0	Chloride	mg/l	4.90	0.50	150
ITL2272-03	Copper-200.8	Copper	ug/l	6.29	2.00	14
ITL2272-03	Cyanide, Total-4500CN-E (5ppb)	Total Cyanide	ug/l	-2	5.0	8.5
ITL2272-03	Lead-200.8	Lead	ug/l	4.55	1.00	5.2
ITL2272-03	MBAS - SM5540C	Surfactants (MBAS)	mg/l	0.0027	0.10	0.5
ITL2272-03	Mercury - 245.1	Mercury	ug/l	0	0.20	0.1
ITL2272-03	Nitrate-N, 300.0	Nitrate-N	mg/l	0.22	0.11	8
ITL2272-03	Nitrite-N, 300.0	Nitrite-N	mg/l	0	0.15	1

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

ITL2272-03	Nitrogen, NO3+NO2 -N EPA 300.0	Nitrate/Nitrite-N	mg/l	0.22	0.26	8
ITL2272-03	Perchlorate 314.0 - Default	Perchlorate	ug/l	0	4.0	6
ITL2272-03	Selenium-200.8	Selenium	ug/l	0.35	2.0	5
ITL2272-03	Sulfate-300.0	Sulfate	mg/l	5.44	0.50	300
ITL2272-03	TDS - SM2540C	Total Dissolved Solids	mg/l	90	10	950
ITL2272-03	TSS - SM2540D	Total Suspended Solids	mg/l	50	10	45
ITL2272-03	Zinc-200.7	Zinc	ug/l	28	20.0	119

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits appear in bold on this page.

LabNumber	Analysis	Analyte	Units	Result	MRL	Compliance Limit
-----------	----------	---------	-------	--------	-----	------------------

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

DATA QUALIFIERS AND DEFINITIONS

- a** Spiked analyte recovery is outside stated control limits.
- B** Method blank contamination. The associated method blank contains the target analyte at a reportable level.
- J** Estimated result. Result is less than the reporting limit.
- Ja** Estimated value. Analyte detected at a level less than the Reporting Limit (RL) and greater than or equal to the Method Detection Limit (MDL). The user of this data should be aware that this data is of limited reliability.
- Jb** The RESULT is less than the RDL (Required Detection Limit) and no U qualifier is assigned.
- M1** The MS and/or MSD were above the acceptance limits due to sample matrix interference. See Blank Spike (LCS).
- M2** The MS and/or MSD were below the acceptance limits due to sample matrix interference. See Blank Spike (LCS).
- MHA** Due to high levels of analyte in the sample, the MS/MSD calculation does not provide useful spike recovery information. See Blank Spike (LCS).
- MNR1** There was no MS/MSD analyzed with this batch due to insufficient sample volume. See Blank Spike/Blank Spike Duplicate.
- Q** Estimated maximum possible concentration (EMPC).
- U** The RESULT is less than the MDA (Minimum Detectable Activity). If the MDA is blank, the ERROR is used as the limit.
- ND** Analyte NOT DETECTED at or above the reporting limit or MDL, if MDL is specified.
- RPD** Relative Percent Difference

TestAmerica Irvine

Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

ITL2272 <Page 42 of 45>

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
 Quarterly Outfall 011
 Report Number: ITL2272

Sampled: 12/22/10-12/23/10
 Received: 12/22/10

Certification Summary

TestAmerica Irvine

Method	Matrix	Nelac	California
EPA 120.1	Water	X	X
EPA 1664A	Water	X	X
EPA 180.1	Water	X	X
EPA 200.7-Diss	Water	X	X
EPA 200.7	Water	X	X
EPA 200.8-Diss	Water	X	X
EPA 200.8	Water	X	X
EPA 245.1-Diss	Water	X	X
EPA 245.1	Water	X	X
EPA 300.0	Water	X	X
EPA 314.0	Water	X	X
EPA 608	Water	X	X
EPA 624	Water	X	X
EPA 625	Water	X	X
Filtration	Water	N/A	N/A
SM 2540D	Water	X	X
SM2540C	Water	X	
SM2540F	Water	X	X
SM4500CN-E	Water	X	X
SM4500NH3-C	Water	X	X
SM5210B	Water	X	X
SM5540-C	Water	X	X

Nevada and NELAP provide analyte specific accreditations. Analyte specific information for TestAmerica may be obtained by contacting the laboratory or visiting our website at www.testamericainc.com

Subcontracted Laboratories

Aquatic Testing Laboratories-SUB California Cert #1775

4350 Transport Street, Unit 107 - Ventura, CA 93003

Analysis Performed: Bioassay-7 dy Chnric

Samples: ITL2272-03

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

Eberline Services - SUB

2030 Wright Avenue - Richmond, CA 94804

Analysis Performed: Gamma Spec
Samples: ITL2272-03

Samples: ITL2272-04

Analysis Performed: Gross Alpha
Samples: ITL2272-03

Samples: ITL2272-04

Analysis Performed: Gross Beta
Samples: ITL2272-03

Samples: ITL2272-04

Analysis Performed: Radium, Combined
Samples: ITL2272-03

Samples: ITL2272-04

Analysis Performed: Strontium 90
Samples: ITL2272-03

Samples: ITL2272-04

Analysis Performed: Tritium
Samples: ITL2272-03

Analysis Performed: Uranium, Combined
Samples: ITL2272-03

Samples: ITL2272-04

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 011 2010
Quarterly Outfall 011
Report Number: ITL2272

Sampled: 12/22/10-12/23/10
Received: 12/22/10

TestAmerica Buffalo

10 Hazelwood Drive, Suite 106 - Amherst, NY 14228

Method Performed: 8649
Samples: ITL2272-03, ITL2272-04

Method Performed: 900
Samples: ITL2272-03, ITL2272-04

Method Performed: 901.1
Samples: ITL2272-03, ITL2272-04

Method Performed: 903.1
Samples: ITL2272-03, ITL2272-04

Method Performed: 904
Samples: ITL2272-03, ITL2272-04

Method Performed: 905
Samples: ITL2272-03, ITL2272-04

Method Performed: 906
Samples: ITL2272-03

TestAmerica West Sacramento *NELAC Cert #1119CA, Nevada Cert #CA44*

880 Riverside Parkway - West Sacramento, CA 95605

Method Performed: EPA-5 1613B
Samples: ITL2272-03

TestAmerica Irvine

Debby Wilson
Project Manager

LABORATORY REPORT



**Aquatic
Testing
Laboratories**

"dedicated to providing quality aquatic toxicity testing"

4350 Transport Street, Unit 107
Ventura, CA 93003
(805) 650-0546 FAX (805) 650-0756
CA DOHS ELAP Cert. No.: 1775

Date: December 30, 2010

Client: TestAmerica, Irvine
17461 Derian Ave., Suite 100
Irvine, CA 92614
Attn: Debby Wilson

Laboratory No.: A-10122302-001
Sample I.D.: ITL2272-03 (Outfall 011)

Sample Control: The sample was received by ATL within the recommended hold time, chilled and with the chain of custody record attached. Testing conducted on only one sample per client instruction (rain runoff sample).

Date Sampled: 12/23/10 - composite
Date Received: 12/23/10
Temp. Received: 5.7°C
Chlorine (TRC): 0.0 mg/l
Date Tested: 12/23/10 to 12/30/10

Sample Analysis: The following analyses were performed on your sample:
Ceriodaphnia dubia Survival and Reproduction Test (EPA Method 1002).
Attached are the test data generated from the analysis of your sample.

Result Summary:

	<u>NOEC</u>	<u>TUc</u>
<i>Ceriodaphnia</i> Survival:	100%	1.0
<i>Ceriodaphnia</i> Reproduction:	100%	1.0

Quality Control: Reviewed and approved by:


Joseph A. LeMay
Laboratory Director

CERIODAPHNIA CHRONIC BIOASSAY EPA METHOD 1002.0



Lab No.: A-10122302-001
Client/ID: Test America – ITL2272-03 (Outfall 011)

Date Tested: 12/23/10 to 12/30/10

TEST SUMMARY

Test type: Daily static-renewal.
Species: *Ceriodaphnia dubia*.
Age: < 24 hrs; all released within 8 hrs.
Test vessel size: 30 ml.
Number of test organisms per vessel: 1.
Temperature: 25 +/- 1°C.
Dilution water: Mod. hard reconstituted (MHRW).
QA/QC Batch No.: RT-101207.

Endpoints: Survival and Reproduction.
Source: In-laboratory culture.
Food: .1 ml YTC, algae per day.
Test solution volume: 15 ml.
Number of replicates: 10.
Photoperiod: 16/8 hrs. light/dark cycle.
Test duration: 7 days.
Statistics: ToxCalc computer program.

RESULTS SUMMARY

Sample Concentration	Percent Survival	Mean Number of Young Per Female
Control	100%	25.2
100% Sample	100%	28.7
* Sample not statistically significantly less than Control.		

CHRONIC TOXICITY

Survival NOEC	100%
Survival T _{Uc}	1.0
Reproduction NOEC	100%
Reproduction T _{Uc}	1.0

QA/QC TEST ACCEPTABILITY

Parameter	Result
Control survival ≥ 80%	Pass (100% survival)
≥ 15 young per surviving control female	Pass (25.2 young)
≥ 60% surviving controls had 3 broods	Pass (100% with 3 broods)
PMSD < 47% for reproduction; if > 47% and no toxicity at IWC, the test must be repeated	Pass (PMSD = 8.4%)
Statistically significantly different concentrations relative difference > 13%	Pass (no concentration significantly different)
Concentration response relationship acceptable	Pass (no significant response at concentration tested)

Ceriodaphnia Survival and Reproduction Test-7 Day Survival


Start Date: 12/23/2010 14:30 Test ID: 10122302c Sample ID: Outfall 011
 End Date: 12/30/2010 13:30 Lab ID: CAATL-Aquatic Testing Labs Sample Type: EFF2-Industrial
 Sample Date: 12/23/2010 10:54 Protocol: FWCH EPA Test Species: CD-Ceriodaphnia dubia
 Comments:

Conc-%	1	2	3	4	5	6	7	8	9	10
D-Control	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
100	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000

Conc-%	Mean	N-Mean	Resp	Not Resp	Total	N	Fisher's 1-Tailed		Isotonic	
							Exact P	Critical	Mean	N-Mean
D-Control	1.0000	1.0000	0	10	10	10			1.0000	1.0000
100	1.0000	1.0000	0	10	10	10	1.0000	0.0500	1.0000	1.0000

Hypothesis Test (1-tail, 0.05)	NOEC	LOEC	ChV	TU
Fisher's Exact Test	100	>100		1
Treatments vs D-Control				

Point	%	SD	Linear Interpolation (200 Resamples)	
			95% CL	Skew
IC05	>100			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			



Ceriodaphnia Survival and Reproduction Test-Reproduction


Start Date: 12/23/2010 14:30 Test ID: 10122302c Sample ID: Outfall 011
 End Date: 12/30/2010 13:30 Lab ID: CAATL-Aquatic Testing Labs Sample Type: EFF2-Industrial
 Sample Date: 12/23/2010 10:54 Protocol: FWCH EPA Test Species: CD-Ceriodaphnia dubia
 Comments:

Conc-%	1	2	3	4	5	6	7	8	9	10
D-Control	26.000	24.000	27.000	19.000	24.000	28.000	27.000	25.000	27.000	25.000
100	26.000	27.000	29.000	32.000	28.000	32.000	27.000	33.000	29.000	24.000

Conc-%	Mean	N-Mean	Transform: Untransformed					N	t-Stat	1-Tailed Critical	MSD	Isotonic	
			Mean	Min	Max	CV%	Mean					N-Mean	
D-Control	25.200	1.0000	25.200	19.000	28.000	10.212	10				26.950	1.0000	
100	28.700	1.1389	28.700	24.000	33.000	10.132	10	-2.850	1.734	2.129	26.950	1.0000	

Auxiliary Tests	Statistic	Critical	Skew	Kurt		
Shapiro-Wilk's Test indicates normal distribution (p > 0.05)	0.96539	0.905	-0.564	0.3019		
F-Test indicates equal variances (p = 0.72)	1.27685	6.54109				
Hypothesis Test (1-tail, 0.05)	MSDu	MSDp	MSB	MSE	F-Prob	df
Homoscedastic t Test indicates no significant differences Treatments vs D-Control	2.12928	0.0845	61.25	7.53889	0.01062	1, 18

Linear Interpolation (200 Resamples)				
Point	%	SD	95% CL	Skew
IC05	>100			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			



CERIODAPHNIA DUBIA CHRONIC BIOASSAY
EPA METHOD 1002.0 Raw Data Sheet



Lab No.: A-10122302-001

Client ID: TestAmerica - Outfall 011

Start Date: 12/23/2010

		DAY 1		DAY 2		DAY 3		DAY 4		DAY 5		DAY 6		DAY 7	
		0 hr	24hr												
Analyst Initials:		Rm	Ja	Ja	Ja										
Time of Readings:		1430	1440	1440	1440	1440	1500	1500	1500	1500	1400	1400	1330	1330	1330
Control	DO	8.0	8.2	8.2	8.2	8.4	8.2	8.3	8.1	8.4	8.4	9.0	8.0	8.8	8.1
	pH	8.2	8.2	8.1	8.1	8.2	8.1	8.2	8.1	8.2	8.2	8.2	8.1	8.2	8.1
	Temp	24.2	24.2	25.6	24.4	24.2	24.4	24.3	24.4	24.3	24.1	25.4	24.4	24.3	24.2
100%	DO	9.5	8.2	9.9	8.0	9.8	7.7	9.9	8.3	9.6	8.6	11.0	8.1	10.4	8.2
	pH	7.3	8.1	7.4	8.0	8.8	8.1	7.6	8.2	8.2	7.8	7.2	7.9	7.5	8.1
	Temp	25.7	24.5	24.9	24.4	24.1	24.4	24.6	24.3	24.6	24.2	24.6	24.8	25.0	24.3

Additional Parameters	Control	100% Sample
Conductivity (umohms)	310	90
Alkalinity (mg/l CaCO ₃)	77	30
Hardness (mg/l CaCO ₃)	88	31
Ammonia (mg/l NH ₃ -N)	<0.1	0.3

Source of Neonates											
Replicate:	A	B	C	D	E	F	G	H	I	J	
Brood ID:	2A	2B	1C	1D	2E	2F	3G	3H	1I	1J	

Sample	Day	Number of Young Produced										Total Live Young	No. Live Adults	Analyst Initials
		A	B	C	D	E	F	G	H	I	J			
Control	1	0	0	0	0	0	0	0	0	0	0	0	10	Ja
	2	0	0	0	0	0	0	0	0	0	0	0	10	
	3	0	0	0	0	3	0	4	4	0	0	11	10	
	4	4	4	3	3	0	4	0	0	4	3	25	10	
	5	0	0	9	0	8	10	10	9	9	8	63	10	
	6	7	8	0	6	0	14	13	12	14	0	74	10	
	7	15	12	15	10	13	16	0	0	0	14	79	10	
	Total	26	24	27	19	24	28	27	25	27	25	252	10	
100%	1	0	0	0	0	0	0	0	0	0	0	0	10	Ja
	2	0	0	0	0	0	0	0	0	0	0	0	10	
	3	0	0	0	0	4	0	3	4	4	0	15	10	
	4	4	3	4	5	0	4	0	0	0	4	24	10	
	5	7	8	9	10	9	11	7	11	10	10	92	10	
	6	0	16	0	0	0	17	17	0	15	0	65	10	
	7	15	0	16	17	15	0	0	18	0	10	91	10	
	Total	26	27	29	32	28	32	27	34	29	24	287	10	

Circled fourth brood not used in statistical analysis.
 7th day only used if <60% of the surviving control females have produced their third brood.



***CHAIN
OF
CUSTODY***

Client Name/Address: MWH-Arcadia 618 Michillinda Ave, Suite 200 Arcadia, CA 91007 Test America Contact: Debby Wilson				Project: Boeing-SSFL NPDES Quarterly Outfall 011 COMPOSITE <i>TIME WEIGHTED</i>			ANALYSIS REQUIRED														Comments				
Project Manager: Bronwyn Kelly Sampler: <i>RICK BANAGA</i>				Phone Number: (626) 568-6691 Fax Number: (626) 568-6515			Total Dissolved Metals: Cu, Pb, Hg, Cd, Se, Zn, Fe, Mn	Gross Alpha(900.0), Gross Beta(900.0), Tritium (H-3) (906.0), Sr-90 (905.0), Total Combined Radium 226 (903.0 or 903.1) & Radium 228 (904.0), Uranium (908.0), K- 40, CS-137 (901.0 or 901.1)	Cyanide	Chronic Toxicity															
Sample Description	Sample Matrix	Container Type	# of Cont	Sampling Date/Time	Preservative	Bottle #																			
Outfall 011	W	1L Poly	1	<i>12-23-2010</i>	None	16																			
Outfall 011	W	2.5 Gal Cube	1	<i>10:54</i>	None	17A	X																		
		500 mL Amber	1		None	17B																			
Outfall 011	W	500 mL Poly	1	<i>12-23-2010</i>	NaOH	18	X																		
Outfall 011	W	1 Gal Poly	1	<i>10:54</i>	None	19	X																		
COC Page 2 of 3 and Page 3 of 3 are the composite samples for Outfall 011 for this storm event. These must be added to the same work order for COC Page 1 of 3 for Outfall 011 for the same event.																									
Relinquished By <i>Carly Boyer</i>				Date/Time: <i>12-23-2010</i>				Received By <i>Umi Padilla</i>				Date/Time: <i>12/23/10</i>				Turn-around time: (Check) 24 Hour: ___ 72 Hour: ___ 10 Day: ___ 48 Hour: ___ 5 Day: <input checked="" type="checkbox"/> Normal: ___									
Relinquished By <i>Umi Padilla</i>				Date/Time: <i>12/23/10 14:15</i>				Received By <i>[Signature]</i>				Date/Time: <i>12-23-10 14:15</i>				Sample Integrity: (Check) Intact: ___ On Ice: <input checked="" type="checkbox"/>									
Relinquished By				Date/Time:				Received By				Date/Time:				Data Requirements: (Check) No Level IV: ___ All Level IV: ___ NPDES Level IV: <input checked="" type="checkbox"/>									

SUBCONTRACT ORDER

TestAmerica Irvine

ITL2272

SENDING LABORATORY:

TestAmerica Irvine
17461 Derian Avenue, Suite 100
Irvine, CA 92614
Phone: (949) 261-1022
Fax: (949) 260-3297
Project Manager: Debby Wilson

RECEIVING LABORATORY:

Aquatic Testing Laboratories-SUB
4350 Transport Street, Unit 107
Ventura, CA 93003
Phone : (805) 650-0546
Fax: (805) 650-0756

Analysis	Due	Expires	Laboratory ID	Comments
Sample ID: ITL2272-03	Water	Sampled: 12/23/10 10:54		
Bioassay-7 dy Chrmic	12/30/10 12:00	12/24/10 22:54		Cerio, EPA/821-R02-013, Sub to Aquatic testing
Containers Supplied: 1 gal Poly (W)				outfall 011

Released By _____ Date _____ Received By *[Signature]* Date 12-23-10 14:15

Released By _____ Date _____ Received By _____ Date _____



***REFERENCE
TOXICANT
DATA***

CERIODAPHNIA CHRONIC BIOASSAY
EPA METHOD 1002.0
REFERENCE TOXICANT - NaCl



QA/QC Batch No.: RT-101207

Date Tested: 12/07/10 to 12/13/10

TEST SUMMARY

Test type: Daily static-renewal.
 Species: *Ceriodaphnia dubia*.
 Age: < 24 hrs; all released within 8 hrs.
 Test vessel size: 30 ml.
 Number of test organisms per vessel: 1.
 Temperature: 25 +/- 1°C.
 Dilution water: Mod. hard reconstituted (MHRW).
 Reference Toxicant: Sodium chloride (NaCl).

Endpoints: Survival and Reproduction.
 Source: In-laboratory culture.
 Food: .1 ml YTC, algae per day.
 Test solution volume: 20 ml.
 Number of replicates: 10.
 Photoperiod: 16/8 hrs. light/dark cycle.
 Test duration: 6 days.
 Statistics: ToxCalc computer program.

RESULTS SUMMARY

Sample Concentration	Percent Survival		Mean Number of Young Per Female	
Control	100%		23.3	
0.25 g/l	100%		25.2	
0.5 g/l	100%		23.7	
1.0 g/l	100%		16.0	*
2.0 g/l	100%		2.9	*
4.0 g/l	0%	*	0	**

* Statistically significantly less than control at P = 0.05 level
 ** Reproduction data from concentrations greater than survival NOEC are excluded from statistical analysis.

CHRONIC TOXICITY

Survival LC50	2.8 g/l
Reproduction IC25	0.86 mg/l

QA/QC TEST ACCEPTABILITY

Parameter	Result
Control survival ≥80%	Pass (100% Survival)
≥15 young per surviving control female	Pass (23.3 young)
≥60% surviving controls had 3 broods	Pass (80% with 3 broods)
PMSD <47% for reproduction	Pass (PMSD = 18.9%)
Stat. sig. diff. conc. relative difference > 13%	Pass (Stat. sig. diff. conc. Relative difference = 31.3%)
Concentration response relationship acceptable	Pass (Response curve normal)

Ceriodaphnia Survival and Reproduction Test-Survival Day 6

Start Date: 12/7/2010 14:00 Test ID: RT101207c Sample ID: REF-Ref Toxicant
 End Date: 12/13/2010 14:00 Lab ID: CAATL-Aquatic Testing Labs Sample Type: NACL-Sodium chloride
 Sample Date: 12/6/2010 Protocol: FWCH EPA Test Species: CD-Ceriodaphnia dubia

Comments:

Conc-gm/L	1	2	3	4	5	6	7	8	9	10
D-Control	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.25	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.5	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
1	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
2	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
4	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000


Conc-gm/L	Mean	N-Mean	Resp	Not Resp	Total	N	Fisher's Exact P	1-Tailed Critical	Number Resp	Total Number
D-Control	1.0000	1.0000	0	10	10	10			0	10
0.25	1.0000	1.0000	0	10	10	10	1.0000	0.0500	0	10
0.5	1.0000	1.0000	0	10	10	10	1.0000	0.0500	0	10
1	1.0000	1.0000	0	10	10	10	1.0000	0.0500	0	10
2	1.0000	1.0000	0	10	10	10	1.0000	0.0500	0	10
4	0.0000	0.0000	10	0	10	10			10	10

Hypothesis Test (1-tail, 0.05)	NOEC	LOEC	ChV	TU
Fisher's Exact Test	2	4	2.82843	
Treatments vs D-Control				

Graphical Method


Trim Level	EC50
0.0%	2.8284

2.8284



Ceriodaphnia Chronic Survival Laboratory Control Chart

CV% = 8.41



Ceriodaphnia Survival and Reproduction Test-Reproduction

Start Date: 12/7/2010 14:00 Test ID: RT101207c Sample ID: REF-Ref Toxicant
 End Date: 12/13/2010 14:00 Lab ID: CAATL-Aquatic Testing Labs Sample Type: NACL-Sodium chloride
 Sample Date: 12/6/2010 Protocol: FWCH EPA Test Species: CD-Ceriodaphnia dubia

Comments:


Conc-gm/L	1	2	3	4	5	6	7	8	9	10
D-Control	22.000	11.000	28.000	27.000	26.000	28.000	21.000	28.000	27.000	15.000
0.25	28.000	29.000	21.000	21.000	28.000	28.000	28.000	25.000	25.000	19.000
0.5	25.000	17.000	20.000	26.000	24.000	29.000	29.000	23.000	25.000	19.000
1	10.000	10.000	20.000	22.000	20.000	11.000	15.000	12.000	24.000	16.000
2	0.000	2.000	7.000	4.000	2.000	4.000	0.000	5.000	2.000	3.000
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conc-gm/L	Mean	N-Mean	Transform: Untransformed					N	t-Stat	1-Tailed Critical	MSD	Isotonic	
			Mean	Min	Max	CV%	Mean					N-Mean	
D-Control	23.300	1.0000	23.300	11.000	28.000	25.913	10				24.250	1.0000	
0.25	25.200	1.0815	25.200	19.000	29.000	14.466	10	-0.959	2.223	4.404	24.250	1.0000	
0.5	23.700	1.0172	23.700	17.000	29.000	17.000	10	-0.202	2.223	4.404	23.700	0.9773	
*1	16.000	0.6867	16.000	10.000	24.000	32.676	10	3.686	2.223	4.404	16.000	0.6598	
*2	2.900	0.1245	2.900	0.000	7.000	75.285	10	10.299	2.223	4.404	2.900	0.1196	
4	0.000	0.0000	0.000	0.000	0.000	0.000	10				0.000	0.0000	

Auxiliary Tests	Statistic	Critical	Skew	Kurt						
Shapiro-Wilk's Test indicates normal distribution (p > 0.05)	0.96459	0.947	-0.5938	0.09413						
Bartlett's Test indicates equal variances (p = 0.06)	8.97697	13.2767								
Hypothesis Test (1-tail, 0.05)	NOEC	LOEC	ChV	TU	MSDu	MSDp	MSB	MSE	F-Prob	df
Dunnett's Test	0.5	1	0.70711		4.40372	0.189	860.47	19.6156	5.6E-15	4, 45


Linear Interpolation (200 Resamples)

Point	gm/L	SD	95% CL	Skew
IC05	0.5430	0.1060	0.2194 0.6041	-1.2164
IC10	0.6218	0.0833	0.4101 0.7081	-1.1699
IC15	0.7005	0.0819	0.5141 0.8292	-0.4850
IC20	0.7792	0.0859	0.5998 0.9452	0.1951
IC25	0.8580	0.0903	0.6963 1.0439	0.3636
IC40	1.1107	0.1011	0.9055 1.2772	-0.0498
IC50	1.2958	0.0936	1.0659 1.4429	-0.4534



Ceriodaphnia Chronic Reproduction Laboratory Control Chart

CV% = 10.1



CERIODAPHNIA DUBIA CHRONIC BIOASSAY
Reference Toxicant - NaCl
Reproduction and Survival Raw Data Sheet



QA/QC No.: RT-101207

Start Date: 12/07/2010

Sample	Day	Number of Young Produced										Total Live Young	No. Live Adults	Analyst Initials
		A	B	C	D	E	F	G	H	I	J			
Control	1	0	0	0	0	0	0	0	0	0	0	0	10	R
	2	0	0	0	0	0	0	0	0	0	0	0	10	R
	3	0	0	4	0	0	0	0	0	0	0	4	10	R
	4	3	3	0	5	4	2	3	4	4	3	31	10	R
	5	9	8	6	7	8	9	6	9	7	0	69	10	R
	6	10	0	18	15	14	17	12	15	16	12	129	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	22	11	28	27	26	28	21	28	27	15	233	10	R
0.25 g/l	1	0	0	0	0	0	0	0	0	0	0	10	R	
	2	0	0	0	0	0	0	0	0	0	0	10	R	
	3	0	0	4	0	0	0	0	0	0	4	10	R	
	4	4	3	0	4	5	4	4	3	4	4	35	10	R
	5	6	9	7	0	8	10	9	7	7	0	63	10	R
	6	18	17	10	17	15	14	15	15	14	15	150	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	28	29	21	21	28	28	28	25	25	19	252	10	R
0.5 g/l	1	0	0	0	0	0	0	0	0	0	0	10	R	
	2	0	0	0	0	0	0	0	0	0	0	10	R	
	3	0	0	0	4	0	0	0	0	0	4	10	R	
	4	4	3	4	0	5	4	4	3	3	4	34	10	R
	5	6	0	6	8	7	9	7	6	7	0	56	10	R
	6	15	14	10	14	12	16	18	14	15	15	143	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	25	17	20	26	24	29	29	23	25	19	237	10	R

Circled fourth brood not used in statistical analysis.

7th day only used if <60% of the surviving control females have produced their third brood.

CERIODAPHNIA DUBIA CHRONIC BIOASSAY
Reference Toxicant - NaCl
Reproduction and Survival Raw Data Sheet



QA/QC No.: RT-101207

Start Date: 12/07/2010

Sample	Day	Number of Young Produced										Total Live Young	No. Live Adults	Analyst Initials
		A	B	C	D	E	F	G	H	I	J			
1.0 g/l	1	0	0	0	0	0	0	0	0	0	0	0	10	R
	2	0	0	0	0	0	0	0	0	0	0	0	10	R
	3	0	0	0	0	0	0	0	0	0	0	0	10	R
	4	4	3	4	4	5	4	3	4	4	3	38	10	R
	5	0	7	6	6	7	0	0	0	6	6	38	10	R
	6	6	0	10	12	8	7	12	8	14	7	84	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	10	10	20	22	20	11	15	12	24	16	160	10	R
2.0 g/l	1	0	0	0	0	0	0	0	0	0	0	10	R	
	2	0	0	0	0	0	0	0	0	0	0	10	R	
	3	0	0	0	0	0	0	0	0	0	0	10	R	
	4	0	0	0	0	2	0	0	2	0	0	4	10	R
	5	0	2	3	0	0	4	0	0	2	0	11	10	R
	6	0	0	4	4	0	0	0	3	0	3	14	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	0	2	7	4	2	4	0	5	2	3	29	10	R
4.0 g/l	1	X	X	X	X	X	X	X	X	X	0	0	R	
	2	-	-	-	-	-	-	-	-	-	-	-	-	
	3	-	-	-	-	-	-	-	-	-	-	-	-	
	4	-	-	-	-	-	-	-	-	-	-	-	-	
	5	-	-	-	-	-	-	-	-	-	-	-	-	
	6	-	-	-	-	-	-	-	-	-	-	-	-	
	7	-	-	-	-	-	-	-	-	-	-	-	-	
	Total	0	0	0	0	0	0	0	0	0	0	0	0	R

Circled fourth brood not used in statistical analysis.
 7th day only used if <60% of the surviving control females have produced their third brood.

CERIODAPHNIA DUBIA CHRONIC BIOASSAY

Reference Toxicant - NaCl Water Chemistries Raw Data Sheet



QA/QC No.: RT-101207

Start Date: 12/07/2010

		DAY 1		DAY 2		DAY 3		DAY 4		DAY 5		DAY 6		DAY 7	
		Initial	Final												
Analyst Initials:		R	R	R	R	R	R	R	R	R	R	R	R	R	R
Time of Readings:		1400	1500	1500	1400	1400	1400	1400	1300	1300	1330	1330	1440	-	-
Control	DO	8.4	8.7	8.4	8.6	8.7	8.3	8.2	8.4	8.1	7.9	8.2	7.6	-	-
	pH	8.2	8.3	8.4	7.9	8.2	8.0	8.2	8.0	8.1	7.9	8.2	8.2	-	-
	Temp	25.0	24.3	25.0	24.5	25.0	24.6	24.8	24.7	25.1	24.0	25.3	24.2	-	-
0.25 g/l	DO	8.4	8.8	8.4	8.6	8.6	8.3	8.2	8.4	8.2	7.9	8.2	7.7	-	-
	pH	8.2	8.3	8.3	7.9	8.2	8.0	8.2	8.0	8.1	8.1	8.2	8.2	-	-
	Temp	25.0	24.6	25.0	24.8	25.0	25.0	24.8	24.8	25.1	24.0	25.2	24.2	-	-
0.5 g/l	DO	8.5	8.8	8.4	8.7	8.6	8.4	8.2	8.3	8.2	7.9	8.3	7.6	-	-
	pH	8.2	8.2	8.3	7.9	8.2	8.0	8.2	8.0	8.1	7.4	8.2	8.1	-	-
	Temp	25.0	24.7	25.1	24.8	25.0	25.1	24.9	24.9	25.0	24.1	24.6	24.1	-	-
1.0 g/l	DO	8.5	8.7	8.4	8.7	8.5	8.4	8.2	8.3	8.2	8.3	8.3	7.7	-	-
	pH	8.2	8.2	8.3	7.9	8.2	8.0	8.2	8.0	8.2	7.4	8.2	8.1	-	-
	Temp	24.9	24.6	25.1	24.9	25.1	25.0	24.9	24.9	25.0	24.0	24.5	24.9	-	-
2.0 g/l	DO	8.6	8.6	8.5	8.8	8.3	8.4	8.2	8.5	8.2	8.2	8.2	7.4	-	-
	pH	8.2	8.2	8.3	7.9	8.1	8.0	8.2	8.0	8.2	7.4	8.2	8.1	-	-
	Temp	24.8	24.8	25.2	24.8	25.2	24.9	25.0	24.8	24.9	24.9	24.5	24.2	-	-
4.0 g/l	DO	8.7	8.8	-	-	-	-	-	-	-	-	-	-	-	-
	pH	8.1	8.2	-	-	-	-	-	-	-	-	-	-	-	-
	Temp	24.6	24.8	-	-	-	-	-	-	-	-	-	-	-	-

Dissolved Oxygen (DO) readings are in mg/l O₂; Temperature (Temp) readings are in °C.

Additional Parameters	Control			High Concentration		
	Day 1	Day 3	Day 5	Day 1	Day 3	Day 5
Conductivity (µS)	325	329	322	6470	3690	3430
Alkalinity (mg/l CaCO ₃)	74	73	73	73	74	74
Hardness (mg/l CaCO ₃)	87	88	89	90	89	89

Source of Neonates


Replicate:	A	B	C	D	E	F	G	H	I	J
Brood ID:	1A	2A	3A	3B	1G	1H	2I	1J	2J	3J

Test Temperature Chart

Test No: RT-101207

Date Tested: 12/07/10 to 12/13/10

Acceptable Range: 25 \pm 1 $^{\circ}$ C





EBERLINE SERVICES

EBERLINE ANALYTICAL CORPORATION

2030 Wright Avenue

Richmond, California 94804-3849

Phone (510) 235-2633 Fax (510) 235-0438

Toll Free (800) 841-5487

www.eberlineservices.com

February 5, 2011

Ms. Debby Wilson
Test America Irvine
17461 Derian Ave., Ste. 100
Irvine, CA 92614

**Reference: Test America-Irvine ITL2272
Eberline Analytical Report S120364-8649
Sample Delivery Group 8649**

Dear Ms. Wilson:

Enclosed is a Level IV CLP-like data package (on CD) for two water samples received under Test America Job No. ITL2272. The sample was received on December 29, 2010.

Please call me, if you have any questions concerning the enclosed report.

Sincerely,

N. Joseph Verville
Client Services Manager

RM/ijb

Enclosure: Level IV CLP-like Data Package CD

1.0 General Comments

Sample delivery group 8649 consists of the analytical results and supporting documentation for two water samples. Sample ID's and reference dates/times are given in the Sample Summary section of the Summary Data report. The sample was received as stated on the chain-of-custody document. Any discrepancies are noted on the Eberline Analytical Sample Receipt Checklist. No holding times were exceeded.

Tritium and gamma analyses were performed on the sample as received i.e. the sample was not filtered. The analytical volumes for all other analyses were subjected to a full nitric acid/hydrofluoric acid dissolution, and analyses were performed on the dissolution volume.

2.0 Quality Control

For efficiency of analysis, sample ITL2272-03 was analyzed in a common prep batch with other TA samples. The QC samples from that common prep batch were assigned to SDG 8654 and are reported herein. For efficiency of analysis, sample ITL2272-03 (TRIP-BLANK) was analyzed in a common prep batch with other TA samples. The QC samples from that common prep batch were assigned to SDG 8657 and are reported herein. Quality Control Samples consisted of laboratory control samples (LCS), method blanks, duplicate analyses and matrix spike analyses. Included in the data package are copies of the Eberline Analytical radiometrics data sheets. The radiometrics data sheets for the QC LCS and QC blank samples indicate Eberline Analytical's standard QC aliquot of 1.0 sample; results for those QC types are calculated as pCi/sample. The QC LCS and QC blank sample results reported in the Summary Data Section have been divided by the appropriate method specific aliquot (see the Lab Method Summaries for specific aliquots) in order to make the results comparable to the field sample results. All QC sample results were within required control limits.

3.0 Method Errors

The error for each result is an estimate of the significant random uncertainties incurred in the measurement process. These are propagated to each final result. They include the counting (Poisson) uncertainty, as well as those intrinsic errors due to carrier or tracer standardization, aliquoting, counter efficiencies, weights, or volumes. The following method errors were propagated to the count error to calculate the 2σ error (Total):

Analysis	Method Error
Gross alpha	20.6%
Gross beta	11.0%
Tritium	10.0%
Sr-90	10.4%
Ra-226	16.4%
Ra-228	10.4%
Uranium, Total	
Gamma Spec.	7.0%

Analysis Notes


- 3.1 **Gross Alpha/Gross Beta Analysis** – No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.2 **Tritium Analysis** – No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.3 **Strontium-90 Analysis** - The Sr-90 MDA in the QC Method blank is 2.02 pCi/L, greater than the required detection limit of 2.00 pCi/L. No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.4 **Radium-226 Analysis** - No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.5 **Radium-228 Analysis** - No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.6 **Total Uranium Analysis** - No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.7 **Gamma Spectroscopy** – The K-40 MDA for sample ITL2489-03 (53.7 pCi/L) and the duplicate of sample ITL2489-03 (53.7 pCi/L) were greater than the required detection limit of 25 pCi/L, due to an elevated K40 background in the ROI for K40 on the detector used for analysis. The K-40 MDA for the duplicate of sample ITL2724-02 (28.0 pCi/L) and sample ITL2272-03 (TRIP-BLANK)(42.5 pCi/L) were greater than the required detection limit of 25 pCi/L. No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.

5.0 Case Narrative Certification Statement

"I certify that this data package is in compliance with the SOW, both technically and for completeness, for other than the conditions detailed above. Release of the data obtained in this hard copy data package has been authorized by the Laboratory Manager or a designee, as verified by the following signature."



N. Joseph Verville
Client Services Manager



Date

EBERLINE ANALYTICAL
SDG 8649

SDG 8649
Contact N. Joseph Verville


Client Test America, Inc.
Contract ITL2272

S U M M A R Y D A T A S E C T I O N

T A B L E O F C O N T E N T S				
About this section	.	.	.	1
Sample Summaries	.	.	.	3
Prep Batch Summary	.	.	.	5
Work Summary	.	.	.	6
Method Blanks	.	.	.	9
Lab Control Samples	.	.	.	11
Duplicates	.	.	.	13
Data Sheets	.	.	.	15
Method Summaries	.	.	.	17
Report Guides	.	.	.	32
End of Section	.	.	.	46



Prepared by



Reviewed by

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-TOC
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2272

ABOUT THE DATA SUMMARY SECTION

The Data Summary Section of a Data Package has all data, in several useful orders, necessary for first level, routine review of the data package for a Sample Delivery Group (SDG). This section follows the Data Package Narrative, which has an overview of the data package and a discussion of special problems. It is followed by the Raw Data Section, which has full details.

The Data Summary Section has several groups of reports:

SAMPLE SUMMARIES

The Sample and QC Summary Reports show all samples, including QC samples, reported in one SDG. These reports cross-reference client and lab sample identifiers.

PREPARATION BATCH SUMMARY

The Preparation Batch Summary Report shows all preparation batches (lab groupings reflecting how work was organized) relevant to the reported SDG with information necessary to check the completeness and consistency of the SDG.

WORK SUMMARY

The Work Summary Report shows all samples and work done on them relevant to the reported SDG.

METHOD BLANKS

The Method Blank Reports, one for each Method Blank relevant to the SDG, show all results and primary supporting information for the blanks.

LAB CONTROL SAMPLES

The Lab Control Sample Reports, one for each Lab Control Sample relevant to the SDG, show all results, recoveries and primary supporting information for these QC samples.

DUPLICATES

REPORT GUIDES

Page 1

SUMMARY DATA SECTION

Page 1

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2272

ABOUT THE DATA SUMMARY SECTION

The Duplicate Reports, one for each Duplicate and Original sample pair relevant to the SDG, show all results, differences and primary supporting information for these QC samples.

MATRIX SPIKES

The Matrix Spike Reports, one for each Spiked and Original sample pair relevant to the SDG, show all results, recoveries and primary supporting information for these QC samples.

DATA SHEETS

The Data Sheet Reports, one for each client sample in the SDG, show all results and primary supporting information for these samples.

METHOD SUMMARIES

The Method Summary Reports, one for each test used in the SDG, show all results, QC and method performance data for one analyte on one or two pages. (A test is a short code for the method used to do certain work to the client's specification.)

REPORT GUIDES

The Report Guides, one for each of the above groups of reports, have documentation on how to read the associated reports.

REPORT GUIDES

Page 2

SUMMARY DATA SECTION

Page 2

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2272

LAB SAMPLE SUMMARY

LAB SAMPLE ID	CLIENT SAMPLE ID	LOCATION	MATRIX	LEVEL	SAS NO	CHAIN OF CUSTODY	COLLECTED
S012364-01	ITL2272-03	Boeing - SSFL	WATER			ITL2272	12/23/10 10:54
S012364-02	ITL2272-03 (TRIP-BLANK)	Boeing - SSFL	WATER			ITL2272	12/23/10 10:54
S012369-03	Lab Control Sample		WATER				
S012369-04	Method Blank		WATER				
S012369-05	Duplicate (S012369-01)	Boeing - SSFL	WATER				12/26/10 08:58
S101004-02	Lab Control Sample		WATER				
S101004-03	Method Blank		WATER				
S101004-04	Duplicate (S101004-01)	Boeing - SSFL	WATER				12/30/10 02:55

LAB SUMMARY

Page 1

SUMMARY DATA SECTION

Page 3

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LS
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
 Contact N. Joseph Verville

QC SUMMARY

Client Test America, Inc.
 Contract ITL2272

QC BATCH	CHAIN OF CUSTODY	CLIENT SAMPLE ID	MATRIX	% MOIST	SAMPLE AMOUNT	BASIS AMOUNT	DAYS SINCE RECEIVED	LAB COLL	LAB SAMPLE ID	DEPARTMENT SAMPLE ID
8649	ITL2272	ITL2272-03	WATER		10.0 L		12/29/10	6	S012364-01	8649-001
		ITL2272-03 (TRIP-BLANK)	WATER		10.0 L		12/29/10	6	S012364-02	8649-002
8654		Method Blank	WATER						S012369-04	8654-004
		Lab Control Sample	WATER						S012369-03	8654-003
		Duplicate (S012369-01)	WATER		10.0 L		12/29/10	3	S012369-05	8654-005
8657		Method Blank	WATER						S101004-03	8657-003
		Lab Control Sample	WATER						S101004-02	8657-002
		Duplicate (S101004-01)	WATER		10.0 L		12/31/10	1	S101004-04	8657-004

QC SUMMARY

Page 1

SUMMARY DATA SECTION

Page 4

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-QS
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

PREP BATCH SUMMARY

Client Test America, Inc.
Contract ITL2272

TEST	MATRIX	METHOD	PREPARATION ERROR		PLANCHETS ANALYZED				QUALIFIERS
			BATCH	2σ %	CLIENT	MORE	RE BLANK	LCS	
Beta Counting									
AC	WATER	Radium-228 in Water	7271-037	10.4	1		1	1	1/0/1
			7271-039	10.4	1		1	1	1/0/1
Strontium-90 in Water									
SR	WATER	Strontium-90 in Water	7271-037	10.4	1		1	1	1/0/1
			7271-039	10.4	1		1	1	1/0/1
Gas Proportional Counting									
80A	WATER	Gross Alpha in Water	7271-037	20.6	1		1	1	1/0/1
			7271-039	20.6	1		1	1	1/0/1
80B	WATER	Gross Beta in Water	7271-037	11.0	1		1	1	1/0/1
			7271-039	11.0	1		1	1	1/0/1
Gamma Spectroscopy									
GAM	WATER	Gamma Emitters in Water	7271-037	7.0	1		1	1	1/0/1
			7271-039	7.0	1		1	1	1/0/1
Kinetic Phosphorimetry, ug									
U_T	WATER	Uranium, Total	7271-037		1		1	1	1/0/1
			7271-039		1		1	1	1/0/1
Liquid Scintillation Counting									
H	WATER	Tritium in Water	7271-037	10.0	1		1	1	1/0/1
Radon Counting									
RA	WATER	Radium-226 in Water	7271-037	16.4	1		1	1	1/0/1
			7271-039	16.4	1		1	1	1/0/1

Blank, LCS, Duplicate and Spike planchets are those in the same preparation batch as some Client sample.
In counts like 'a/b/c', 'a' = QC planchets, 'b' = Originals in this SDG, 'c' = Originals in other SDGs.

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-PBS
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

Client Test America, Inc.
Contract ITL2272

LAB WORK SUMMARY

LAB SAMPLE	CLIENT SAMPLE ID									
COLLECTED	LOCATION	MATRIX		SUF-						
RECEIVED	CUSTODY	SAS no	PLANCHET	TEST	FIX	ANALYZED	REVIEWED	BY	METHOD	
S012364-01	ITL2272-03		8649-001	80A/80		01/06/11	01/07/11	BW	Gross Alpha in Water	
12/23/10	Boeing - SSFL	WATER	8649-001	80B/80		01/06/11	01/07/11	BW	Gross Beta in Water	
12/29/10	ITL2272		8649-001	AC		01/24/11	01/25/11	BW	Radium-228 in Water	
			8649-001	GAM		01/05/11	01/11/11	MWT	Gamma Emitters in Water	
			8649-001	H		01/12/11	01/18/11	BW	Tritium in Water	
			8649-001	RA		01/22/11	01/24/11	BW	Radium-226 in Water	
			8649-001	SR		01/13/11	01/25/11	BW	Strontium-90 in Water	
			8649-001	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S012364-02	ITL2272-03 (TRIP-BLANK)		8649-002	80A/80		01/14/11	01/17/11	BW	Gross Alpha in Water	
12/23/10	Boeing - SSFL	WATER	8649-002	80B/80		01/14/11	01/17/11	BW	Gross Beta in Water	
12/29/10	ITL2272		8649-002	AC		01/26/11	01/31/11	BW	Radium-228 in Water	
			8649-002	GAM		01/13/11	01/31/11	MWT	Gamma Emitters in Water	
			8649-002	RA		01/22/11	01/28/11	BW	Radium-226 in Water	
			8649-002	SR		01/24/11	01/31/11	BW	Strontium-90 in Water	
			8649-002	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S012369-03	Lab Control Sample		8654-003	80A/80		01/06/11	01/07/11	BW	Gross Alpha in Water	
		WATER	8654-003	80B/80		01/06/11	01/07/11	BW	Gross Beta in Water	
			8654-003	AC		01/24/11	01/25/11	BW	Radium-228 in Water	
			8654-003	GAM		01/05/11	01/11/11	MWT	Gamma Emitters in Water	
			8654-003	H		01/12/11	01/18/11	BW	Tritium in Water	
			8654-003	RA		01/22/11	01/24/11	BW	Radium-226 in Water	
			8654-003	SR		01/13/11	01/25/11	BW	Strontium-90 in Water	
			8654-003	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S012369-04	Method Blank		8654-004	80A/80		01/06/11	01/07/11	BW	Gross Alpha in Water	
		WATER	8654-004	80B/80		01/06/11	01/07/11	BW	Gross Beta in Water	
			8654-004	AC		01/24/11	01/25/11	BW	Radium-228 in Water	
			8654-004	GAM		01/05/11	01/11/11	MWT	Gamma Emitters in Water	
			8654-004	H		01/12/11	01/18/11	BW	Tritium in Water	
			8654-004	RA		01/22/11	01/24/11	BW	Radium-226 in Water	
			8654-004	SR		01/13/11	01/25/11	BW	Strontium-90 in Water	
			8654-004	U_T		01/20/11	01/24/11	BW	Uranium, Total	

WORK SUMMARY

Page 1

SUMMARY DATA SECTION

Page 6

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-LWS
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

Client Test America, Inc.
Contract ITL2272

WORK SUMMARY, cont.

LAB SAMPLE	CLIENT SAMPLE ID									
COLLECTED	LOCATION	MATRIX		SUP-						
RECEIVED	CUSTODY	SAS no	PLANCHET	TEST	FIX	ANALYZED	REVIEWED	BY	METHOD	
S012369-05	Duplicate (S012369-01)		8654-005	80A/80		01/06/11	01/07/11	BW	Gross Alpha in Water	
12/26/10	Boeing - SSFL	WATER	8654-005	80B/80		01/06/11	01/07/11	BW	Gross Beta in Water	
12/29/10			8654-005	AC		01/24/11	01/25/11	BW	Radium-228 in Water	
			8654-005	GAM		01/05/11	01/11/11	MWT	Gamma Emitters in Water	
			8654-005	H		01/12/11	01/18/11	BW	Tritium in Water	
			8654-005	RA		01/22/11	01/24/11	BW	Radium-226 in Water	
			8654-005	SR		01/13/11	01/25/11	BW	Strontium-90 in Water	
			8654-005	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S101004-02	Lab Control Sample		8657-002	80A/80		01/11/11	01/12/11	BW	Gross Alpha in Water	
		WATER	8657-002	80B/80		01/11/11	01/12/11	BW	Gross Beta in Water	
			8657-002	AC		01/26/11	01/31/11	BW	Radium-228 in Water	
			8657-002	GAM		01/10/11	01/31/11	MWT	Gamma Emitters in Water	
			8657-002	RA		01/21/11	01/24/11	BW	Radium-226 in Water	
			8657-002	SR		01/26/11	01/31/11	BW	Strontium-90 in Water	
			8657-002	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S101004-03	Method Blank		8657-003	80A/80		01/11/11	01/12/11	BW	Gross Alpha in Water	
		WATER	8657-003	80B/80		01/11/11	01/12/11	BW	Gross Beta in Water	
			8657-003	AC		01/26/11	01/31/11	BW	Radium-228 in Water	
			8657-003	GAM		01/10/11	01/31/11	MWT	Gamma Emitters in Water	
			8657-003	RA		01/21/11	01/24/11	BW	Radium-226 in Water	
			8657-003	SR		01/26/11	01/31/11	BW	Strontium-90 in Water	
			8657-003	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S101004-04	Duplicate (S101004-01)		8657-004	80A/80		01/11/11	01/12/11	BW	Gross Alpha in Water	
12/30/10	Boeing - SSFL	WATER	8657-004	80B/80		01/11/11	01/12/11	BW	Gross Beta in Water	
12/31/10			8657-004	AC		01/26/11	01/31/11	BW	Radium-228 in Water	
			8657-004	GAM		01/11/11	01/31/11	MWT	Gamma Emitters in Water	
			8657-004	RA		01/21/11	01/24/11	BW	Radium-226 in Water	
			8657-004	SR		01/26/11	01/31/11	BW	Strontium-90 in Water	
			8657-004	U_T		01/20/11	01/24/11	BW	Uranium, Total	

WORK SUMMARY

Page 2

SUMMARY DATA SECTION

Page 7

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-LWS
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

WORK SUMMARY, cont.

SDG 8649
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2272

COUNTS OF TESTS BY SAMPLE TYPE

TEST	SAS no	METHOD	REFERENCE	CLIENT	MORE	RE	BLANK	LCS	DUP SPIKE	TOTAL
80A/80		Gross Alpha in Water	900.0	2			2	2	2	8
80B/80		Gross Beta in Water	900.0	2			2	2	2	8
AC		Radium-228 in Water	904.0	2			2	2	2	8
GAM		Gamma Emitters in Water	901.1	2			2	2	2	8
H		Tritium in Water	906.0	1			1	1	1	4
RA		Radium-226 in Water	903.1	2			2	2	2	8
SR		Strontium-90 in Water	905.0	2			2	2	2	8
U_T		Uranium, Total	D5174	2			2	2	2	8
TOTALS				15			15	15	15	60

WORK SUMMARY

Page 3

SUMMARY DATA SECTION

Page 8

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LWS
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

8657-003

Method Blank

METHOD BLANK

SDG <u>8649</u>	Client <u>Test America, Inc.</u>
Contact <u>N. Joseph Verville</u>	Contract <u>ITL2272</u>
Lab sample id <u>S101004-03</u>	Client sample id <u>Method Blank</u>
Dept sample id <u>8657-003</u>	Material/Matrix <u>WATER</u>

ANALYTE	CAS NO	RESULT pCi/L	2σ ERR (COUNT)	MDA pCi/L	RDL pCi/L	QUALI- FIERS	TEST
Gross Alpha	12587461	0.035	0.30	0.620	3.00	U	80A
Gross Beta	12587472	-0.211	0.63	1.11	4.00	U	80B
Tritium	10028178	N.A.			500		H
Radium-226	13982633	0.053	0.35	0.627	1.00	U	RA
Radium-228	15262201	-0.165	0.28	0.717	1.00	U	AC
Strontium-90	10098972	0.357	0.92	<u>2.02</u>	2.00	U	SR
Uranium, Total		0	0.007	0.017	1.00	U	U_T
Potassium-40	13966002	U		22.5	25.0	U	GAM
Cesium-137	10045973	U		0.916	20.0	U	GAM

QC-BLANK #76735

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-DS</u>
Version <u>3.06</u>
Report date <u>02/05/11</u>

EBERLINE ANALYTICAL

SDG 8649

8654-005

ITL2489-03

DUPLICATE

SDG <u>8649</u> Contact <u>N. Joseph Verville</u> DUPLICATE Lab sample id <u>S012369-05</u> Dept sample id <u>8654-005</u>	ORIGINAL Lab sample id <u>S012369-01</u> Dept sample id <u>8654-001</u> Received <u>12/29/10</u>	Client <u>Test America, Inc.</u> Contract <u>ITL2272</u> Client sample id <u>ITL2489-03</u> Location/Matrix <u>Boeing - SSFL</u> <u>WATER</u> Collected/Volume <u>12/26/10 08:58</u> <u>10.0 L</u> Chain of custody id <u>ITL2489</u>
--	---	--

ANALYTE	DUPLICATE	2σ ERR	MDA	RDL	QUALI-	TEST	ORIGINAL	2σ ERR	MDA	QUALI-	RPD	3σ	DER
	pCi/L	(COUNT)	pCi/L	pCi/L	FIERS		pCi/L	(COUNT)	pCi/L	FIERS	%	TOT	σ
Gross Alpha	1.65	0.42	0.342	3.00	J	80A	1.89	0.47	0.400	J	14	69	0.6
Gross Beta	3.05	0.59	0.819	4.00	J	80B	3.06	0.63	0.885	J	0	48	0
Tritium	44.4	160	267	500	U	H	-40.3	150	270	U	-		0.8
Radium-226	-0.022	0.31	0.592	1.00	U	RA	0.097	0.36	0.653	U	-		0.5
Radium-228	0.035	0.16	0.446	1.00	U	AC	0.109	0.17	0.456	U	-		0.6
Strontium-90	-0.005	0.29	0.693	2.00	U	SR	0.222	0.33	0.684	U	-		1.0
Uranium, Total	0.164	0.023	0.017	1.00	J	U_T	0.177	0.022	0.017	J	8	28	0.8
Potassium-40	U		<u>53.7</u>	25.0	U	GAM	U		<u>53.7</u>	U	-		0
Cesium-137	U		2.68	20.0	U	GAM	U		2.68	U	-		0

QC-DUP#1 76730

DUPLICATES

Page 1

SUMMARY DATA SECTION

Page 13

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-DUP</u>
Version <u>3.06</u>
Report date <u>02/05/11</u>

EBERLINE ANALYTICAL

SDG 8649

8657-004

ITL2724-02

DUPLICATE

SDG <u>8649</u> Contact <u>N. Joseph Verville</u> DUPLICATE Lab sample id <u>S101004-04</u> Dept sample id <u>8657-004</u>	ORIGINAL Lab sample id <u>S101004-01</u> Dept sample id <u>8657-001</u> Received <u>12/31/10</u>	Client <u>Test America, Inc.</u> Contract <u>ITL2272</u> Client sample id <u>ITL2724-02</u> Location/Matrix <u>Boeing - SSFL</u> <u>WATER</u> Collected/Volume <u>12/30/10 02:55</u> <u>10.0 L</u> Chain of custody id <u>ITL2724</u>
--	---	--

ANALYTE	DUPLICATE		MDA		RDL		QUALI- FIERS	TEST	ORIGINAL		MDA		QUALI- FIERS	RPD %	3σ TOT	DER σ
	pCi/L	2σ ERR (COUNT)	pCi/L		pCi/L				pCi/L	2σ ERR (COUNT)	pCi/L					
Gross Alpha	0.672	0.31	0.372		3.00		J	80A	0.336	0.29	0.412		U	67	134	1.5
Gross Beta	1.60	0.58	0.884		4.00		J	80B	1.23	0.54	0.835		J	26	87	0.9
Tritium	N.A.			500				H	N.A.							
Radium-226	0.082	0.32	0.566		1.00		U	RA	0.146	0.31	0.541		U	-		0.3
Radium-228	0.063	0.29	0.734		1.00		U	AC	0.030	0.21	0.458		U	-		0.2
Strontium-90	-0.236	0.71	1.75		2.00		U	SR	-0.099	0.80	1.94		U	-		0.3
Uranium, Total	0.082	0.012	0.017		1.00		J	U_T	0.093	0.013	0.017		J	13	30	1.2
Potassium-40	U		<u>28.0</u>		25.0		U	GAM	U		16.2		U	-		0.7
Cesium-137	U		1.50		20.0		U	GAM	U		1.25		U	-		0.3

QC-DUP#1 76736

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-DUP</u>
Version <u>3.06</u>
Report date <u>02/05/11</u>

EBERLINE ANALYTICAL

SDG 8649

8649-001

ITL2272-03

DATA SHEET

SDG <u>8649</u>	Client <u>Test America, Inc.</u>
Contact <u>N. Joseph Verville</u>	Contract <u>ITL2272</u>
Lab sample id <u>S012364-01</u>	Client sample id <u>ITL2272-03</u>
Dept sample id <u>8649-001</u>	Location/Matrix <u>Boeing - SSFL</u> <u>WATER</u>
Received <u>12/29/10</u>	Collected/Volume <u>12/23/10 10:54</u> <u>10.0 L</u>
	Chain of custody id <u>ITL2272</u>

ANALYTE	CAS NO	RESULT pCi/L	2σ ERR (COUNT)	MDA pCi/L	RDL pCi/L	QUALI- FIERS	TEST
Gross Alpha	12587461	5.10	0.71	0.467	3.00		80A
Gross Beta	12587472	5.75	0.71	0.926	4.00		80B
Tritium	10028178	49.5	160	271	500	U	H
Radium-226	13982633	0.888	0.48	0.679	1.00	J	RA
Radium-228	15262201	0.262	0.24	0.556	1.00	U	AC
Strontium-90	10098972	-0.041	0.33	0.780	2.00	U	SR
Uranium, Total		0.477	0.055	0.017	1.00	J	U_T
Potassium-40	13966002	U		16.2	25.0	U	GAM
Cesium-137	10045973	U		1.28	20.0	U	GAM

DATA SHEETS

Page 1

SUMMARY DATA SECTION

Page 15

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-DS</u>
Version <u>3.06</u>
Report date <u>02/05/11</u>

EBERLINE ANALYTICAL

SDG 8649

8649-002

ITL2272-03 (TRIP-BLANK)

DATA SHEET

SDG <u>8649</u>	Client <u>Test America, Inc.</u>
Contact <u>N. Joseph Verville</u>	Contract <u>ITL2272</u>
Lab sample id <u>S012364-02</u>	Client sample id <u>ITL2272-03 (TRIP-BLANK)</u>
Dept sample id <u>8649-002</u>	Location/Matrix <u>Boeing - SSFL</u> <u>WATER</u>
Received <u>12/29/10</u>	Collected/Volume <u>12/23/10 10:54</u> <u>10.0 L</u>
	Chain of custody id <u>ITL2272</u>

ANALYTE	CAS NO	RESULT pCi/L	2σ ERR (COUNT)	MDA pCi/L	RDL pCi/L	QUALI- FIERS	TEST
Gross Alpha	12587461	0.004	0.15	0.273	3.00	U	80A
Gross Beta	12587472	-0.182	0.47	0.788	4.00	U	80B
Radium-226	13982633	0.158	0.40	0.713	1.00	U	RA
Radium-228	15262201	0.060	0.21	0.402	1.00	U	AC
Strontium-90	10098972	0.015	0.31	0.630	2.00	U	SR
Uranium, Total		0	0.007	0.017	1.00	U	U_T
Potassium-40	13966002	U		<u>42.5</u>	25.0	U	GAM
Cesium-137	10045973	U		2.32	20.0	U	GAM

DATA SHEETS

Page 2

SUMMARY DATA SECTION

Page 16

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-DS</u>
Version <u>3.06</u>
Report date <u>02/05/11</u>

EBERLINE ANALYTICAL

SDG 8649

LAB METHOD SUMMARY, cont.

RADIUM-228 IN WATER

BETA COUNTING

Test AC Matrix _____

SDG 8649

Contact N. Joseph Verville

Client Test America, Inc.

Contract ITL2272

PROCEDURES REFERENCE 904.0
DWP-894 Sequential Separation of Actinium-228 and
Radium-226 in Drinking Water (>1 Liter Aliquot),
rev 5

AVERAGES \pm 2 SD MDA 0.525 \pm 0.264
FOR 8 SAMPLES YIELD 78 \pm 11

METHOD SUMMARIES

Page 2

SUMMARY DATA SECTION

Page 18

Lab id EAS

Protocol TA

Version Ver 1.0

Form DVD-LMS

Version 3.06

Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

LAB METHOD SUMMARY

STRONTIUM-90 IN WATER

BETA COUNTING

Test SR Matrix WATER
SDG 8649
Contact N. Joseph Verville

Client Test America, Inc.
Contract ITL2272

RESULTS

LAB RAW SUF-
SAMPLE ID TEST FIX PLANCHET CLIENT SAMPLE ID Strontium-90

Preparation batch 7271-037

S012364-01	8649-001	ITL2272-03	U
S012369-03	8654-003	Lab Control Sample	ok
S012369-04	8654-004	Method Blank	U
S012369-05	8654-005	Duplicate (S012369-01)	- U

Preparation batch 7271-039

S012364-02	8649-002	ITL2272-03 (TRIP-BLANK)	U
S101004-02	8657-002	Lab Control Sample	ok
S101004-03	8657-003	Method Blank	U
S101004-04	8657-004	Duplicate (S101004-01)	- U

Nominal values and limits from method RDLs (pCi/L) 2.00

METHOD PERFORMANCE

LAB RAW SUF- MDA ALIQ PREP DILU- YIELD EFF COUNT FWHM DRIFT DAYS ANAL-
SAMPLE ID TEST FIX CLIENT SAMPLE ID pCi/L L FAC TION % % min keV KeV HELD PREPARED YZED DETECTOR

Preparation batch 7271-037 2σ prep error 10.4 % Reference Lab Notebook No. 7271 pg.037

S012364-01	ITL2272-03	0.780	0.500	69	50	21	01/08/11	01/13	GRB-204
S012369-03	Lab Control Sample	0.597	0.500	83	50		01/08/11	01/13	GRB-222
S012369-04	Method Blank	0.666	0.500	82	50		01/08/11	01/13	GRB-201
S012369-05	Duplicate (S012369-01)	0.693	0.500	72	50	18	01/08/11	01/13	GRB-202

Preparation batch 7271-039 2σ prep error 10.4 % Reference Lab Notebook No. 7271 pg.039

S012364-02	ITL2272-03 (TRIP-BLANK)	0.630	0.500	80	100	32	01/19/11	01/24	GRB-223
S101004-02	Lab Control Sample	1.12	0.500	59	50		01/19/11	01/26	GRB-221
S101004-03	Method Blank	2.02	0.500	44	50		01/19/11	01/26	GRB-230
S101004-04	Duplicate (S101004-01)	1.75	0.500	55	50	27	01/19/11	01/26	GRB-231

Nominal values and limits from method 2.00 0.500 30-105 50 180

METHOD SUMMARIES

Page 3

SUMMARY DATA SECTION

Page 19

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-LMS
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

LAB METHOD SUMMARY, cont.

STRONTIUM-90 IN WATER

BETA COUNTING

Test SR Matrix _____

SDG 8649

Contact N. Joseph Verville

Client Test America, Inc.

Contract ITL2272

PROCEDURES REFERENCE 905.0
DWP-380 Strontium in Drinking Water, rev 8

AVERAGES \pm 2 SD MDA 1.03 \pm 1.11
FOR 8 SAMPLES YIELD 68 \pm 28

Lab id EAS

Protocol TA

Version Ver 1.0

Form DVD-LMS

Version 3.06

Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

Test 80A Matrix _____

SDG 8649

Contact N. Joseph Verville

LAB METHOD SUMMARY, cont.

GROSS ALPHA IN WATER

GAS PROPORTIONAL COUNTING

Client Test America, Inc.

Contract ITL2272

PROCEDURES	REFERENCE	900.0
	DWP-121	Gross Alpha and Gross Beta in Drinking Water, rev 10

AVERAGES ± 2 SD	MDA	<u>0.505</u> ± <u>0.366</u>
FOR 8 SAMPLES	RESIDUE	<u>42</u> ± <u>47</u>

Lab id EAS

Protocol TA

Version Ver 1.0

Form DVD-LMS

Version 3.06

Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

Test 80B Matrix WATER
 SDG 8649
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2272

LAB METHOD SUMMARY

GROSS BETA IN WATER
 GAS PROPORTIONAL COUNTING

RESULTS

LAB	RAW	SUF-			
SAMPLE ID	TEST FIX	PLANCHET	CLIENT SAMPLE ID	Gross Beta	
Preparation batch 7271-037					
S012364-01	80	8649-001	ITL2272-03	5.75	
S012369-03	80	8654-003	Lab Control Sample	ok	
S012369-04	80	8654-004	Method Blank	U	
S012369-05	80	8654-005	Duplicate (S012369-01)	ok	J
Preparation batch 7271-039					
S012364-02	80	8649-002	ITL2272-03 (TRIP-BLANK)	U	
S101004-02	80	8657-002	Lab Control Sample	ok	
S101004-03	80	8657-003	Method Blank	U	
S101004-04	80	8657-004	Duplicate (S101004-01)	ok	J
Nominal values and limits from method			RDLs (pCi/L)	4.00	

METHOD PERFORMANCE

LAB	RAW	SUF-	MDA	ALIQ	PREP	DILU-	RESID	EFF	COUNT	FWHM	DRIFT	DAYS	ANAL-		
SAMPLE ID	TEST FIX	CLIENT SAMPLE ID	pCi/L	L	FAC	TION	mg	%	min	keV	KeV	HELD	PREPARED	YZED	DETECTOR
Preparation batch 7271-037 2σ prep error 11.0 % Reference Lab Notebook No. 7271 pg.037															
S012364-01	80	ITL2272-03	0.926	0.300			41		400			14	01/06/11	01/06	GRB-214
S012369-03	80	Lab Control Sample	1.58	0.250			60		400				01/06/11	01/06	GRB-107
S012369-04	80	Method Blank	0.999	0.250			62		400				01/06/11	01/06	GRB-109
S012369-05	80	Duplicate (S012369-01)	0.819	0.300			31		400			11	01/06/11	01/06	GRB-111
Preparation batch 7271-039 2σ prep error 11.0 % Reference Lab Notebook No. 7271 pg.039															
S012364-02	80	ITL2272-03 (TRIP-BLANK)	0.788	0.300			0		400			22	01/14/11	01/14	GRB-109
S101004-02	80	Lab Control Sample	1.13	0.250			62		400				01/11/11	01/11	GRB-214
S101004-03	80	Method Blank	1.11	0.250			61		400				01/11/11	01/11	GRB-216
S101004-04	80	Duplicate (S101004-01)	0.884	0.300			20		400			12	01/11/11	01/11	GRB-105
Nominal values and limits from method			4.00	0.250			0-200		100			180			

METHOD SUMMARIES

Page 7

SUMMARY DATA SECTION

Page 23

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

LAB METHOD SUMMARY, cont.

GROSS BETA IN WATER
GAS PROPORTIONAL COUNTING

Test 80B Matrix _____
SDG 8649
Contact N. Joseph Verville

Client Test America, Inc.
Contract ITL2272

PROCEDURES REFERENCE 900.0
DWP-121 Gross Alpha and Gross Beta in Drinking Water,
rev 10

AVERAGES \pm 2 SD MDA 1.03 \pm 0.510
FOR 8 SAMPLES RESIDUE 42 \pm 47

METHOD SUMMARIES

Page 8

SUMMARY DATA SECTION

Page 24

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-LMS
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

Test GAM Matrix WATER
 SDG 8649
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2272

LAB METHOD SUMMARY

GAMMA EMITTERS IN WATER

GAMMA SPECTROSCOPY

RESULTS

LAB	RAW	SUF-				
SAMPLE ID	TEST FIX	PLANCHET	CLIENT SAMPLE ID	Cobalt-60	Cesium-137	
Preparation batch 7271-037						
S012364-01		8649-001	ITL2272-03		U	
S012369-03		8654-003	Lab Control Sample	ok	ok	
S012369-04		8654-004	Method Blank		U	
S012369-05		8654-005	Duplicate (S012369-01)		- U	
Preparation batch 7271-039						
S012364-02		8649-002	ITL2272-03 (TRIP-BLANK)		U	
S101004-02		8657-002	Lab Control Sample	ok	ok	
S101004-03		8657-003	Method Blank		U	
S101004-04		8657-004	Duplicate (S101004-01)		- U	
Nominal values and limits from method				RDLs (pCi/L)	10.0	20.0

METHOD PERFORMANCE

LAB	RAW	SUF-	MDA	ALIQ	PREP	DILU-	YIELD	EFF	COUNT	FWHM	DRIFT	DAYS	ANAL-		
SAMPLE ID	TEST FIX	CLIENT SAMPLE ID	pCi/L	L	FAC	TION	%	%	min	keV	KeV	HELD	PREPARED	YZED	DETECTOR
Preparation batch 7271-037 2σ prep error 7.0 % Reference Lab Notebook No. 7271 pg.037															
S012364-01		ITL2272-03		2.00								13	01/05/11	01/05	MB,08,00
S012369-03		Lab Control Sample		2.00									01/05/11	01/05	MB,02,00
S012369-04		Method Blank		2.00									01/05/11	01/05	01,04,00
S012369-05		Duplicate (S012369-01)		2.00								10	01/05/11	01/05	MB,05,00
Preparation batch 7271-039 2σ prep error 7.0 % Reference Lab Notebook No. 7271 pg.039															
S012364-02		ITL2272-03 (TRIP-BLANK)		2.00								21	01/10/11	01/13	MB,05,00
S101004-02		Lab Control Sample		2.00									01/10/11	01/10	MB,05,00
S101004-03		Method Blank		2.00									01/10/11	01/10	MB,08,00
S101004-04		Duplicate (S101004-01)		2.00								12	01/10/11	01/11	01,02,00
Nominal values and limits from method				6.00	2.00				400			180			

METHOD SUMMARIES

Page 9

SUMMARY DATA SECTION

Page 25

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

LAB METHOD SUMMARY, cont.

GAMMA EMITTERS IN WATER

GAMMA SPECTROSCOPY

Test GAM Matrix _____

SDG 8649

Contact N. Joseph Verville

Client Test America, Inc.

Contract ITL2272

PROCEDURES	REFERENCE	901.1
	DWP-100	Preparation of Drinking Water Samples for Gamma Spectroscopy, rev 5

METHOD SUMMARIES

Page 10

SUMMARY DATA SECTION

Page 26

Lab id EAS

Protocol TA

Version Ver 1.0

Form DVD-LMS

Version 3.06

Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

Test U T Matrix WATER
 SDG 8649
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2272

LAB METHOD SUMMARY

URANIUM, TOTAL
 KINETIC PHOSPHORIMETRY, UG

RESULTS

LAB	RAW	SUF-		Uranium,
SAMPLE ID	TEST FIX	PLANCHET	CLIENT SAMPLE ID	Total

Preparation batch 7271-037

S012364-01	8649-001	ITL2272-03		0.477 J
S012369-03	8654-003	Lab Control Sample		ok
S012369-04	8654-004	Method Blank		U
S012369-05	8654-005	Duplicate (S012369-01)		ok J

Preparation batch 7271-039

S012364-02	8649-002	ITL2272-03 (TRIP-BLANK)		U
S101004-02	8657-002	Lab Control Sample		ok
S101004-03	8657-003	Method Blank		U
S101004-04	8657-004	Duplicate (S101004-01)		ok J

Nominal values and limits from method RDLs (pCi/L) 1.00

METHOD PERFORMANCE

LAB	RAW	SUF-	MDA	ALIQ	PREP	DILU-	YIELD	EFF	COUNT	FWHM	DRIFT	DAYS	ANAL-		
SAMPLE ID	TEST FIX	CLIENT SAMPLE ID	pCi/L	L	FAC	TION	%	%	min	keV	KeV	HELD	PREPARED	YZED	DETECTOR

Preparation batch 7271-037 2σ prep error Reference Lab Notebook No. 7271 pg.037

S012364-01	ITL2272-03	0.017	0.0200									28	01/20/11	01/20	KPA-001
S012369-03	Lab Control Sample	0.174	0.0200										01/20/11	01/20	KPA-001
S012369-04	Method Blank	0.017	0.0200										01/20/11	01/20	KPA-001
S012369-05	Duplicate (S012369-01)	0.017	0.0200									25	01/20/11	01/20	KPA-001

Preparation batch 7271-039 2σ prep error Reference Lab Notebook No. 7271 pg.039

S012364-02	ITL2272-03 (TRIP-BLANK)	0.017	0.0200										28	01/20/11	01/20	KPA-001
S101004-02	Lab Control Sample	0.174	0.0200											01/20/11	01/20	KPA-001
S101004-03	Method Blank	0.017	0.0200											01/20/11	01/20	KPA-001
S101004-04	Duplicate (S101004-01)	0.017	0.0200										21	01/20/11	01/20	KPA-001

Nominal values and limits from method 1.00 0.0200 180

METHOD SUMMARIES

Page 11

SUMMARY DATA SECTION

Page 27

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

LAB METHOD SUMMARY, cont.

URANIUM, TOTAL
KINETIC PHOSPHORIMETRY, UG

Test U T Matrix _____

SDG 8649

Contact N. Joseph Verville

Client Test America, Inc.

Contract ITL2272

PROCEDURES REFERENCE D5174

AVERAGES \pm 2 SD

MDA 0.056 \pm 0.145

FOR 8 SAMPLES

YIELD _____ \pm _____

METHOD SUMMARIES

Page 12

SUMMARY DATA SECTION

Page 28

Lab id EAS

Protocol TA

Version Ver 1.0

Form DVD-LMS

Version 3.06

Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

Test H Matrix WATER
 SDG 8649
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2272

LAB METHOD SUMMARY

TRITIUM IN WATER

LIQUID SCINTILLATION COUNTING

RESULTS

LAB RAW SUP- Tritium
 SAMPLE ID TEST FIX PLANCHET CLIENT SAMPLE ID

Preparation batch 7271-037

S012364-01	8649-001	ITL2272-03	U
S012369-03	8654-003	Lab Control Sample	ok
S012369-04	8654-004	Method Blank	U
S012369-05	8654-005	Duplicate (S012369-01)	- U

Nominal values and limits from method RDLs (pCi/L) 500

METHOD PERFORMANCE

LAB RAW SUP- MDA ALIQ PREP DILU- YIELD EFF COUNT FWHM DRIFT DAYS ANAL-
 SAMPLE ID TEST FIX CLIENT SAMPLE ID pCi/L L FAC TION % % min keV KeV HELD PREPARED YZED DETECTOR

Preparation batch 7271-037 2σ prep error 10.0 % Reference Lab Notebook No. 7271 pg.037

S012364-01	ITL2272-03	271	0.0100	100	50	20	01/12/11	01/12	LSC-004
S012369-03	Lab Control Sample	271	0.100	10	50		01/12/11	01/12	LSC-004
S012369-04	Method Blank	272	0.100	10	50		01/12/11	01/12	LSC-004
S012369-05	Duplicate (S012369-01)	267	0.0100	100	50	17	01/12/11	01/12	LSC-004

Nominal values and limits from method 500 0.0100 100 180

PROCEDURES REFERENCE 906.0
 DWP-212 Tritium in Drinking Water by Distillation, rev 8

AVERAGES ± 2 SD MDA 270 ± 4.43
 FOR 4 SAMPLES YIELD 55 ± 104

METHOD SUMMARIES

Page 13

SUMMARY DATA SECTION

Page 29

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

LAB METHOD SUMMARY, cont.

RADIUM-226 IN WATER

RADON COUNTING

Test RA Matrix _____
SDG 8649 _____
Contact N. Joseph Verville _____

Client Test America, Inc. _____
Contract ITL2272 _____

PROCEDURES REFERENCE 903.1
DWP-881A Ra-226 Screening in Drinking Water, rev 6

AVERAGES ± 2 SD MDA 0.629 ± 0.101
FOR 8 SAMPLES YIELD 100 ± 0

Lab id EAS _____
Protocol TA _____
Version Ver 1.0 _____
Form DVD-LMS _____
Version 3.06 _____
Report date 02/05/11 _____

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2272

SAMPLE SUMMARY

The Sample and QC Summary Reports show all samples, including QC samples, reported in one Sample Delivery Group (SDG).

The Sample Summary Report fully identifies client samples and gives the corresponding lab sample identification. The QC Summary Report shows at the sample level how the lab organized the samples into batches and generated QC samples. The Preparation Batch and Method Summary Reports show this at the analysis level.

The following notes apply to these reports:

- * LAB SAMPLE ID is the lab's primary identification for a sample.
- * DEPARTMENT SAMPLE ID is an alternate lab id, for example one assigned by a radiochemistry department in a lab.
- * CLIENT SAMPLE ID is the client's primary identification for a sample. It includes any sample preparation done by the client that is necessary to identify the sample.
- * QC BATCH is a lab assigned code that groups samples to be processed and QCed together. These samples should have similar matrices.

QC BATCH is not necessarily the same as SDG, which reflects samples received and reported together.

- * All Lab Control Samples, Method Blanks, Duplicates and Matrix Spikes are shown that QC any of the samples. Due to possible reanalyses, not all results for all these QC samples may be relevant to the SDG. The Lab Control Sample, Method Blank, Duplicate, Matrix Spike and Method Summary Reports detail these relationships.

REPORT GUIDES

Page 1

SUMMARY DATA SECTION

Page 32

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2272

PREPARATION BATCH SUMMARY

The Preparation Batch Summary Report shows all preparation batches in one Sample Delivery Group (SDG) with information necessary to check the completeness and consistency of the SDG.

The following notes apply to this report:

- * The preparation batches are shown in the same order as the Method Summary Reports are printed.
- * Only analyses of planchets relevant to the SDG are included.
- * Each preparation batch should have at least one Method Blank and LCS in it to validate client sample results.
- * The QUALIFIERS shown are all qualifiers other than U, J, B, L and H that occur on any analysis in the preparation batch. The Method Summary Report has these qualifiers on a per sample basis.

These qualifiers should be reviewed as follows:

- X Some data has been manually entered or modified. Transcription errors are possible.
- P One or more results are 'preliminary'. The data is not ready for final reporting.
- 2 There were two or more results for one analyte on one planchet imported at one time. The results in DVD may not be the same as on the raw data sheets.

Other lab defined qualifiers may occur. In general, these should be addressed in the SDG narrative.

REPORT GUIDES

Page 2

SUMMARY DATA SECTION

Page 33

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2272

WORK SUMMARY

The Work Summary Report shows all samples, including QC samples, and all relevant analyses in one Sample Delivery Group (SDG). This report is often useful as supporting documentation for an invoice.

The following notes apply to this report:

- * TEST is a code for the method used to measure associated analytes. Results and related information for each analyte are on the Data Sheet Report. In special cases, a test code used in the summary data section is not the same as in associated raw data. In this case, both codes are shown on the Work Summary.
- * SUFFIX is the lab's code to distinguish multiple analyses (recounts, reworks, reanalyses) of a fraction of the sample. The suffix indicates which result is being reported. An empty suffix normally identifies the first attempt to analyze the sample.
- * The LAB SAMPLE ID, TEST and SUFFIX uniquely identify all supporting data for a result. The Method Summary Report for each TEST has method performance data, such as yield, for each lab sample id and suffix and procedures used in the method.
- * PLANCHET is an alternate lab identifier for work done for one test. It, combined with the TEST and SUFFIX, may be the best link to raw data.
- * For QC samples, only analyses that directly QC some regular sample are shown. The Lab Control Sample, Method Blank, Duplicate, Matrix Spike and Method Summary Reports detail these relationships.
- * The SAS (Special Analytical Services) Number is a client or lab assigned code that reflects special processing for samples, such as rapid turn around. Counts of tests done are lists by SAS number since it is likely to affect prices.

REPORT GUIDES

Page 3

SUMMARY DATA SECTION

Page 34

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
 Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
 Contract ITL2272

DATA SHEET

The Data Sheet Report shows all results and primary supporting information for one client sample or Method Blank. This report corresponds to both the CLP Inorganics and Organics Data Sheet.

The following notes apply to this report:

- * TEST is a code for the method used to measure an analyte. If the TEST is empty, no data is available; the analyte was not analyzed for.
- * The LAB SAMPLE ID and TEST uniquely identify work within the Summary Data Section of a Data Package. The Work Summary and Method Summary Reports further identify raw data that underlies this work.

The Method Summary Report for each TEST has method performance data, such as yield, for each Lab Sample ID and a list of procedures used in the method.

- * ERRORS can be labeled TOTAL or COUNT. TOTAL implies a preparation (non-counting method) error has been added, as square root of sum of squares, to the counting error denoted by COUNT. The preparation errors, which may vary by preparation batch, are shown on the Method Summary Report.
- * A RESULT can be 'N.R.' (Not Reported). This means the lab did this work but chooses not to report it now, possibly because it was reported at another time.
- * When reporting a Method Blank, a RESULT can be 'N.A.' (Not Applicable). This means there is no reported client sample work in the same preparation batch as the Blank's result. This is likely to occur when the Method Blank is associated with reanalyses of selected work for a few samples in the SDG.

The following qualifiers are defined by the DVD system:

- U The RESULT is less than the MDA (Minimum Detectable Activity). If the MDA is blank, the ERROR is used as the limit.

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2272

DATA SHEET

J The RESULT is less than the RDL (Required Detection Limit) and no U qualifier is assigned.

B A Method Blank associated with this sample had a result without a U flag and, after correcting for possibly different aliquots, that result is greater than or equal to the MDA for this sample.

Normally, B is not assigned if U is. When method blank subtraction is shown on this report, B flags are assigned based on the unsubtracted values while U's are assigned based on the subtracted ones. Both flags can be assigned in this case.

For each sample result, all Method Blank results in the same preparation batch are compared. The Method Summary Report documents this and other QC relationships.

L Some Lab Control Sample that QC's this sample had a low recovery. The lab can disable assignment of this qualifier.

H Similar to 'L' except the recovery was high.

P The RESULT is 'preliminary'.

X Some data necessary to compute the RESULT, ERROR or MDA was manually entered or modified.

2 There were two or more results available for this analyte. The reported result may not be the same as in the raw data.

Other qualifiers are lab defined. Definitions should be in the SDG narrative.

The following values are underlined to indicate possible problems:

* An MDA is underlined if it is bigger than its RDL.

* An ERROR is underlined if the 1.645 sigma counting error is bigger than both the MDA and the RESULT, implying that the MDA

REPORT GUIDES

Page 5

SUMMARY DATA SECTION

Page 36

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2272

DATA SHEET

may not be a good estimate of the 'real' minimum detectable activity.

- * A negative RESULT is underlined if it is less than the negative of its 2 sigma counting ERROR.
- * When reporting a Method Blank, a RESULT is underlined if greater than its MDA. If the MDA is blank, the 2 sigma counting error is used in the comparison.

REPORT GUIDES

Page 6

SUMMARY DATA SECTION

Page 37

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2272

LAB CONTROL SAMPLE

The Lab Control Sample Report shows all results, recoveries and primary supporting information for one Lab Control Sample.

The following notes apply to this report:

- * All fields in common with the Data Sheet Report have similar usage. Refer to its Report Guide for details.
- * An amount ADDED is the lab's value for the actual amount spiked into this sample with its ERROR an estimate of the error of this amount.

An amount added is underlined if its ratio to the corresponding RDL is outside protocol specified limits.

- * REC (Recovery) is RESULT divided by ADDED expressed as a percent.
- * The first, computed limits for the recovery reflect:
 1. The error of RESULT, including that introduced by rounding the result prior to printing.

If the limits are labeled (TOTAL), they include preparation error in the result. If labeled (COUNT), they do not.
 2. The error of ADDED.
 3. A lab specified, per analyte bias. The bias changes the center of the computed limits.
- * The second limits are protocol defined upper and lower QC limits for the recovery.
- * The recovery is underlined if it is outside either of these ranges.

REPORT GUIDES

Page 7

SUMMARY DATA SECTION

Page 38

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649

Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.

Contract ITL2272

DUPLICATE

The Duplicate Report shows all results, differences and primary supporting information for one Duplicate and associated Original sample.

The following notes apply to this report:

- * All fields in common with the Data Sheet Report have similar usage. This applies both to the Duplicate and Original sample data. Refer to the Data Sheet Report Guide for details.

If the Duplicate has data for a TEST and the lab did not do this test to the Original, the Original's RESULTS are underlined.

- * The RPD (Relative Percent Difference) is the absolute value of the difference of the RESULTS divided by their average expressed as a percent.

If both RESULTS are less than their MDAs, no RPD is computed and a '-' is printed.

For an analyte, if the lab did work for both samples but has data for only one, the MDA from the sample with data is used as the other's result in the RPD.

- * The first, computed limit is the sum, as square root of sum of squares, of the errors of the results divided by the average result as a percent, hence the relative error of the difference rather than the error of the relative difference. The errors include those introduced by rounding the RESULTS prior to printing.

If this limit is labeled TOT, it includes the preparation error in the RESULTS. If labeled CNT, it does not.

This value reported for this limit is at most 999.

- * The second limit for the RPD is the larger of:
 1. A fixed percentage specified in the protocol.

REPORT GUIDES

Page 8

SUMMARY DATA SECTION

Page 39

Lab id EAS

Protocol TA

Version Ver 1.0

Form DVD-RG

Version 3.06

Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2272

DUPLICATE

2. A protocol factor (typically 2) times the average MDA as a percent of the average result. This limit applies when the results are close to the MDAs.

- * The RPD is underlined if it is greater than either limit.
- * If specified by the lab, the second limit column is replaced by the Difference Error Ratio (DER), which is the absolute value of the difference of the results divided by the quadratic sum of their one sigma errors, the same errors as used in the first limit.

Except for differences due to rounding, the DER is the same as the RPD divided by the first RPD limit with the limit scaled to 1 sigma.

- * The DER is underlined if it is greater than the sigma factor, typically 2 or 3, shown in the header for the first RPD limit.

REPORT GUIDES

Page 9

SUMMARY DATA SECTION

Page 40

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2272

MATRIX SPIKE

The Matrix Spike Report shows all results, recoveries and primary supporting information for one Matrix Spike and associated Original sample.

The following notes apply to this report:

- * All fields in common with the Data Sheet Report have similar usage. This applies both to the Spiked and Original sample data. Refer to the Data Sheet Report Guide for details.

If the Spike has data for a TEST and the lab did not do this test to the Original, the Original's RESULTS are underlined.

- * An amount ADDED is the lab's value for the actual amount spiked into the Spike sample with its ERROR an estimate of the error of this amount.

An amount is underlined if its ratio to the corresponding RDL is outside protocol specified limits.

- * REC (Recovery) is the Spike RESULT minus the Original RESULT divided by ADDED expressed as a percent.

- * The first, computed limits for the recovery reflect:

1. The errors of the two RESULTS, including those introduced by rounding them prior to printing.

If the limits are labeled (TOTAL), they include preparation error in the result. If labeled (COUNT), they do not.

2. The error of ADDED.

3. A lab specified, per analyte bias. The bias changes the center of the computed limits.

- * The second limits are protocol defined upper and lower QC limits for the recovery.

REPORT GUIDES

Page 10

SUMMARY DATA SECTION

Page 41

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2272

MATRIX SPIKE

These limits are left blank if the Original RESULT is more than a protocol defined factor (typically 4) times ADDED. This is a way of accounting for that when the spike is small compared to the amount in the original sample, the recovery is unreliable.

- * The recovery is underlined (out of spec) if it is outside either of these ranges.

REPORT GUIDES

Page 11

SUMMARY DATA SECTION

Page 42

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2272

METHOD SUMMARY

The Method Summary Report has two tables. One shows up to five results measured using one method. The other has performance data for the method. There is one report for each TEST, as used on the Data Sheet Report.

The following notes apply to this report:

- * Each table is subdivided into sections, one for each preparation batch. A preparation batch is a group of aliquots prepared at roughly the same time in one work area of the lab using the same method.

There should be Lab Control Sample and Method Blank results in each preparation batch since this close correspondence makes the QC meaningful. Depending on lab policy, Duplicates need not occur in each batch since they QC sample dependencies such as matrix effects.

- * The RAW TEST column shows the test code used in the raw data to identify a particular analysis if it is different than the test code in the header of the report. This occurs in special cases due to method specific details about how the lab labels work.

The Lab Sample or Planchet ID combined with the (Raw) Test Code and Suffix uniquely identify the raw data for each analysis.

- * If a result is less than both its MDA and RDL, it is replaced by just 'U' on this report. If it is greater than or equal to the RDL but less than the MDA, the result is shown with a 'U' flag.

The J and X flags are as on the data sheet.

- * Non-U results for Method Blanks are underlined to indicate possible contamination of other samples in the preparation batch. The Method Blank Report has supporting data.

- * Lab Control Sample and Matrix Spike results are shown as: ok, No data, LOW or HIGH, with the last two underlined. 'No data' means no amount ADDED was specified. 'LOW' and 'HIGH'

REPORT GUIDES

Page 12

SUMMARY DATA SECTION

Page 43

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-RG
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
 Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
 Contract ITL2272

METHOD SUMMARY

correspond to when the recovery is underlined on the Lab Control Sample or Matrix Spike Report. See these reports for supporting data.

- * Duplicate sample results are shown as: ok, No data, or OUT, with the last two underlined. 'No data' means there was no original sample data found for this duplicate. 'OUT' corresponds to when the RPD is underlined on the Duplicate Report. See this report for supporting data.
 - * If the MDA column is labeled 'MAX MDA', there was more than one result measured by the reported method and the MDA shown is the largest MDA. If not all these results have the same RDL, the MAX MDA reflects only those results with RDL equal to the smallest one.
- MDAs are underlined if greater than the printed RDL.
- * Aliquots are underlined if less than the nominal value specified for the method.
 - * Preparation factors are underlined if greater than the nominal value specified for the method.
 - * Dilution factors are underlined if greater than the nominal value specified for the method.
 - * Residues are underlined if outside the range specified for the method. Residues are not printed if yields are.
 - * Yields, which may be gravimetric, radiometric or some type of recovery depending on the method, are underlined if outside the range specified for the method.
 - * Efficiencies are underlined if outside the range specified for the method. Efficiencies are detector and geometry dependent so this test is only approximate.
 - * Count times are underlined if less than the nominal value

REPORT GUIDES

Page 13

SUMMARY DATA SECTION

Page 44

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-RG
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649

Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.

Contract ITL2272

METHOD SUMMARY

specified for the method.

- * Resolutions (as FWHM; Full Width at Half Max) are underlined if greater than the method specified limit.
- * Tracer drifts are underlined if their absolute values are greater than the method specified limit. Tracer drifts are not printed if percent moistures are.
- * Days Held are underlined if greater than the holding time specified in the protocol.
- * Analysis dates are underlined if before their planchet's preparation date or, if a limit is specified, too far after it.

For some methods, ratios as percentages and error estimates for them are computed for pairs of results. A ratio column header like '1+3' means the ratio of the first result column and the third result column.

Ratios are not computed for Lab Control Sample, Method Blank or Matrix Spike results since their matrices are not necessarily similar to client samples'.

The error estimate for a ratio of results from one planchet reflects only counting errors since other errors should be correlated. For a ratio involving different planchets, if QC limits are computed based on total errors, the error for the ratio allows for the preparation errors for the planchets.

The ratio is underlined (out of spec) if the absolute value of its difference from the nominal value is greater than its error estimate. If no nominal value is specified, this test is not done.

For Gross Alpha or Gross Beta results, there may be a column showing the sum of other Alpha or Beta emitters. This sum includes all relevant results in the DVD database, whether reported or not. Results in the sum are weighted by a particles/decay value specified by the lab for each relevant analyte. Results less than their MDA are not included.

REPORT GUIDES

Page 14

SUMMARY DATA SECTION

Page 45

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-RG
 Version 3.06
 Report date 02/05/11

EBERLINE ANALYTICAL

SDG 8649

SDG 8649
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2272

METHOD SUMMARY

No sums are computed for Lab Control, Method Blank or Matrix Spike samples since their various planchets may not be physically related.

If a ratio of total isotopic to Gross Alpha or Beta is shown, the error for the ratio reflects both the error in the Gross result and the sum, as square root of sum of squares, of the errors in the isotopic results.

For total elemental uranium or thorium results, there may be a column showing the total weight computed from associated isotopic results. Ignoring results less than their MDAs, this is a weighted sum of the isotopic results. The weights depend on the molecular weight and half-life of each isotope so as to convert activities (decays) to weight (atoms).

If a ratio of total computed to measured elemental uranium or thorium is shown, the error for the ratio reflects the errors in all the measurements.

REPORT GUIDES

Page 15

SUMMARY DATA SECTION

Page 46

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 02/05/11

SUBCONTRACT ORDER
TestAmerica Irvine

ITL2272

81649

SENDING LABORATORY:

TestAmerica Irvine
 17461 Derian Avenue, Suite 100
 Irvine, CA 92614
 Phone: (949) 261-1022
 Fax: (949) 260-3297
 Project Manager: Debby Wilson

RECEIVING LABORATORY:

Eberline Services
 2030 Wright Avenue
 Richmond, CA 94804
 Phone : (510) 235-2633
 Fax: (510) 235-0438
 Project Location: California
 Receipt Temperature: _____ °C Ice: Y / N

Analysis	Units	Due	Expires	Comments
Sample ID: ITL2272-03 (Outfall 011 (Composite) - Water) Sampled: 12/23/10 10:54				
Gamma Spec-O	mg/kg	12/29/10	12/23/11 10:54	Out St Louis, k-40 and cs-137 only, DO NOT FILTER!
Gross Alpha-O	pCi/L	12/29/10	06/21/11 10:54	Out St Louis, Boeing permit, DO NOT FILTER!
Gross Beta-O	pCi/L	12/29/10	06/21/11 10:54	Out St Louis, Boeing permit, DO NOT FILTER!
Radium, Combined-O	pCi/L	12/29/10	12/23/11 10:54	Out St Louis, Boeing permit, DO NOT FILTER!
Tritium-O	pCi/L	12/29/10	12/23/11 10:54	Out St Louis, Boeing permit, DO NOT FILTER!
Uranium, Combined-O	pCi/L	12/29/10	12/23/11 10:54	Out St Louis, Boeing permit, DO NOT FILTER!

Containers Supplied:

2.5 gal Poly (T) 500 mL Amber (U)

Strontium-90 added by Debby Wilson 12/30/10 J 12/30


 Released By _____ Date/Time 12/28/10 17:00
FED EX
 Released By _____ Date/Time 12/29/10

FedEx
 Received By _____ Date/Time 12/28/10 17:00
Alex Keluef
 Received By _____ Date/Time 12/29/10 10:00



RICHMOND, CA LABORATORY

SAMPLE RECEIPT CHECKLIST

Client: TEST AMERICA City IRVINE State CA

Date/Time received 12/29/10 10:00 CoC No. ITL 2272, 2485, 2486, 2487, 2488, 2489

Container I.D. No. N/A Requested TAT (Days) STAND P.O. Received Yes [] No []

INSPECTION

1. Custody seals on shipping container intact? Yes [] No [] N/A []

2. Custody seals on shipping container dated & signed? Yes [] No [] N/A []

3. Custody seals on sample containers intact? Yes [] No [] N/A []

4. Custody seals on sample containers dated & signed? Yes [] No [] N/A []

5. Packing material is: Wet [] Dry [] N/A []

6. Number of samples in shipping container: 8 Sample Matrix WATER

7. Number of containers per sample: ≠ (Or see CoC)

8. Samples are in correct container Yes [] No []

9. Paperwork agrees with samples? Yes [] No []

10. Samples have: Tape [] Hazard labels [] Rad labels [] Appropriate sample labels []

11. Samples are: In good condition [] Leaking [] Broken Container [] Missing []

12. Samples are: Preserved [] Not preserved [] pH 2 Preservative HNO3

13. Describe any anomalies:
Two client TRIP BLANKS Not included
1 No CoC

14. Was P.M. notified of any anomalies? Yes [] No [] Date _____

15. Inspected by AK Date: 12/29/10 Time: 14:20

Customer Sample No.	Beta/Gamma cpm	Ion Chamber mR/hr	Wipe	Customer Sample No.	Beta/Gamma cpm	Ion Chamber mR/hr	wipe
<u>All Sample</u>	<u>< 60</u>						

Ion Chamber Ser. No. _____ Calibration date _____

Alpha Meter Ser. No. _____ Calibration date _____

Beta/Gamma Meter Ser. No. 100482 Calibration date 29 Sep 2010

THIS PAGE LEFT INTENTIONALLY BLANK

APPENDIX G

Section 37

Outfall 018 – December 20 & 21, 2010

MEC^X Data Validation Report

THIS PAGE LEFT INTENTIONALLY BLANK



DATA VALIDATION REPORT

Boeing SSFL NPDES

SAMPLE DELIVERY GROUP: ITL2014

Prepared by

MEC^x, LP
12269 East Vassar Drive
Aurora, CO 80014

I. INTRODUCTION

Task Order Title: Boeing SSFL NPDES
 Contract Task Order: 1261.100D.00
 Sample Delivery Group: ITL2014
 Project Manager: B. Kelly
 Matrix: Water
 QC Level: IV
 No. of Samples: 2
 No. of Reanalyses/Dilutions: 0
 Laboratory: TestAmerica-Irvine

Table 1. Sample Identification

Client ID	Laboratory ID	Sub-Laboratory ID	Matrix	Collected	Method
Outfall 018 (Grab)	ITL2014-01	N/A	Water	12/20/2010 11:00:00 AM	EPA 120.1
Outfall 018 (Composite)	ITL2014-03	G0L230559-001, S012314-01	Water	12/21/2010 10:17:00 AM	1613B, 900, 901.1, 903.1, 904, 905, 906, 245.1, 245.1-Diss, 200.7, 200.7-Diss, 180.1, D5174

II. Sample Management

No anomalies were observed regarding sample management. The temperature upon receipt was not noted by Eberline; however, due to the nonvolatile nature of the analytes, no qualifications were required. The samples in this SDG were received at TestAmerica-West Sacramento below the control limit; however, as the samples were not noted to be frozen or damaged, no qualifications were required. The samples in this SDG were received at TestAmerica-Irvine within the temperature limits of 4°C ±2°C. According to the case narrative for this SDG, the samples were received intact, on ice, and properly preserved, if applicable. The COCs were appropriately signed and dated by field and/or laboratory personnel. As the samples were couriered to TestAmerica-Irvine, custody seals were not required. Custody seals were intact upon receipt at Eberline and TestAmerica West Sacramento. If necessary, the client ID was added to the sample result summary by the reviewer.

Data Qualifier Reference Table

Qualifier	Organics	Inorganics
U	The analyte was analyzed for, but was not detected above the reported sample quantitation limit. The associated value is the quantitation limit or the estimated detection limit for dioxins or PCB congeners.	The material was analyzed for, but was not detected above the level of the associated value. The associated value is either the sample quantitation limit or the sample detection limit. The associated value is the sample detection limit or the quantitation limit for perchlorate only.
J	The analyte was positively identified; the associated numerical value is the approximate concentration of the analyte in the sample.	The associated value is an estimated quantity.
N	The analysis indicates the presence of an analyte for which there is presumptive evidence to make a "tentative identification."	Not applicable.
NJ	The analysis indicates the presence of an analyte that has been "tentatively identified" and the associated numerical value represents its approximate concentration.	Not applicable.
UJ	The analyte was not deemed above the reported sample quantitation limit. However, the reported quantitation limit is approximate and may or may not represent the actual limit of quantitation necessary to accurately and precisely measure the analyte in the sample.	The material was analyzed for, but was not detected. The associated value is an estimate and may be inaccurate or imprecise.
R	The data are unusable. The sample results are rejected due to serious deficiencies in the ability to analyze the sample and to meet quality control criteria. The presence or absence of the analyte cannot be verified.	The data are unusable. The sample results are rejected due to serious deficiencies in the ability to analyze the sample and to meet quality control criteria. The presence or absence of the analyte cannot be verified.

Qualification Code Reference Table

Qualifier	Organics	Inorganics
H	Holding times were exceeded.	Holding times were exceeded.
S	Surrogate recovery was outside QC limits.	The sequence or number of standards used for the calibration was incorrect
C	Calibration %RSD or %D was noncompliant.	Correlation coefficient is <0.995.
R	Calibration RRF was <0.05.	%R for calibration is not within control limits.
B	Presumed contamination as indicated by the preparation (method) blank results.	Presumed contamination as indicated by the preparation (method) or calibration blank results.
L	Laboratory Blank Spike/Blank Spike Duplicate %R was not within control limits.	Laboratory Control Sample %R was not within control limits.
Q	MS/MSD recovery was poor or RPD high.	MS recovery was poor.
E	Not applicable.	Duplicates showed poor agreement.
I	Internal standard performance was unsatisfactory.	ICP ICS results were unsatisfactory.
A	Not applicable.	ICP Serial Dilution %D were not within control limits.
M	Tuning (BFB or DFTPP) was noncompliant.	Not applicable.
T	Presumed contamination as indicated by the trip blank results.	Not applicable.
+	False positive – reported compound was not present.	Not applicable.
-	False negative – compound was present but not reported.	Not applicable.
F	Presumed contamination as indicated by the FB or ER results.	Presumed contamination as indicated by the FB or ER results.
\$	Reported result or other information was incorrect.	Reported result or other information was incorrect.
?	TIC identity or reported retention time has been changed.	Not applicable.

Qualification Code Reference Table Cont.

D	The analysis with this flag should not be used because another more technically sound analysis is available.	The analysis with this flag should not be used because another more technically sound analysis is available.
P	Instrument performance for pesticides was poor.	Post Digestion Spike recovery was not within control limits.
DNQ	The reported result is above the method detection limit but is less than the reporting limit.	The reported result is above the method detection limit but is less than the reporting limit.
*II, *III	Unusual problems found with the data that have been described in Section II, "Sample Management," or Section III, "Method Analyses." The number following the asterisk (*) will indicate the report section where a description of the problem can be found.	Unusual problems found with the data that have been described in Section II, "Sample Management," or Section III, "Method Analyses." The number following the asterisk (*) will indicate the report section where a description of the problem can be found.

III. Method Analyses

A. EPA METHOD 1613—Dioxin/Furans

Reviewed By: L. Calvin

Date Reviewed: January 18, 2011

The sample listed in Table 1 for this analysis was validated based on the guidelines outlined in the *MEC^x Data Validation Procedure for Dioxins and Furans (DVP-19, Rev. 0)*, *USEPA Method 1613*, and the *National Functional Guidelines Chlorinated Dioxin/Furan Data Review (8/02)*.

- Holding Times: Extraction and analytical holding times were met. The water sample was extracted and analyzed within one year of collection.
- Instrument Performance: Instrument performance criteria were met. Following are findings associated with instrument performance.
 - GC Column Performance: A Windows Defining Mix (WDM) containing the first and last eluting congeners of each descriptor and isomer specificity compounds was analyzed prior to the initial calibration sequence and at the beginning of each analytical sequence. The GC column performance in the calibrations was acceptable, with the height of the valley between the closely eluting isomers and 2,3,7,8-TCDD reported as less than 25%.
 - Mass Spectrometer Performance: The mass spectrometer performance was acceptable with the static resolving power greater than 10,000.
- Calibration: Calibration criteria were met.
 - Initial Calibration: Initial calibration criteria were met. The initial calibration was acceptable with %RSDs $\leq 20\%$ for the 15 native compounds (calibration by isotope dilution) and $\leq 35\%$ for the two native and all labeled compounds (calibration by internal standard). The relative retention times and ion abundance ratios were within the Method 1613 QC limits for all standards.
 - Continuing Calibration: Calibration verification (VER) consisted of a mid-level standard (CS3) analyzed at the beginning of each analytical sequence. The VERs were acceptable with the concentrations within the acceptance criteria listed in Table 6 of EPA Method 1613. The ion abundance ratios and relative retention times were within the method QC limits.
- Blanks: The method blank had detects between the EDL and the RL for 1,2,3,4,6,7,8-HpCDD, 1,2,3,4,6,7,8-HpCDF, 1,2,3,4,7,8,9-HpCDF, OCDD, OCDF, total HpCDD, and total HpCDF. The HpCDF isomers and total were reported as EMPCs in the method blank; however, due to the extent of the method blank contamination, the reviewer considered it appropriate to use the EMPCs to qualify sample results. The method blank

concentration of OCDD was insufficient to qualify the sample result. All other individual isomers detected in both the method blank and site sample were qualified as nondetected, "U" at the EDL, or at the level of contamination in the sample. The sample totals containing one or more peaks detected in the method blank were qualified as estimated, "J."

- Blank Spikes and Laboratory Control Samples: The LCS recoveries were within the acceptance criteria listed in Table 6 of Method 1613.
- Field QC Samples: Field QC samples were evaluated, and if necessary, qualified based on method blanks and other laboratory QC results affecting the usability of the field QC data. Any remaining detects were used to evaluate the associated site samples. Following are findings associated with field QC samples:
 - Field Blanks and Equipment Rinsates: This SDG had no identified field blank or equipment rinsate samples.
 - Field Duplicates: There were no field duplicate samples identified for this SDG.
- Internal Standards Performance: The labeled standard recoveries in the sample were within the acceptance criteria listed in Table 7 of Method 1613.
- Compound Identification: Compound identification was verified. The laboratory analyzed for polychlorinated dioxins/furans by EPA Method 1613.
- Compound Quantification and Reported Detection Limits: Compound quantitation was verified by recalculating a representative number of reportable sample results. Any individual isomers reported as EMPCs previously qualified as nondetected for method blank contamination were not further qualified as EMPCs. Remaining EMPCs were qualified as estimated nondetects, "UJ," at the level of the EMPC. Any totals including EMPC peaks were qualified as estimated, "J." Any detects reported between the estimated detection limit (EDL) and the reporting limit (RL) were qualified as estimated, "J," and coded with "DNQ," in order to comply with the NPDES permit. Nondetects are valid to the EDL.

B. EPA METHODS 200.7 and 245.1—Metals and Mercury

Reviewed By: P. Meeks

Date Reviewed: January 14, 2011

The sample listed in Table 1 for these analyses was validated based on the guidelines outlined in the *MEC^X Data Validation Procedure for Metals (DVP-5, Rev. 0 and DVP-21, Rev. 0)*, *EPA Methods 200.7 and 245.1*, and the *National Functional Guidelines for Inorganic Data Review (7/02)*.

- Holding Times: Analytical holding times, six months for ICP metals and 28 days for mercury, were met.
- Tuning: Not applicable to these analyses.
- Calibration: Calibration criteria were met. Mercury initial calibration r^2 values were ≥ 0.995 and all initial and continuing calibration recoveries were within 90-110% for the ICP and ICP-MS metals and 85-115% for mercury. CRDL/CRA recoveries were within the control limits of 70-130%.
- Blanks: Method blanks and CCBs had no detects.
- Interference Check Samples: Recoveries were within the method-established control limits of 80-120%. There were no target compounds present in the ICSA solution at concentrations indicative of matrix interference.
- Blank Spikes and Laboratory Control Samples: Recoveries were within laboratory-established QC limits.
- Laboratory Duplicates: No laboratory duplicate analyses were performed on the sample in this SDG.
- Matrix Spike/Matrix Spike Duplicate: MS/MSD analyses were performed for total and dissolved mercury and the dissolved 200.7 analytes. Recoveries and RPDs were within laboratory-established QC limits.
- Serial Dilution: No serial dilution analyses were performed on the sample in this SDG.
- Internal Standards Performance: Not applicable to these analyses.
- Sample Result Verification: Calculations were verified and the sample results reported on the sample result summary were verified against the raw data. No transcription errors or calculation errors were noted. When the sample results were qualified and the reviewer was able to clearly determine bias, detected results were qualified as either "J+" or "J-"; otherwise, bias was not indicated in the qualification. Any detects between the method detection limit and the reporting limit were qualified as estimated, "J," and coded with "DNQ," in order to comply with the NPDES permit. Reported nondetects are valid to the MDL.
- Field QC Samples: Field QC samples were evaluated, and if necessary, qualified based on method blanks and other laboratory QC results affecting the usability of the field QC data. Any remaining detects were used to evaluate the associated site samples. Following are findings associated with field QC samples:
 - Field Blanks and Equipment Rinsates: This SDG had no identified field blank or equipment rinsate samples.

- Field Duplicates: There were no field duplicate samples identified for this SDG.

C. VARIOUS EPA METHODS — Radionuclides

Reviewed By: P. Meeks

Date Reviewed: February 2011

The samples listed in Table 1 for these analyses were validated based on the guidelines outlined in the *EPA Methods 900.0, 901.1, 903.1, 904.0, 905.0, and 906.0, ASTM Method D-5174, and the National Functional Guidelines for Inorganic Data Review (10/04)*.

- Holding Times: The tritium sample was analyzed within 180 days of collection. The remaining aliquots were prepared within the five-day analytical holding time for unpreserved samples.
- Calibration: The laboratory calibration information included the standard certificates and applicable preparation/dilutions logs for NIST-traceability.

The gross alpha detector efficiency was less than 20%; therefore, gross alpha detected in the sample was qualified as an estimated detect, "J." The remaining detector efficiencies were greater than 20%.

The tritium aliquot was spiked for efficiency determination; therefore, no calibration was necessary. All chemical yields were at least 40% and were considered acceptable. The gamma spectroscopy analytes were determined at the maximum photopeak energy. The kinetic phosphorescence analyzer (KPA) was calibrated immediately prior to the sample analysis.

- Blanks: There were no analytes detected in the method blanks or the KPA CCBs.
- Blank Spikes and Laboratory Control Samples: The recoveries were within laboratory-established control limits.
- Laboratory Duplicates: Laboratory duplicate analyses were performed on the sample in this SDG for all analytes. All RPDs were within the laboratory-established control limits.
- Matrix Spike/Matrix Spike Duplicate: No MS/MSD analyses were performed for the sample in this SDG. Method accuracy was evaluated based on the LCS results.
- Sample Result Verification: An EPA Level IV review was performed for the sample in this data package. The sample results and MDAs reported on the sample result form were verified against the raw data and no calculation or transcription errors were noted. Any detects between the MDA and the reporting limit were qualified as estimated, "J," and coded with "DNQ," in order to comply with the NPDES permit. Reported nondetects are valid to the MDA.

A notation in the sample preparation logbook indicated that the aliquot for Radium-228 was filtered and that the filter was digested and added to the aliquot.

- Field QC Samples: Field QC samples were evaluated, and if necessary, qualified based on method blanks and other laboratory QC results affecting the usability of the field QC data. Any remaining detects were used to evaluate the associated site samples. Following are findings associated with field QC samples:
 - Field Blanks and Equipment Rinsates: This SDG had no identified field blank or equipment rinsate samples.
 - Field Duplicates: There were no field duplicate samples identified for this SDG.

D. VARIOUS EPA METHODS—General Minerals

Reviewed By: P. Meeks

Date Reviewed: January 14, 2011

The samples listed in Table 1 for this analysis were validated based on the guidelines outlined in the *MEC^x Data Validation Procedure for General Minerals (DVP-6, Rev. 0)*, *EPA Methods 120.1 and 180.1*, and the *National Functional Guidelines for Inorganic Data Review (7/02)*.

- Holding Times: Analytical holding times, 48 hours from collection for turbidity and 28 days for conductivity, were met.
- Calibration: Calibration criteria were met. The turbidity initial calibration r^2 value was ≥ 0.995 and all initial and continuing calibration recoveries were within 90-110%.
- Blanks: Method blanks and CCBs had no detects.
- Blank Spikes and Laboratory Control Samples: Recoveries were within laboratory-established QC limits.
- Laboratory Duplicates: No laboratory duplicate analyses were performed on the sample in this SDG.
- Matrix Spike/Matrix Spike Duplicate: No MS/MSD analyses were performed on the sample in this SDG. Method accuracy was evaluated based on LCS results.
- Sample Result Verification: Calculations were verified and the sample results reported on the sample result summary were verified against the raw data. No transcription errors or calculation errors were noted. When the sample results were qualified and the reviewer was able to clearly determine bias, detected results were qualified as either “J+” or “J-”; otherwise, bias was not indicated in the qualification. Any detects between the method detection limit and the reporting limit were qualified as estimated, “J,” and coded with

“DNQ,” in order to comply with the NPDES permit. Reported nondetects are valid to the MDL.

- Field QC Samples: Field QC samples were evaluated, and if necessary, qualified based on method blanks and other laboratory QC results affecting the usability of the field QC data. Any remaining detects were used to evaluate the associated site samples. Following are findings associated with field QC samples:
 - Field Blanks and Equipment Rinsates: This SDG had no identified field blank or equipment rinsate samples.
 - Field Duplicates: There were no field duplicate samples identified for this SDG.

Validated Sample Result Forms ITL2014

Analysis Method 8647

Sample Name	Outfall 018 (Composite)	Matrix Type:	WATER	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Uranium, Total		0.237	1	0.017	pCi/L	Jb	J	DNQ

Analysis Method 900

Sample Name	Outfall 018 (Composite)	Matrix Type:	WATER	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Gross Alpha	12587461	0.948	3	0.399	pCi/L	Jb	J	DNQ,C
Gross Beta	12587472	4.3	4	0.868	pCi/L			

Analysis Method 901.1

Sample Name	Outfall 018 (Composite)	Matrix Type:	WATER	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Cesium-137	10045973	ND	20	1.8	pCi/L	U	U	
Potassium-40	13966002	ND	25	24	pCi/L	U	U	

Analysis Method 903.1

Sample Name	Outfall 018 (Composite)	Matrix Type:	WATER	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Radium-226	13982633	0.312	1	0.71	pCi/L	U	U	

Analysis Method 904

Sample Name	Outfall 018 (Composite)	Matrix Type:	WATER	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Radium-228	15262201	0.125	1	0.604	pCi/L	U	U	

Analysis Method 905

Sample Name	Outfall 018 (Composite)	Matrix Type:	WATER	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Strontium-90	10098972	0.018	2	0.637	pCi/L	U	U	

Analysis Method 906

Sample Name	Outfall 018 (Composite)	Matrix Type:	WATER	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Tritium	10028178	144	500	340	pCi/L	U	U	

Analysis Method EPA 120.1

Sample Name	Outfall 018 (Grab)	Matrix Type:	Water	Validation Level:	IV			
Lab Sample Name:	ITL2014-01	Sample Date:	12/20/2010 11:00:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Specific Conductance	NA	150	1.0	1.0	umhos/c			

Analysis Method EPA 180.1

Sample Name	Outfall 018 (Composite)	Matrix Type:	Water	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Turbidity	Turb	47	2.0	0.080	NTU			

Analysis Method EPA 200.7

Sample Name	Outfall 018 (Composite)	Matrix Type:	Water	Validation Level:	IV			
Lab Sample Name:	ITL2014-03	Sample Date:	12/21/2010 10:17:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Iron	7439-89-6	2.3	0.040	0.015	mg/l			
Zinc	7440-66-6	19.3	20.0	6.00	ug/l	Ja	J	DNQ

Analysis Method *EPA 200.7-Diss*

Sample Name Outfall 018 (Composite) **Matrix Type:** Water **Validation Level:** IV

Lab Sample Name: ITL2014-03 **Sample Date:** 12/21/2010 10:17:00 AM

Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Iron	7439-89-6	0.016	0.040	0.015	mg/l	Ja	J	DNQ
Zinc	7440-66-6	8.05	20.0	6.00	ug/l	Ja	J	DNQ

Analysis Method *EPA 245.1*

Sample Name Outfall 018 (Composite) **Matrix Type:** Water **Validation Level:** IV

Lab Sample Name: ITL2014-03 **Sample Date:** 12/21/2010 10:17:00 AM

Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Mercury	7439-97-6	ND	0.20	0.10	ug/l		U	

Analysis Method *EPA 245.1-Diss*

Sample Name Outfall 018 (Composite) **Matrix Type:** Water **Validation Level:** IV

Lab Sample Name: ITL2014-03 **Sample Date:** 12/21/2010 10:17:00 AM

Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Mercury	7439-97-6	ND	0.20	0.10	ug/l		U	

Analysis Method EPA-5 1613B

Sample Name Outfall 018 (Composite) **Matrix Type:** WATER **Validation Level:** IV
Lab Sample Name: ITL2014-03 **Sample Date:** 12/21/2010 10:17:00 AM

Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
1,2,3,4,6,7,8-HpCDD	35822-46-9	ND	0.00005	0.0000005	ug/L	J, B	U	B
1,2,3,4,6,7,8-HpCDF	67562-39-4	ND	0.00005	0.0000005	ug/L	J, B	U	B
1,2,3,4,7,8,9-HpCDF	55673-89-7	ND	0.00005	0.0000006	ug/L	J, B	U	B
1,2,3,4,7,8-HxCDD	39227-28-6	ND	0.00005	0.0000001	ug/L	J, Q	UJ	*III
1,2,3,4,7,8-HxCDF	70648-26-9	ND	0.00005	0.0000006	ug/L		U	
1,2,3,6,7,8-HxCDD	57653-85-7	2.6e-006	0.00005	0.0000001	ug/L	J	J	DNQ
1,2,3,6,7,8-HxCDF	57117-44-9	ND	0.00005	0.0000003	ug/L		U	
1,2,3,7,8,9-HxCDD	19408-74-3	ND	0.00005	0.0000001	ug/L	J, Q	UJ	*III
1,2,3,7,8,9-HxCDF	72918-21-9	ND	0.00005	0.0000001	ug/L		U	
1,2,3,7,8-PeCDD	40321-76-4	ND	0.00005	0.0000007	ug/L		U	
1,2,3,7,8-PeCDF	57117-41-6	ND	0.00005	0.0000002	ug/L		U	
2,3,4,6,7,8-HxCDF	60851-34-5	ND	0.00005	0.0000006	ug/L		U	
2,3,4,7,8-PeCDF	57117-31-4	ND	0.00005	0.0000003	ug/L		U	
2,3,7,8-TCDD	1746-01-6	ND	0.00001	0.0000004	ug/L		U	
2,3,7,8-TCDF	51207-31-9	ND	0.00001	0.0000002	ug/L		U	
OCDD	3268-87-9	0.00052	0.0001	0.0000011	ug/L	B		
OCDF	39001-02-0	ND	0.0001	0.0000005	ug/L	J, B	U	B
Total HpCDD	37871-00-4	0.0001	0.00005	0.0000005	ug/L	J, B	J	B, DNQ
Total HpCDF	38998-75-3	2.4e-005	0.00005	0.0000005	ug/L	J, B	J	B, DNQ
Total HxCDD	34465-46-8	1.8e-005	0.00005	0.0000001	ug/L	J, Q	J	DNQ, *III
Total HxCDF	55684-94-1	7.2e-006	0.00005	0.0000001	ug/L	J, Q	J	DNQ, *III
Total PeCDD	36088-22-9	ND	0.00005	0.0000007	ug/L		U	
Total PeCDF	30402-15-4	ND	0.00005	0.0000002	ug/L		U	
Total TCDD	41903-57-5	ND	0.00001	0.0000004	ug/L		U	
Total TCDF	55722-27-5	ND	0.00001	0.0000002	ug/L		U	

THIS PAGE LEFT INTENTIONALLY BLANK

APPENDIX G

Section 38

Outfall 018 – December 20 & 21, 2010

Test America Analytical Laboratory Report

THIS PAGE LEFT INTENTIONALLY BLANK

LABORATORY REPORT

Prepared For: MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project: Quarterly Outfall 018 2010
Quarterly Outfall 018

Sampled: 12/20/10-12/21/10
Received: 12/20/10
Issued: 02/01/11 16:34

NELAP #01108CA California ELAP#2706 CSDLAC #10256 AZ #AZ0671 NV #CA01531

The results listed within this Laboratory Report pertain only to the samples tested in the laboratory. The analyses contained in this report were performed in accordance with the applicable certifications as noted. All soil samples are reported on a wet weight basis unless otherwise noted in the report. This Laboratory Report is confidential and is intended for the sole use of TestAmerica and its client. This report shall not be reproduced, except in full, without written permission from TestAmerica. The Chain(s) of Custody, 3 pages, are included and are an integral part of this report.

This entire report was reviewed and approved for release.

CASE NARRATIVE

SAMPLE RECEIPT: Samples were received intact, at 2°C, on ice and with chain of custody documentation.

HOLDING TIMES: All samples were analyzed within prescribed holding times and/or in accordance with the TestAmerica Sample Acceptance Policy unless otherwise noted in the report.

PRESERVATION: Samples requiring preservation were verified prior to sample analysis.

QA/QC CRITERIA: All analyses met method criteria, except as noted in the report with data qualifiers.

COMMENTS: Results that fall between the MDL and RL are 'J' flagged.

SUBCONTRACTED: Refer to the last page for specific subcontract laboratory information included in this report.

ADDITIONAL INFORMATION: WATER, 1613B, Dioxins/Furans with Totals
Some analytes in these samples and the associated method blank have an ion abundance ratio that is outside of criteria. The analytes are considered as an "estimated maximum possible concentration" (EMPC) because the quantitation is based on the theoretical ion abundance ratio. Analytical results are reported with a "Q" flag.

LABORATORY ID

ITL2014-01
ITL2014-02
ITL2014-03

CLIENT ID

Outfall 018 (Grab)
Trip Blanks
Outfall 018 (Composite)

MATRIX

Water
Water
Water

Reviewed By:



TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

PURGEABLES BY GC/MS (EPA 624)

Analyte	Method	Batch	Reporting Limit	MDL	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-01 (Outfall 018 (Grab) - Water)			Sampled: 12/20/10						
Reporting Units: ug/l									
Benzene	EPA 624	10L2782	0.50	0.28	ND	1	12/23/2010	12/24/2010	
Carbon tetrachloride	EPA 624	10L2782	0.50	0.28	ND	1	12/23/2010	12/24/2010	
Chloroform	EPA 624	10L2782	0.50	0.33	ND	1	12/23/2010	12/24/2010	
1,1-Dichloroethane	EPA 624	10L2782	0.50	0.40	ND	1	12/23/2010	12/24/2010	
1,2-Dichloroethane	EPA 624	10L2782	0.50	0.28	ND	1	12/23/2010	12/24/2010	
1,1-Dichloroethene	EPA 624	10L2782	0.50	0.42	ND	1	12/23/2010	12/24/2010	
Ethylbenzene	EPA 624	10L2782	0.50	0.25	ND	1	12/23/2010	12/24/2010	
Tetrachloroethene	EPA 624	10L2782	0.50	0.32	ND	1	12/23/2010	12/24/2010	
Toluene	EPA 624	10L2782	0.50	0.36	ND	1	12/23/2010	12/24/2010	
1,1,1-Trichloroethane	EPA 624	10L2782	0.50	0.30	ND	1	12/23/2010	12/24/2010	
1,1,2-Trichloroethane	EPA 624	10L2782	0.50	0.30	ND	1	12/23/2010	12/24/2010	
Trichloroethene	EPA 624	10L2782	0.50	0.26	ND	1	12/23/2010	12/24/2010	
Trichlorofluoromethane	EPA 624	10L2782	0.50	0.34	ND	1	12/23/2010	12/24/2010	
Trichlorotrifluoroethane (Freon 113)	EPA 624	10L2782	5.0	0.50	ND	1	12/23/2010	12/24/2010	
Vinyl chloride	EPA 624	10L2782	0.50	0.40	ND	1	12/23/2010	12/24/2010	
Xylenes, Total	EPA 624	10L2782	1.5	0.90	ND	1	12/23/2010	12/24/2010	
<i>Surrogate: 4-Bromofluorobenzene (80-120%)</i>					97 %				
<i>Surrogate: Dibromofluoromethane (80-120%)</i>					100 %				
<i>Surrogate: Toluene-d8 (80-120%)</i>					102 %				

Sample ID: ITL2014-02 (Trip Blanks - Water)			Sampled: 12/20/10						
Reporting Units: ug/l									
Benzene	EPA 624	10L2794	0.50	0.28	ND	1	12/23/2010	12/23/2010	
Carbon tetrachloride	EPA 624	10L2794	0.50	0.28	ND	1	12/23/2010	12/23/2010	
Chloroform	EPA 624	10L2794	0.50	0.33	ND	1	12/23/2010	12/23/2010	
1,1-Dichloroethane	EPA 624	10L2794	0.50	0.40	ND	1	12/23/2010	12/23/2010	
1,2-Dichloroethane	EPA 624	10L2794	0.50	0.28	ND	1	12/23/2010	12/23/2010	
1,1-Dichloroethene	EPA 624	10L2794	0.50	0.42	ND	1	12/23/2010	12/23/2010	
Ethylbenzene	EPA 624	10L2794	0.50	0.25	ND	1	12/23/2010	12/23/2010	
Tetrachloroethene	EPA 624	10L2794	0.50	0.32	ND	1	12/23/2010	12/23/2010	
Toluene	EPA 624	10L2794	0.50	0.36	ND	1	12/23/2010	12/23/2010	
1,1,1-Trichloroethane	EPA 624	10L2794	0.50	0.30	ND	1	12/23/2010	12/23/2010	
1,1,2-Trichloroethane	EPA 624	10L2794	0.50	0.30	ND	1	12/23/2010	12/23/2010	
Trichloroethene	EPA 624	10L2794	0.50	0.26	ND	1	12/23/2010	12/23/2010	
Trichlorofluoromethane	EPA 624	10L2794	0.50	0.34	ND	1	12/23/2010	12/23/2010	
Trichlorotrifluoroethane (Freon 113)	EPA 624	10L2794	5.0	0.50	ND	1	12/23/2010	12/23/2010	
Vinyl chloride	EPA 624	10L2794	0.50	0.40	ND	1	12/23/2010	12/23/2010	
Xylenes, Total	EPA 624	10L2794	1.5	0.90	ND	1	12/23/2010	12/23/2010	
<i>Surrogate: 4-Bromofluorobenzene (80-120%)</i>					86 %				
<i>Surrogate: Dibromofluoromethane (80-120%)</i>					91 %				
<i>Surrogate: Toluene-d8 (80-120%)</i>					107 %				

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

ACID & BASE/NEUTRALS BY GC/MS (EPA 625)

Analyte	Method	Batch	Reporting Limit	MDL	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)					Sampled: 12/21/10				
Reporting Units: ug/l									
Bis(2-ethylhexyl)phthalate	EPA 625	10L2492	4.72	1.60	ND	0.943	12/21/2010	12/23/2010	
2,4-Dinitrotoluene	EPA 625	10L2492	4.72	0.189	ND	0.943	12/21/2010	12/23/2010	
N-Nitrosodimethylamine	EPA 625	10L2492	4.72	0.0943	ND	0.943	12/21/2010	12/23/2010	
Pentachlorophenol	EPA 625	10L2492	4.72	0.0943	ND	0.943	12/21/2010	12/23/2010	
2,4,6-Trichlorophenol	EPA 625	10L2492	5.66	0.0943	ND	0.943	12/21/2010	12/23/2010	
<i>Surrogate: 2,4,6-Tribromophenol (40-120%)</i>					86 %				
<i>Surrogate: 2-Fluorobiphenyl (50-120%)</i>					77 %				
<i>Surrogate: 2-Fluorophenol (30-120%)</i>					59 %				
<i>Surrogate: Nitrobenzene-d5 (45-120%)</i>					67 %				
<i>Surrogate: Phenol-d6 (35-120%)</i>					63 %				
<i>Surrogate: Terphenyl-d14 (50-125%)</i>					82 %				

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

ORGANOCHLORINE PESTICIDES (EPA 608)

Analyte	Method	Batch	Reporting Limit	MDL	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)					Sampled: 12/21/10				
Reporting Units: ug/l									
alpha-BHC	EPA 608	10L2628	0.0094	0.0024	ND	0.943	12/22/2010	12/22/2010	
<i>Surrogate: Decachlorobiphenyl (45-120%)</i>					85 %				
<i>Surrogate: Tetrachloro-m-xylene (35-115%)</i>					69 %				

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

HEXANE EXTRACTABLE MATERIAL

Analyte	Method	Batch	Reporting Limit	MDL	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-01 (Outfall 018 (Grab) - Water)					Sampled: 12/20/10				
Reporting Units: mg/l									
Hexane Extractable Material (Oil & Grease)	EPA 1664A	10L2996	4.7	1.3	ND	1	12/27/2010	12/28/2010	

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METALS

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers	
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)						Sampled: 12/21/10			
Reporting Units: mg/l									
Iron	EPA 200.7	10L2687	0.040	2.3	1	12/22/2010	12/23/2010		
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)						Sampled: 12/21/10			
Reporting Units: ug/l									
Mercury	EPA 245.1	10L3104	0.20	0.10	ND	1	12/28/2010	12/28/2010	
Cadmium	EPA 200.8	10L2645	1.0	0.10	0.12	1	12/22/2010	12/22/2010	J
Zinc	EPA 200.7	10L2687	20.0	6.00	19.3	1	12/22/2010	12/23/2010	J
Copper	EPA 200.8	10L2645	2.00	0.500	4.10	1	12/22/2010	12/23/2010	
Lead	EPA 200.8	10L2645	1.0	0.20	1.8	1	12/22/2010	12/23/2010	
Manganese	EPA 200.8	10L2645	1.0		45	1	12/22/2010	12/22/2010	
Selenium	EPA 200.8	10L2645	2.0	0.50	ND	1	12/22/2010	12/22/2010	

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

DISSOLVED METALS

Analyte	Method	Batch	Reporting Limit		Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)					Sampled: 12/21/10				
Reporting Units: mg/l									
Iron	EPA 200.7-Diss	10L2799	0.040		ND	1	12/23/2010	12/23/2010	
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)					Sampled: 12/21/10				
Reporting Units: ug/l									
Mercury	EPA 245.1-Diss	10L3103	0.20	0.10	ND	1	12/28/2010	12/28/2010	
Cadmium	EPA 200.8-Diss	10L2800	1.0	0.10	ND	1	12/23/2010	12/23/2010	
Zinc	EPA 200.7-Diss	10L2799	20.0	6.00	8.05	1	12/23/2010	12/23/2010	J
Copper	EPA 200.8-Diss	10L2800	2.00	0.500	2.12	1	12/23/2010	12/23/2010	
Lead	EPA 200.8-Diss	10L2800	1.0	0.20	ND	1	12/23/2010	12/23/2010	
Manganese	EPA 200.8-Diss	10L2800	1.0		8.8	1	12/23/2010	12/23/2010	
Selenium	EPA 200.8-Diss	10L2800	2.0	0.50	ND	1	12/23/2010	12/23/2010	

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

INORGANICS

Analyte	Method	Batch	Reporting Limit	MDL	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-01 (Outfall 018 (Grab) - Water)					Sampled: 12/20/10				
Reporting Units: ml/l									
Total Settleable Solids	SM2540F	10L2517	0.10	0.10	ND	1	12/21/2010	12/21/2010	
Sample ID: ITL2014-01 (Outfall 018 (Grab) - Water)					Sampled: 12/20/10				
Reporting Units: umhos/cm @ 25C									
Specific Conductance	EPA 120.1	10L2408	1.0	1.0	150	1	12/21/2010	12/21/2010	
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)					Sampled: 12/21/10				
Reporting Units: mg/l									
Ammonia-N (Distilled)	SM4500NH3-C	10L2867	0.500	0.500	ND	1	12/23/2010	12/23/2010	
Biochemical Oxygen Demand	SM5210B	10L2828	2.0	0.50	1.8	1	12/23/2010	12/28/2010	J
Chloride	EPA 300.0	10L2625	0.50	0.25	6.9	1	12/22/2010	12/22/2010	
Nitrate-N	EPA 300.0	10L2625	0.11	0.060	1.0	1	12/22/2010	12/22/2010	
Nitrite-N	EPA 300.0	10L2625	0.15	0.090	ND	1	12/22/2010	12/22/2010	
Nitrate/Nitrite-N	EPA 300.0	10L2625	0.26	0.15	1.0	1	12/22/2010	12/22/2010	
Sulfate	EPA 300.0	10L2625	0.50	0.20	38	1	12/22/2010	12/22/2010	
Surfactants (MBAS)	SM5540-C	10L2679	0.10	0.050	ND	1	12/22/2010	12/22/2010	
Total Dissolved Solids	SM2540C	10L2589	10	1.0	110	1	12/22/2010	12/22/2010	
Total Suspended Solids	SM 2540D	10L2850	10	1.0	22	1	12/23/2010	12/23/2010	
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)					Sampled: 12/21/10				
Reporting Units: NTU									
Turbidity	EPA 180.1	10L2657	2.0	0.080	47	2	12/22/2010	12/22/2010	
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)					Sampled: 12/21/10				
Reporting Units: ug/l									
Perchlorate	EPA 314.0	10L3015	4.0	0.90	ND	1	12/28/2010	12/28/2010	
Total Cyanide	SM4500CN-E	10L2704	5.0	2.2	ND	1	12/22/2010	12/22/2010	

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

8647

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)				Sampled: 12/21/10				
Reporting Units: pCi/L								
Uranium, Total	8647	8647	1	0.237	1	12/30/2010	1/20/2011	Jb

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

900

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)				Sampled: 12/21/10				
Reporting Units: pCi/L								
Gross Alpha	900	8647	3	0.948	1	1/4/2011	1/5/2011	Jb
Gross Beta	900	8647	4	4.3	1	1/4/2011	1/5/2011	

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

901.1

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)				Sampled: 12/21/10				
Reporting Units: pCi/L								
Cesium-137	901.1	8647	20	ND	1	12/30/2010	1/6/2011	U
Potassium-40	901.1	8647	25	ND	1	12/30/2010	1/6/2011	U

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

903.1

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)				Sampled: 12/21/10				
Reporting Units: pCi/L								
Radium-226	903.1	8647	1	0.312	1	1/21/2011	1/21/2011	U

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

904

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)				Sampled: 12/21/10				
Reporting Units: pCi/L								
Radium-228	904	8647	1	0.125	1	1/21/2011	1/21/2011	U

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

905

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)				Sampled: 12/21/10				
Reporting Units: pCi/L								
Strontium-90	905	8647	2	0.018	1	1/8/2011	1/13/2011	U

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

906

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)				Sampled: 12/21/10				
Reporting Units: pCi/L								
Tritium	906	8647	500	144	1	1/13/2011	1/14/2011	U

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

EPA-5 1613Bx

Analyte	Method	Batch	Reporting Limit	MDL	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)			Sampled: 12/21/10						
Reporting Units: ug/L									
1,2,3,4,6,7,8-HpCDD	EPA-5 1613B	357431	0.00005	0.000005	564.7e-005	0.99	12/23/2010	12/28/2010	J, B
1,2,3,4,6,7,8-HpCDF	EPA-5 1613B	357431	0.000050	0.000005	9e-006	0.99	12/23/2010	12/28/2010	J, B
1,2,3,4,7,8,9-HpCDF	EPA-5 1613B	357431	0.00005	0.0000063	1e-006	0.99	12/23/2010	12/28/2010	J, B
1,2,3,4,7,8-HxCDD	EPA-5 1613B	357431	0.00005	0.000001	127.5e-007	0.99	12/23/2010	12/28/2010	J, Q
1,2,3,4,7,8-HxCDF	EPA-5 1613B	357431	0.00005	0.0000068	ND	0.99	12/23/2010	12/28/2010	
1,2,3,6,7,8-HxCDD	EPA-5 1613B	357431	0.000050	0.000001	2.6e-006	0.99	12/23/2010	12/28/2010	J
1,2,3,6,7,8-HxCDF	EPA-5 1613B	357431	0.00005	0.0000036	ND	0.99	12/23/2010	12/28/2010	
1,2,3,7,8,9-HxCDD	EPA-5 1613B	357431	0.000050	0.000001	1.9e-006	0.99	12/23/2010	12/28/2010	J, Q
1,2,3,7,8,9-HxCDF	EPA-5 1613B	357431	0.00005	0.0000012	ND	0.99	12/23/2010	12/28/2010	
1,2,3,7,8-PeCDD	EPA-5 1613B	357431	0.00005	0.0000072	ND	0.99	12/23/2010	12/28/2010	
1,2,3,7,8-PeCDF	EPA-5 1613B	357431	0.00005	0.0000022	ND	0.99	12/23/2010	12/28/2010	
2,3,4,6,7,8-HxCDF	EPA-5 1613B	357431	0.000050	0.000006	ND	0.99	12/23/2010	12/28/2010	
2,3,4,7,8-PeCDF	EPA-5 1613B	357431	0.00005	0.0000035	ND	0.99	12/23/2010	12/28/2010	
2,3,7,8-TCDD	EPA-5 1613B	357431	0.00005	0.0000044	ND	0.99	12/23/2010	12/28/2010	
2,3,7,8-TCDF	EPA-5 1613B	357431	0.00005	0.0000026	ND	0.99	12/23/2010	12/28/2010	
OCDD	EPA-5 1613B	357431	0.0001	0.0000011	0.00052	0.99	12/23/2010	12/28/2010	B
OCDF	EPA-5 1613B	357431	0.00010	0.0000058	1.6e-005	0.99	12/23/2010	12/28/2010	J, B
Total HpCDD	EPA-5 1613B	357431	0.00005	0.0000056	0.0001	0.99	12/23/2010	12/28/2010	J, B
Total HpCDF	EPA-5 1613B	357431	0.00005	0.0000056	2.4e-005	0.99	12/23/2010	12/28/2010	J, B
Total HxCDD	EPA-5 1613B	357431	0.00005	0.0000011	1.8e-005	0.99	12/23/2010	12/28/2010	J, Q
Total HxCDF	EPA-5 1613B	357431	0.000050	0.000001	7.2e-006	0.99	12/23/2010	12/28/2010	J, Q
Total PeCDD	EPA-5 1613B	357431	0.00005	0.0000072	ND	0.99	12/23/2010	12/28/2010	
Total PeCDF	EPA-5 1613B	357431	0.00005	0.0000022	ND	0.99	12/23/2010	12/28/2010	
Total TCDD	EPA-5 1613B	357431	0.00005	0.0000044	ND	0.99	12/23/2010	12/28/2010	
Total TCDF	EPA-5 1613B	357431	0.00005	0.0000026	ND	0.99	12/23/2010	12/28/2010	

Surrogate: 13C-1,2,3,4,6,7,8-HpCDD (23-140%)	104 %
Surrogate: 13C-1,2,3,4,6,7,8-HpCDF (28-143%)	92 %
Surrogate: 13C-1,2,3,4,7,8,9-HpCDF (26-138%)	99 %
Surrogate: 13C-1,2,3,4,7,8-HxCDD (32-141%)	78 %
Surrogate: 13C-1,2,3,4,7,8-HxCDF (26-152%)	77 %
Surrogate: 13C-1,2,3,6,7,8-HxCDD (28-130%)	94 %
Surrogate: 13C-1,2,3,6,7,8-HxCDF (26-123%)	79 %
Surrogate: 13C-1,2,3,7,8,9-HxCDF (29-147%)	77 %
Surrogate: 13C-1,2,3,7,8-PeCDD (25-181%)	86 %
Surrogate: 13C-1,2,3,7,8-PeCDF (24-185%)	94 %
Surrogate: 13C-2,3,4,6,7,8-HxCDF (28-136%)	79 %
Surrogate: 13C-2,3,4,7,8-PeCDF (21-178%)	86 %
Surrogate: 13C-2,3,7,8-TCDD (25-164%)	84 %
Surrogate: 13C-2,3,7,8-TCDF (24-169%)	79 %
Surrogate: 13C-OCDD (17-157%)	90 %
Surrogate: 37Cl-2,3,7,8-TCDD (35-197%)	101 %

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

SHORT HOLD TIME DETAIL REPORT

	Hold Time (in days)	Date/Time Sampled	Date/Time Received	Date/Time Extracted	Date/Time Analyzed
Sample ID: Outfall 018 (Grab) (ITL2014-01) - Water					
SM2540F	2	12/20/2010 11:00	12/20/2010 20:24	12/21/2010 11:35	12/21/2010 11:35
Sample ID: Outfall 018 (Composite) (ITL2014-03) - Water					
EPA 180.1	2	12/21/2010 10:17	12/20/2010 20:24	12/22/2010 10:30	12/22/2010 10:30
EPA 300.0	2	12/21/2010 10:17	12/20/2010 20:24	12/22/2010 09:00	12/22/2010 09:21
Filtration	1	12/21/2010 10:17	12/20/2010 20:24	12/21/2010 23:45	12/21/2010 23:45
SM5210B	2	12/21/2010 10:17	12/20/2010 20:24	12/23/2010 09:40	12/28/2010 11:00
SM5540-C	2	12/21/2010 10:17	12/20/2010 20:24	12/22/2010 10:20	12/22/2010 11:20

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2782 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2782-BLK1)										
Benzene	ND	0.50	ug/l							
Carbon tetrachloride	ND	0.50	ug/l							
Chloroform	ND	0.50	ug/l							
1,1-Dichloroethane	ND	0.50	ug/l							
1,2-Dichloroethane	ND	0.50	ug/l							
1,1-Dichloroethene	ND	0.50	ug/l							
Ethylbenzene	ND	0.50	ug/l							
Tetrachloroethene	ND	0.50	ug/l							
Toluene	ND	0.50	ug/l							
1,1,1-Trichloroethane	ND	0.50	ug/l							
1,1,2-Trichloroethane	ND	0.50	ug/l							
Trichloroethene	ND	0.50	ug/l							
Trichlorofluoromethane	ND	0.50	ug/l							
Trichlorotrifluoroethane (Freon 113)	ND	5.0	ug/l							
Vinyl chloride	ND	0.50	ug/l							
Xylenes, Total	ND	1.5	ug/l							
<i>Surrogate: 4-Bromofluorobenzene</i>	23.8		ug/l	25.0		95	80-120			
<i>Surrogate: Dibromofluoromethane</i>	24.1		ug/l	25.0		96	80-120			
<i>Surrogate: Toluene-d8</i>	25.1		ug/l	25.0		100	80-120			
LCS Analyzed: 12/23/2010 (10L2782-BS1)										
Benzene	24.2	0.50	ug/l	25.0		97	70-120			
Carbon tetrachloride	30.1	0.50	ug/l	25.0		120	65-140			
Chloroform	26.1	0.50	ug/l	25.0		104	70-130			
1,1-Dichloroethane	26.2	0.50	ug/l	25.0		105	70-125			
1,2-Dichloroethane	28.0	0.50	ug/l	25.0		112	60-140			
1,1-Dichloroethene	24.3	0.50	ug/l	25.0		97	70-125			
Ethylbenzene	27.2	0.50	ug/l	25.0		109	75-125			
Tetrachloroethene	27.8	0.50	ug/l	25.0		111	70-125			
Toluene	25.8	0.50	ug/l	25.0		103	70-120			
1,1,1-Trichloroethane	30.3	0.50	ug/l	25.0		121	65-135			
1,1,2-Trichloroethane	26.0	0.50	ug/l	25.0		104	70-125			
Trichloroethene	27.5	0.50	ug/l	25.0		110	70-125			
Trichlorofluoromethane	29.0	0.50	ug/l	25.0		116	65-145			
Vinyl chloride	21.8	0.50	ug/l	25.0		87	55-135			
Xylenes, Total	82.0	1.5	ug/l	75.0		109	70-125			

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2782 Extracted: 12/23/10										
LCS Analyzed: 12/23/2010 (10L2782-BS1)										
Surrogate: 4-Bromofluorobenzene	24.6		ug/l	25.0		98	80-120			
Surrogate: Dibromofluoromethane	24.4		ug/l	25.0		98	80-120			
Surrogate: Toluene-d8	25.3		ug/l	25.0		101	80-120			
LCS Dup Analyzed: 12/23/2010 (10L2782-BSD1)										
Benzene	24.6	0.50	ug/l	25.0		98	70-120	2	20	
Carbon tetrachloride	30.7	0.50	ug/l	25.0		123	65-140	2	25	
Chloroform	26.4	0.50	ug/l	25.0		106	70-130	1	20	
1,1-Dichloroethane	26.7	0.50	ug/l	25.0		107	70-125	2	20	
1,2-Dichloroethane	28.5	0.50	ug/l	25.0		114	60-140	2	20	
1,1-Dichloroethene	25.4	0.50	ug/l	25.0		102	70-125	4	20	
Ethylbenzene	27.8	0.50	ug/l	25.0		111	75-125	2	20	
Tetrachloroethene	27.9	0.50	ug/l	25.0		112	70-125	0.4	20	
Toluene	25.9	0.50	ug/l	25.0		104	70-120	0.5	20	
1,1,1-Trichloroethane	30.7	0.50	ug/l	25.0		123	65-135	1	20	
1,1,2-Trichloroethane	26.4	0.50	ug/l	25.0		105	70-125	1	20	
Trichloroethene	27.8	0.50	ug/l	25.0		111	70-125	0.8	20	
Trichlorofluoromethane	29.7	0.50	ug/l	25.0		119	65-145	2	20	
Vinyl chloride	22.0	0.50	ug/l	25.0		88	55-135	0.7	30	
Xylenes, Total	83.1	1.5	ug/l	75.0		111	70-125	1	20	
Surrogate: 4-Bromofluorobenzene	24.4		ug/l	25.0		98	80-120			
Surrogate: Dibromofluoromethane	24.7		ug/l	25.0		99	80-120			
Surrogate: Toluene-d8	25.1		ug/l	25.0		100	80-120			

Matrix Spike Analyzed: 12/23/2010 (10L2782-MS1)

Source: ITL2140-01

Benzene	24.1	0.50	ug/l	25.0	ND	96	65-125			
Carbon tetrachloride	29.6	0.50	ug/l	25.0	ND	118	65-140			
Chloroform	25.4	0.50	ug/l	25.0	ND	101	65-135			
1,1-Dichloroethane	26.0	0.50	ug/l	25.0	ND	104	65-130			
1,2-Dichloroethane	27.6	0.50	ug/l	25.0	ND	111	60-140			
1,1-Dichloroethene	24.6	0.50	ug/l	25.0	ND	98	60-130			
Ethylbenzene	27.2	0.50	ug/l	25.0	ND	109	65-130			
Tetrachloroethene	27.0	0.50	ug/l	25.0	ND	108	65-130			
Toluene	25.5	0.50	ug/l	25.0	ND	102	70-125			
1,1,1-Trichloroethane	29.7	0.50	ug/l	25.0	ND	119	65-140			
1,1,2-Trichloroethane	26.2	0.50	ug/l	25.0	ND	105	65-130			
Trichloroethene	27.0	0.50	ug/l	25.0	ND	108	65-125			

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2782 Extracted: 12/23/10										
Matrix Spike Analyzed: 12/23/2010 (10L2782-MS1)					Source: ITL2140-01					
Trichlorofluoromethane	29.1	0.50	ug/l	25.0	ND	117	60-145			
Vinyl chloride	22.1	0.50	ug/l	25.0	ND	89	45-140			
Xylenes, Total	80.6	1.5	ug/l	75.0	ND	107	60-130			
Surrogate: 4-Bromofluorobenzene	24.8		ug/l	25.0		99	80-120			
Surrogate: Dibromofluoromethane	25.0		ug/l	25.0		100	80-120			
Surrogate: Toluene-d8	25.4		ug/l	25.0		102	80-120			
Matrix Spike Dup Analyzed: 12/23/2010 (10L2782-MSD1)					Source: ITL2140-01					
Benzene	24.0	0.50	ug/l	25.0	ND	96	65-125	0.4	20	
Carbon tetrachloride	29.7	0.50	ug/l	25.0	ND	119	65-140	0.3	25	
Chloroform	25.8	0.50	ug/l	25.0	ND	103	65-135	2	20	
1,1-Dichloroethane	26.2	0.50	ug/l	25.0	ND	105	65-130	0.6	20	
1,2-Dichloroethane	27.6	0.50	ug/l	25.0	ND	110	60-140	0.1	20	
1,1-Dichloroethene	24.7	0.50	ug/l	25.0	ND	99	60-130	0.2	20	
Ethylbenzene	26.9	0.50	ug/l	25.0	ND	108	65-130	1	20	
Tetrachloroethene	27.4	0.50	ug/l	25.0	ND	109	65-130	1	20	
Toluene	25.4	0.50	ug/l	25.0	ND	102	70-125	0.6	20	
1,1,1-Trichloroethane	29.8	0.50	ug/l	25.0	ND	119	65-140	0.5	20	
1,1,2-Trichloroethane	26.7	0.50	ug/l	25.0	ND	107	65-130	2	25	
Trichloroethene	26.8	0.50	ug/l	25.0	ND	107	65-125	0.4	20	
Trichlorofluoromethane	29.0	0.50	ug/l	25.0	ND	116	60-145	0.4	25	
Vinyl chloride	22.0	0.50	ug/l	25.0	ND	88	45-140	0.8	30	
Xylenes, Total	80.1	1.5	ug/l	75.0	ND	107	60-130	0.6	20	
Surrogate: 4-Bromofluorobenzene	24.8		ug/l	25.0		99	80-120			
Surrogate: Dibromofluoromethane	24.8		ug/l	25.0		99	80-120			
Surrogate: Toluene-d8	25.3		ug/l	25.0		101	80-120			

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2794 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2794-BLK1)										
Benzene	ND	0.50	ug/l							
Carbon tetrachloride	ND	0.50	ug/l							
Chloroform	ND	0.50	ug/l							
1,1-Dichloroethane	ND	0.50	ug/l							
1,2-Dichloroethane	ND	0.50	ug/l							
1,1-Dichloroethene	ND	0.50	ug/l							
Ethylbenzene	ND	0.50	ug/l							
Tetrachloroethene	ND	0.50	ug/l							
Toluene	ND	0.50	ug/l							
1,1,1-Trichloroethane	ND	0.50	ug/l							
1,1,2-Trichloroethane	ND	0.50	ug/l							
Trichloroethene	ND	0.50	ug/l							
Trichlorofluoromethane	ND	0.50	ug/l							
Trichlorotrifluoroethane (Freon 113)	ND	5.0	ug/l							
Vinyl chloride	ND	0.50	ug/l							
Xylenes, Total	ND	1.5	ug/l							
<i>Surrogate: 4-Bromofluorobenzene</i>	21.9		ug/l	25.0		88	80-120			
<i>Surrogate: Dibromofluoromethane</i>	22.9		ug/l	25.0		92	80-120			
<i>Surrogate: Toluene-d8</i>	26.0		ug/l	25.0		104	80-120			
LCS Analyzed: 12/23/2010 (10L2794-BS1)										
Benzene	25.2	0.50	ug/l	25.0		101	70-120			
Carbon tetrachloride	25.6	0.50	ug/l	25.0		102	65-140			
Chloroform	23.0	0.50	ug/l	25.0		92	70-130			
1,1-Dichloroethane	24.8	0.50	ug/l	25.0		99	70-125			
1,2-Dichloroethane	24.8	0.50	ug/l	25.0		99	60-140			
1,1-Dichloroethene	24.8	0.50	ug/l	25.0		99	70-125			
Ethylbenzene	26.2	0.50	ug/l	25.0		105	75-125			
Tetrachloroethene	25.6	0.50	ug/l	25.0		102	70-125			
Toluene	26.5	0.50	ug/l	25.0		106	70-120			
1,1,1-Trichloroethane	26.0	0.50	ug/l	25.0		104	65-135			
1,1,2-Trichloroethane	25.7	0.50	ug/l	25.0		103	70-125			
Trichloroethene	24.3	0.50	ug/l	25.0		97	70-125			
Trichlorofluoromethane	25.6	0.50	ug/l	25.0		102	65-145			
Vinyl chloride	20.5	0.50	ug/l	25.0		82	55-135			
Xylenes, Total	84.9	1.5	ug/l	75.0		113	70-125			

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2794 Extracted: 12/23/10										
LCS Analyzed: 12/23/2010 (10L2794-BS1)										
Surrogate: 4-Bromofluorobenzene	24.4		ug/l	25.0		98	80-120			
Surrogate: Dibromofluoromethane	23.6		ug/l	25.0		95	80-120			
Surrogate: Toluene-d8	26.3		ug/l	25.0		105	80-120			
Matrix Spike Analyzed: 12/23/2010 (10L2794-MS1)					Source: ITL1714-01					
Benzene	23.3	0.50	ug/l	25.0	ND	93	65-125			
Carbon tetrachloride	23.9	0.50	ug/l	25.0	ND	96	65-140			
Chloroform	22.4	0.50	ug/l	25.0	ND	90	65-135			
1,1-Dichloroethane	24.0	0.50	ug/l	25.0	ND	96	65-130			
1,2-Dichloroethane	23.3	0.50	ug/l	25.0	ND	93	60-140			
1,1-Dichloroethene	25.4	0.50	ug/l	25.0	ND	102	60-130			
Ethylbenzene	25.4	0.50	ug/l	25.0	ND	102	65-130			
Tetrachloroethene	23.6	0.50	ug/l	25.0	ND	95	65-130			
Toluene	25.1	0.50	ug/l	25.0	ND	100	70-125			
1,1,1-Trichloroethane	25.0	0.50	ug/l	25.0	ND	100	65-140			
1,1,2-Trichloroethane	23.5	0.50	ug/l	25.0	ND	94	65-130			
Trichloroethene	41.3	0.50	ug/l	25.0	ND	165	65-125			MI
Trichlorofluoromethane	25.9	0.50	ug/l	25.0	ND	104	60-145			
Vinyl chloride	21.0	0.50	ug/l	25.0	ND	84	45-140			
Xylenes, Total	81.4	1.5	ug/l	75.0	ND	109	60-130			
Surrogate: 4-Bromofluorobenzene	25.1		ug/l	25.0		100	80-120			
Surrogate: Dibromofluoromethane	9.88		ug/l	25.0		40	80-120			Z
Surrogate: Toluene-d8	26.3		ug/l	25.0		105	80-120			
Matrix Spike Dup Analyzed: 12/23/2010 (10L2794-MSD1)					Source: ITL1714-01					
Benzene	22.7	0.50	ug/l	25.0	ND	91	65-125	3	20	
Carbon tetrachloride	23.0	0.50	ug/l	25.0	ND	92	65-140	4	25	
Chloroform	21.4	0.50	ug/l	25.0	ND	86	65-135	5	20	
1,1-Dichloroethane	23.1	0.50	ug/l	25.0	ND	92	65-130	4	20	
1,2-Dichloroethane	23.0	0.50	ug/l	25.0	ND	92	60-140	0.9	20	
1,1-Dichloroethene	25.1	0.50	ug/l	25.0	ND	101	60-130	1	20	
Ethylbenzene	24.1	0.50	ug/l	25.0	ND	96	65-130	5	20	
Tetrachloroethene	23.1	0.50	ug/l	25.0	ND	92	65-130	2	20	
Toluene	24.4	0.50	ug/l	25.0	ND	98	70-125	3	20	
1,1,1-Trichloroethane	23.4	0.50	ug/l	25.0	ND	94	65-140	7	20	
1,1,2-Trichloroethane	22.5	0.50	ug/l	25.0	ND	90	65-130	4	25	
Trichloroethene	40.4	0.50	ug/l	25.0	ND	162	65-125	2	20	MI

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

PURGEABLES BY GC/MS (EPA 624)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2794 Extracted: 12/23/10										
Matrix Spike Dup Analyzed: 12/23/2010 (10L2794-MSD1)					Source: ITL1714-01					
Trichlorofluoromethane	24.9	0.50	ug/l	25.0	ND	100	60-145	4	25	
Vinyl chloride	19.9	0.50	ug/l	25.0	ND	80	45-140	5	30	
Xylenes, Total	77.5	1.5	ug/l	75.0	ND	103	60-130	5	20	
Surrogate: 4-Bromofluorobenzene	24.7		ug/l	25.0		99	80-120			
Surrogate: Dibromofluoromethane	6.98		ug/l	25.0		28	80-120			Z
Surrogate: Toluene-d8	26.2		ug/l	25.0		105	80-120			

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

ACID & BASE/NEUTRALS BY GC/MS (EPA 625)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2492 Extracted: 12/21/10										
Blank Analyzed: 12/23/2010 (10L2492-BLK1)										
Bis(2-ethylhexyl)phthalate	ND	5.00	ug/l							
2,4-Dinitrotoluene	ND	5.00	ug/l							
N-Nitrosodimethylamine	ND	5.00	ug/l							
Pentachlorophenol	ND	5.00	ug/l							
2,4,6-Trichlorophenol	ND	6.00	ug/l							
Surrogate: 2,4,6-Tribromophenol	17.8		ug/l	20.0		89	40-120			
Surrogate: 2-Fluorobiphenyl	9.22		ug/l	10.0		92	50-120			
Surrogate: 2-Fluorophenol	13.4		ug/l	20.0		67	30-120			
Surrogate: Nitrobenzene-d5	7.36		ug/l	10.0		74	45-120			
Surrogate: Phenol-d6	14.7		ug/l	20.0		74	35-120			
Surrogate: Terphenyl-d14	8.88		ug/l	10.0		89	50-125			
LCS Analyzed: 12/23/2010 (10L2492-BS1)										
Bis(2-ethylhexyl)phthalate	8.72	5.00	ug/l	10.0		87	65-130			MNR1
2,4-Dinitrotoluene	8.20	5.00	ug/l	10.0		82	65-120			
N-Nitrosodimethylamine	6.74	5.00	ug/l	10.0		67	45-120			
Pentachlorophenol	5.34	5.00	ug/l	10.0		53	24-121			
2,4,6-Trichlorophenol	8.30	6.00	ug/l	10.0		83	55-120			
Surrogate: 2,4,6-Tribromophenol	17.5		ug/l	20.0		87	40-120			
Surrogate: 2-Fluorobiphenyl	7.76		ug/l	10.0		78	50-120			
Surrogate: 2-Fluorophenol	12.6		ug/l	20.0		63	30-120			
Surrogate: Nitrobenzene-d5	7.04		ug/l	10.0		70	45-120			
Surrogate: Phenol-d6	14.2		ug/l	20.0		71	35-120			
Surrogate: Terphenyl-d14	8.36		ug/l	10.0		84	50-125			
LCS Dup Analyzed: 12/23/2010 (10L2492-BSD1)										
Bis(2-ethylhexyl)phthalate	8.88	5.00	ug/l	10.0		89	65-130	2	20	
2,4-Dinitrotoluene	7.82	5.00	ug/l	10.0		78	65-120	5	20	
N-Nitrosodimethylamine	6.80	5.00	ug/l	10.0		68	45-120	0.9	20	
Pentachlorophenol	5.10	5.00	ug/l	10.0		51	24-121	5	25	
2,4,6-Trichlorophenol	8.46	6.00	ug/l	10.0		85	55-120	2	30	
Surrogate: 2,4,6-Tribromophenol	17.6		ug/l	20.0		88	40-120			
Surrogate: 2-Fluorobiphenyl	8.06		ug/l	10.0		81	50-120			
Surrogate: 2-Fluorophenol	12.6		ug/l	20.0		63	30-120			
Surrogate: Nitrobenzene-d5	7.24		ug/l	10.0		72	45-120			
Surrogate: Phenol-d6	14.5		ug/l	20.0		72	35-120			
Surrogate: Terphenyl-d14	8.46		ug/l	10.0		85	50-125			

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

ORGANOCHLORINE PESTICIDES (EPA 608)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2628 Extracted: 12/22/10										
Blank Analyzed: 12/22/2010 (10L2628-BLK1)										
alpha-BHC	ND	0.010	ug/l							
Surrogate: Decachlorobiphenyl	0.440		ug/l	0.500		88	45-120			
Surrogate: Tetrachloro-m-xylene	0.401		ug/l	0.500		80	35-115			
LCS Analyzed: 12/22/2010 (10L2628-BS1)										
alpha-BHC	0.460	0.010	ug/l	0.500		92	45-115			
Surrogate: Decachlorobiphenyl	0.448		ug/l	0.500		90	45-120			
Surrogate: Tetrachloro-m-xylene	0.416		ug/l	0.500		83	35-115			
Matrix Spike Analyzed: 12/22/2010 (10L2628-MS1)					Source: ITL1847-01					
alpha-BHC	0.310	0.0094	ug/l	0.472	ND	66	40-120			
Surrogate: Decachlorobiphenyl	0.387		ug/l	0.472		82	45-120			
Surrogate: Tetrachloro-m-xylene	0.212		ug/l	0.472		45	35-115			
Matrix Spike Dup Analyzed: 12/22/2010 (10L2628-MSD1)					Source: ITL1847-01					
alpha-BHC	0.342	0.0094	ug/l	0.472	ND	73	40-120	10	30	
Surrogate: Decachlorobiphenyl	0.436		ug/l	0.472		92	45-120			
Surrogate: Tetrachloro-m-xylene	0.233		ug/l	0.472		49	35-115			

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

HEXANE EXTRACTABLE MATERIAL

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2996 Extracted: 12/27/10										
Blank Analyzed: 12/28/2010 (10L2996-BLK1)										
Hexane Extractable Material (Oil & Grease)	ND	5.0	mg/l							
LCS Analyzed: 12/28/2010 (10L2996-BS1)										
Hexane Extractable Material (Oil & Grease)	18.2	5.0	mg/l	20.0		91	78-114			MNR1
LCS Dup Analyzed: 12/28/2010 (10L2996-BSD1)										
Hexane Extractable Material (Oil & Grease)	18.0	5.0	mg/l	20.0		90	78-114	1	11	

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2645 Extracted: 12/22/10										
Blank Analyzed: 12/22/2010-12/23/2010 (10L2645-BLK1)										
Cadmium	ND	1.0	ug/l							
Copper	ND	2.00	ug/l							
Lead	ND	1.0	ug/l							
Manganese	ND	1.0	ug/l							
Selenium	ND	2.0	ug/l							
LCS Analyzed: 12/22/2010-12/23/2010 (10L2645-BS1)										
Cadmium	77.2	1.0	ug/l	80.0		97	85-115			
Copper	84.1	2.00	ug/l	80.0		105	85-115			
Lead	82.5	1.0	ug/l	80.0		103	85-115			
Manganese	76.2	1.0	ug/l	80.0		95	85-115			
Selenium	77.2	2.0	ug/l	80.0		97	85-115			
Matrix Spike Analyzed: 12/22/2010-12/23/2010 (10L2645-MS1) Source: ITL2015-02										
Cadmium	72.7	1.0	ug/l	80.0	ND	91	70-130			
Copper	69.7	2.00	ug/l	80.0	2.55	84	70-130			
Lead	83.3	1.0	ug/l	80.0	1.61	102	70-130			
Manganese	102	1.0	ug/l	80.0	28.6	91	70-130			
Selenium	73.0	2.0	ug/l	80.0	ND	91	70-130			
Matrix Spike Analyzed: 12/22/2010-12/23/2010 (10L2645-MS2) Source: ITL2014-03										
Cadmium	71.7	1.0	ug/l	80.0	0.123	89	70-130			
Copper	76.5	2.00	ug/l	80.0	4.10	90	70-130			
Lead	85.5	1.0	ug/l	80.0	1.82	105	70-130			
Manganese	115	1.0	ug/l	80.0	45.4	87	70-130			
Selenium	73.4	2.0	ug/l	80.0	ND	92	70-130			
Matrix Spike Dup Analyzed: 12/22/2010-12/23/2010 (10L2645-MSD1) Source: ITL2015-02										
Cadmium	74.0	1.0	ug/l	80.0	ND	93	70-130	2	20	
Copper	69.9	2.00	ug/l	80.0	2.55	84	70-130	0.4	20	
Lead	83.6	1.0	ug/l	80.0	1.61	102	70-130	0.4	20	
Manganese	102	1.0	ug/l	80.0	28.6	92	70-130	0.7	20	
Selenium	74.5	2.0	ug/l	80.0	ND	93	70-130	2	20	

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC %REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2687 Extracted: 12/22/10										
Blank Analyzed: 12/23/2010 (10L2687-BLK1)										
Iron	ND	0.040	mg/l							
Zinc	ND	20.0	ug/l							
LCS Analyzed: 12/23/2010 (10L2687-BS1)										
Iron	0.495	0.040	mg/l	0.500		99	85-115			
Zinc	499	20.0	ug/l	500		100	85-115			
Matrix Spike Analyzed: 12/23/2010 (10L2687-MS1) Source: ITL1987-01										
Iron	0.496	0.040	mg/l	0.500	ND	99	70-130			
Zinc	484	20.0	ug/l	500	ND	97	70-130			
Matrix Spike Analyzed: 12/23/2010 (10L2687-MS2) Source: ITL1989-04										
Iron	0.505	0.040	mg/l	0.500	ND	101	70-130			
Zinc	486	20.0	ug/l	500	ND	97	70-130			
Matrix Spike Dup Analyzed: 12/23/2010 (10L2687-MSD1) Source: ITL1987-01										
Iron	0.501	0.040	mg/l	0.500	ND	100	70-130	1	20	
Zinc	500	20.0	ug/l	500	ND	100	70-130	3	20	
Batch: 10L3104 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3104-BLK1)										
Mercury	ND	0.20	ug/l							
LCS Analyzed: 12/28/2010 (10L3104-BS1)										
Mercury	8.00	0.20	ug/l	8.00		100	85-115			

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L3104 Extracted: 12/28/10										
Matrix Spike Analyzed: 12/28/2010 (10L3104-MS1)					Source: ITL2014-03					
Mercury	7.68	0.20	ug/l	8.00	ND	96	70-130			
Matrix Spike Dup Analyzed: 12/28/2010 (10L3104-MSD1)					Source: ITL2014-03					
Mercury	7.81	0.20	ug/l	8.00	ND	98	70-130	2	20	

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

DISSOLVED METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2799 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2799-BLK1)										
Iron	ND	0.040	mg/l							
Zinc	ND	20.0	ug/l							
LCS Analyzed: 12/23/2010 (10L2799-BS1)										
Iron	0.489	0.040	mg/l	0.500		98	85-115			
Zinc	495	20.0	ug/l	500		99	85-115			
Matrix Spike Analyzed: 12/23/2010 (10L2799-MS1) Source: ITL2014-03										
Iron	0.541	0.040	mg/l	0.500	0.0159	105	70-130			
Zinc	514	20.0	ug/l	500	8.05	101	70-130			
Matrix Spike Dup Analyzed: 12/23/2010 (10L2799-MSD1) Source: ITL2014-03										
Iron	0.532	0.040	mg/l	0.500	0.0159	103	70-130	2	20	
Zinc	501	20.0	ug/l	500	8.05	99	70-130	3	20	
Batch: 10L2800 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2800-BLK1)										
Cadmium	ND	1.0	ug/l							
Copper	ND	2.00	ug/l							
Lead	ND	1.0	ug/l							
Manganese	ND	1.0	ug/l							
Selenium	ND	2.0	ug/l							
LCS Analyzed: 12/23/2010 (10L2800-BS1)										
Cadmium	82.0	1.0	ug/l	80.0		103	85-115			
Copper	77.5	2.00	ug/l	80.0		97	85-115			
Lead	79.8	1.0	ug/l	80.0		100	85-115			
Manganese	81.1	1.0	ug/l	80.0		101	85-115			
Selenium	74.1	2.0	ug/l	80.0		93	85-115			

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

DISSOLVED METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2800 Extracted: 12/23/10										
Matrix Spike Analyzed: 12/23/2010 (10L2800-MS1)					Source: ITL2015-02					
Cadmium	80.2	1.0	ug/l	80.0	ND	100	70-130			
Copper	69.8	2.00	ug/l	80.0	0.969	86	70-130			
Lead	73.8	1.0	ug/l	80.0	ND	92	70-130			
Manganese	75.5	1.0	ug/l	80.0	2.30	91	70-130			
Selenium	74.3	2.0	ug/l	80.0	ND	93	70-130			
Matrix Spike Dup Analyzed: 12/23/2010 (10L2800-MSD1)					Source: ITL2015-02					
Cadmium	83.4	1.0	ug/l	80.0	ND	104	70-130	4	20	
Copper	71.9	2.00	ug/l	80.0	0.969	89	70-130	3	20	
Lead	77.1	1.0	ug/l	80.0	ND	96	70-130	4	20	
Manganese	78.5	1.0	ug/l	80.0	2.30	95	70-130	4	20	
Selenium	76.9	2.0	ug/l	80.0	ND	96	70-130	3	20	
Batch: 10L3103 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3103-BLK1)										
Mercury	ND	0.20	ug/l							
LCS Analyzed: 12/28/2010 (10L3103-BS1)										
Mercury	8.23	0.20	ug/l	8.00		103	85-115			
Matrix Spike Analyzed: 12/28/2010 (10L3103-MS1)					Source: ITL2014-03					
Mercury	8.27	0.20	ug/l	8.00	ND	103	70-130			
Matrix Spike Dup Analyzed: 12/28/2010 (10L3103-MSD1)					Source: ITL2014-03					
Mercury	8.19	0.20	ug/l	8.00	ND	102	70-130	0.9	20	

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2408 Extracted: 12/21/10										
Blank Analyzed: 12/21/2010 (10L2408-BLK1)										
Specific Conductance	ND	1.0	umhos/cm @ 25C							
LCS Analyzed: 12/21/2010 (10L2408-BS1)										
Specific Conductance	1430	1.0	umhos/cm @ 25C	1410		101	90-110			
Duplicate Analyzed: 12/21/2010 (10L2408-DUP1)										
Specific Conductance	116	1.0	umhos/cm @ 25C		115			0.8	5	
Source: ITL1890-01										
Batch: 10L2589 Extracted: 12/22/10										
Blank Analyzed: 12/22/2010 (10L2589-BLK1)										
Total Dissolved Solids	ND	10	mg/l							
LCS Analyzed: 12/22/2010 (10L2589-BS1)										
Total Dissolved Solids	996	10	mg/l	1000		100	90-110			
Duplicate Analyzed: 12/22/2010 (10L2589-DUP1)										
Total Dissolved Solids	3380	20	mg/l		3410			1	10	
Source: ITL2097-01										
Batch: 10L2625 Extracted: 12/22/10										
Blank Analyzed: 12/22/2010 (10L2625-BLK1)										
Chloride	ND	0.50	mg/l							
Nitrate-N	ND	0.11	mg/l							
Nitrite-N	ND	0.15	mg/l							
Nitrate/Nitrite-N	ND	0.26	mg/l							
Sulfate	ND	0.50	mg/l							

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2625 Extracted: 12/22/10										
LCS Analyzed: 12/22/2010 (10L2625-BS1)										
Chloride	4.64	0.50	mg/l	5.00		93	90-110			
Nitrate-N	1.11	0.11	mg/l	1.13		98	90-110			
Nitrite-N	1.49	0.15	mg/l	1.52		98	90-110			
Sulfate	9.73	0.50	mg/l	10.0		97	90-110			
Matrix Spike Analyzed: 12/22/2010 (10L2625-MS1)					Source: ITL2015-02					
Chloride	125	5.0	mg/l	50.0	78.6	94	80-120			
Nitrate-N	11.2	1.1	mg/l	11.3	0.420	95	80-120			
Nitrite-N	14.6	1.5	mg/l	15.2	ND	96	80-120			
Sulfate	114	5.0	mg/l	100	18.0	96	80-120			
Matrix Spike Dup Analyzed: 12/22/2010 (10L2625-MSD1)					Source: ITL2015-02					
Chloride	127	5.0	mg/l	50.0	78.6	98	80-120	2	20	
Nitrate-N	11.5	1.1	mg/l	11.3	0.420	98	80-120	3	20	
Nitrite-N	14.8	1.5	mg/l	15.2	ND	97	80-120	1	20	
Sulfate	115	5.0	mg/l	100	18.0	97	80-120	0.6	20	
Batch: 10L2657 Extracted: 12/22/10										
Blank Analyzed: 12/22/2010 (10L2657-BLK1)										
Turbidity	ND	1.0	NTU							
Duplicate Analyzed: 12/22/2010 (10L2657-DUP1)					Source: ITL2028-01					
Turbidity	87.5	5.0	NTU		87.0			0.6	20	
Duplicate Analyzed: 12/22/2010 (10L2657-DUP2)					Source: ITL2089-09					
Turbidity	12.6	1.0	NTU		12.6			0.2	20	

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2679 Extracted: 12/22/10										
Blank Analyzed: 12/22/2010 (10L2679-BLK1)										
Surfactants (MBAS)	ND	0.10	mg/l							
LCS Analyzed: 12/22/2010 (10L2679-BS1)										
Surfactants (MBAS)	0.253	0.10	mg/l	0.250		101	90-110			
Matrix Spike Analyzed: 12/22/2010 (10L2679-MS1)										
Surfactants (MBAS)	0.384	0.10	mg/l	0.250	0.120	105	50-125			
Matrix Spike Dup Analyzed: 12/22/2010 (10L2679-MSD1)										
Surfactants (MBAS)	0.381	0.10	mg/l	0.250	0.120	104	50-125	0.7	20	
Batch: 10L2704 Extracted: 12/22/10										
Blank Analyzed: 12/22/2010 (10L2704-BLK1)										
Total Cyanide	ND	5.0	ug/l							
LCS Analyzed: 12/22/2010 (10L2704-BS1)										
Total Cyanide	195	5.0	ug/l	200		98	90-110			
Matrix Spike Analyzed: 12/22/2010 (10L2704-MS1)										
Total Cyanide	144	5.0	ug/l	200	ND	72	70-115			
Matrix Spike Dup Analyzed: 12/22/2010 (10L2704-MSD1)										
Total Cyanide	143	5.0	ug/l	200	ND	72	70-115	0.5	15	
Batch: 10L2828 Extracted: 12/23/10										
Blank Analyzed: 12/28/2010 (10L2828-BLK1)										
Biochemical Oxygen Demand	ND	2.0	mg/l							

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2828 Extracted: 12/23/10										
LCS Analyzed: 12/28/2010 (10L2828-BS1)										
Biochemical Oxygen Demand	194	100	mg/l	198		98	85-115			
LCS Dup Analyzed: 12/28/2010 (10L2828-BSD1)										
Biochemical Oxygen Demand	204	100	mg/l	198		103	85-115	5	20	
Batch: 10L2850 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2850-BLK1)										
Total Suspended Solids	ND	10	mg/l							
LCS Analyzed: 12/23/2010 (10L2850-BS1)										
Total Suspended Solids	1000	10	mg/l	1000		100	85-115			
Duplicate Analyzed: 12/23/2010 (10L2850-DUP1)										
Total Suspended Solids	161	10	mg/l		160			0.6	10	
Batch: 10L2867 Extracted: 12/23/10										
Blank Analyzed: 12/23/2010 (10L2867-BLK1)										
Ammonia-N (Distilled)	ND	0.500	mg/l							
LCS Analyzed: 12/23/2010 (10L2867-BS1)										
Ammonia-N (Distilled)	9.80	0.500	mg/l	10.0		98	80-115			
Matrix Spike Analyzed: 12/23/2010 (10L2867-MS1)										
Ammonia-N (Distilled)	9.80	0.500	mg/l	10.0	ND	98	70-120			

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

INORGANICS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10L2867 Extracted: 12/23/10										
Matrix Spike Dup Analyzed: 12/23/2010 (10L2867-MSD1)					Source: ITL2014-03					
Ammonia-N (Distilled)	9.80	0.500	mg/l	10.0	ND	98	70-120	0	15	
Batch: 10L3015 Extracted: 12/28/10										
Blank Analyzed: 12/28/2010 (10L3015-BLK1)										
Perchlorate	ND	4.0	ug/l							
LCS Analyzed: 12/28/2010 (10L3015-BS1)										
Perchlorate	22.7	4.0	ug/l	25.0		91	85-115			
Matrix Spike Analyzed: 12/28/2010 (10L3015-MS1)					Source: ITL2014-03					
Perchlorate	23.1	4.0	ug/l	25.0	ND	92	80-120			
Matrix Spike Dup Analyzed: 12/28/2010 (10L3015-MSD1)					Source: ITL2014-03					
Perchlorate	23.7	4.0	ug/l	25.0	ND	95	80-120	3	20	

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

8647

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
<u>Batch: 8647 Extracted: 12/30/10</u>										
LCS Analyzed: 01/20/2011 (S012314-02)										
Uranium, Total	56.3	1	pCi/L	56.5		100	80-120			
Blank Analyzed: 01/20/2011 (S012314-03)										
Uranium, Total	0	1	pCi/L				-			U
Duplicate Analyzed: 01/20/2011 (S012314-04)										
Uranium, Total	0.245	1	pCi/L		0.237		-	3		Jb

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

900

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
<u>Batch: 8647 Extracted: 01/04/11</u>										
LCS Analyzed: 01/05/2011 (S012314-02)										
Gross Alpha	40.4	3	pCi/L	40.4		100	70-130			
Gross Beta	33.8	4	pCi/L	35		97	70-130			
Blank Analyzed: 01/05/2011 (S012314-03)										
Gross Alpha	-0.064	3	pCi/L							U
Gross Beta	-0.434	4	pCi/L							U
Duplicate Analyzed: 01/05/2011 (S012314-04)										
Gross Alpha	1.12	3	pCi/L		0.948			17		Jb
Gross Beta	4.03	4	pCi/L		4.3			6		

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

901.1

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
<u>Batch: 8647 Extracted: 12/30/10</u>										
LCS Analyzed: 01/06/2011 (S012314-02)										
Cobalt-60	103	10	pCi/L	102		101	80-120			
Cesium-137	118	20	pCi/L	110		107	80-120			
Blank Analyzed: 01/06/2011 (S012314-03)										
Cesium-137	ND	20	pCi/L				-			U
Potassium-40	ND	25	pCi/L				-			U
Duplicate Analyzed: 01/06/2011 (S012314-04)										
Cesium-137	ND	20	pCi/L		0		-	0		U
Potassium-40	ND	25	pCi/L		0		-	0		U

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

903.1

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
<u>Batch: 8647 Extracted: 01/21/11</u>										
LCS Analyzed: 01/21/2011 (S012314-02)										
Radium-226	61	1	pCi/L	55.7		110	80-120			
Blank Analyzed: 01/21/2011 (S012314-03)										
Radium-226	0.035	1	pCi/L				-			U
Duplicate Analyzed: 01/21/2011 (S012314-04)										
Radium-226	0.179	1	pCi/L		Source: ITL2014-03 0.312		-	0		U

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

904

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 8647 Extracted: 01/21/11										
LCS Analyzed: 01/21/2011 (S012314-02)										
Radium-228	5.39	1	pCi/L	4.63		116	60-140			
Blank Analyzed: 01/21/2011 (S012314-03)										
Radium-228	-0.175	1	pCi/L							U
Duplicate Analyzed: 01/21/2011 (S012314-04)										
Radium-228	0.01	1	pCi/L		0.125			0		U

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

905

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 8647 Extracted: 01/08/11										
LCS Analyzed: 01/13/2011 (S012314-02)										
Strontium-90	17.4	2	pCi/L	17.5		99	80-120			
Blank Analyzed: 01/13/2011 (S012314-03)										
Strontium-90	-0.069	2	pCi/L							U
Duplicate Analyzed: 01/13/2011 (S012314-04)										
Strontium-90	0.168	2	pCi/L		0.018			0		U

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

906

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 8647 Extracted: 01/13/11										
LCS Analyzed: 01/14/2011 (S012314-02)										
Tritium	2850	500	pCi/L	2550		112	80-120			
Blank Analyzed: 01/14/2011 (S012314-03)										
Tritium	107	500	pCi/L				-			U
Duplicate Analyzed: 01/14/2011 (S012314-04)										
Tritium	155	500	pCi/L		144		-	0		U

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

EPA-5 1613Bx

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 357431 Extracted: 12/23/10										
Blank Analyzed: 12/28/2010 (G0L230000431B)					Source:					
1,2,3,4,6,7,8-HpCDD	1.5e-006	0.00005	ug/L				-			J
1,2,3,4,6,7,8-HpCDF	9.5e-007	0.00005	ug/L				-			J, Q
1,2,3,4,7,8,9-HpCDF	9.6e-007	0.00005	ug/L				-			J, Q
1,2,3,4,7,8-HxCDD	ND	0.00005	ug/L				-			
1,2,3,4,7,8-HxCDF	ND	0.00005	ug/L				-			
1,2,3,6,7,8-HxCDD	ND	0.00005	ug/L				-			
1,2,3,6,7,8-HxCDF	ND	0.00005	ug/L				-			
1,2,3,7,8,9-HxCDD	ND	0.00005	ug/L				-			
1,2,3,7,8,9-HxCDF	ND	0.00005	ug/L				-			
1,2,3,7,8-PeCDD	ND	0.00005	ug/L				-			
1,2,3,7,8-PeCDF	ND	0.00005	ug/L				-			
2,3,4,6,7,8-HxCDF	ND	0.00005	ug/L				-			
2,3,4,7,8-PeCDF	ND	0.00005	ug/L				-			
2,3,7,8-TCDD	ND	0.00001	ug/L				-			
2,3,7,8-TCDF	ND	0.00001	ug/L				-			
OCDD	5.9e-006	0.0001	ug/L				-			J
OCDF	2e-006	0.0001	ug/L				-			J
Total HpCDD	2.5e-006	0.00005	ug/L				-			J
Total HpCDF	1.9e-006	0.00005	ug/L				-			J, Q
Total HxCDD	ND	0.00005	ug/L				-			
Total HxCDF	ND	0.00005	ug/L				-			
Total PeCDD	ND	0.00005	ug/L				-			
Total PeCDF	ND	0.00005	ug/L				-			
Total TCDD	ND	0.00001	ug/L				-			
Total TCDF	ND	0.00001	ug/L				-			
Surrogate: 13C-1,2,3,4,6,7,8-HpCDD	0.0021		ug/L	0.002		107	23-140			
Surrogate: 13C-1,2,3,4,6,7,8-HpCDF	0.0018		ug/L	0.002		92	28-143			
Surrogate: 13C-1,2,3,4,7,8,9-HpCDF	0.002		ug/L	0.002		100	26-138			
Surrogate: 13C-1,2,3,4,7,8-HxCDD	0.0017		ug/L	0.002		86	32-141			
Surrogate: 13C-1,2,3,4,7,8-HxCDF	0.0016		ug/L	0.002		81	26-152			
Surrogate: 13C-1,2,3,6,7,8-HxCDD	0.002		ug/L	0.002		98	28-130			
Surrogate: 13C-1,2,3,6,7,8-HxCDF	0.0016		ug/L	0.002		83	26-123			
Surrogate: 13C-1,2,3,7,8,9-HxCDF	0.0016		ug/L	0.002		81	29-147			
Surrogate: 13C-1,2,3,7,8-PeCDD	0.0018		ug/L	0.002		91	25-181			
Surrogate: 13C-1,2,3,7,8-PeCDF	0.0018		ug/L	0.002		92	24-185			
Surrogate: 13C-2,3,4,6,7,8-HxCDF	0.0017		ug/L	0.002		85	28-136			

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

METHOD BLANK/QC DATA

EPA-5 1613Bx

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 357431 Extracted: 12/23/10										
Blank Analyzed: 12/28/2010 (G0L230000431B)					Source:					
Surrogate: 13C-2,3,4,7,8-PeCDF	0.0018		ug/L	0.002		89	21-178			
Surrogate: 13C-2,3,7,8-TCDD	0.0017		ug/L	0.002		83	25-164			
Surrogate: 13C-2,3,7,8-TCDF	0.0015		ug/L	0.002		77	24-169			
Surrogate: 13C-OCDD	0.0036		ug/L	0.004		90	17-157			
Surrogate: 37Cl4-2,3,7,8-TCDD	0.0008		ug/L	0.0008		99	35-197			
LCS Analyzed: 12/28/2010 (G0L230000431C)					Source:					
1,2,3,4,6,7,8-HpCDD	0.00102	0.00005	ug/L	0.001		102	70-140			B
1,2,3,4,6,7,8-HpCDF	0.00109	0.00005	ug/L	0.001		109	82-122			B
1,2,3,4,7,8,9-HpCDF	0.00108	0.00005	ug/L	0.001		108	78-138			B
1,2,3,4,7,8-HxCDD	0.00118	0.00005	ug/L	0.001		118	70-164			
1,2,3,4,7,8-HxCDF	0.00102	0.00005	ug/L	0.001		102	72-134			
1,2,3,6,7,8-HxCDD	0.000981	0.00005	ug/L	0.001		98	76-134			
1,2,3,6,7,8-HxCDF	0.00105	0.00005	ug/L	0.001		105	84-130			
1,2,3,7,8,9-HxCDD	0.00108	0.00005	ug/L	0.001		108	64-162			
1,2,3,7,8,9-HxCDF	0.00108	0.00005	ug/L	0.001		108	78-130			
1,2,3,7,8-PeCDD	0.00109	0.00005	ug/L	0.001		109	70-142			
1,2,3,7,8-PeCDF	0.000975	0.00005	ug/L	0.001		98	80-134			
2,3,4,6,7,8-HxCDF	0.00103	0.00005	ug/L	0.001		103	70-156			
2,3,4,7,8-PeCDF	0.000976	0.00005	ug/L	0.001		98	68-160			
2,3,7,8-TCDD	0.000214	0.00001	ug/L	0.0002		107	67-158			
2,3,7,8-TCDF	0.000186	0.00001	ug/L	0.0002		93	75-158			
OCDD	0.00191	0.0001	ug/L	0.002		96	78-144			B
OCDF	0.00182	0.0001	ug/L	0.002		91	63-170			B
Surrogate: 13C-1,2,3,4,6,7,8-HpCDD	0.00221		ug/L	0.002		111	26-166			
Surrogate: 13C-1,2,3,4,6,7,8-HpCDF	0.00194		ug/L	0.002		97	21-158			
Surrogate: 13C-1,2,3,4,7,8,9-HpCDF	0.00207		ug/L	0.002		104	20-186			
Surrogate: 13C-1,2,3,4,7,8-HxCDD	0.00166		ug/L	0.002		83	21-193			
Surrogate: 13C-1,2,3,4,7,8-HxCDF	0.00162		ug/L	0.002		81	19-202			
Surrogate: 13C-1,2,3,6,7,8-HxCDD	0.00201		ug/L	0.002		100	25-163			
Surrogate: 13C-1,2,3,6,7,8-HxCDF	0.00168		ug/L	0.002		84	21-159			
Surrogate: 13C-1,2,3,7,8,9-HxCDF	0.0016		ug/L	0.002		80	17-205			
Surrogate: 13C-1,2,3,7,8-PeCDD	0.00181		ug/L	0.002		91	21-227			
Surrogate: 13C-1,2,3,7,8-PeCDF	0.00187		ug/L	0.002		93	21-192			
Surrogate: 13C-2,3,4,6,7,8-HxCDF	0.00169		ug/L	0.002		85	22-176			
Surrogate: 13C-2,3,4,7,8-PeCDF	0.00177		ug/L	0.002		89	13-328			

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

METHOD BLANK/QC DATA

EPA-5 1613Bx

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 357431 Extracted: 12/23/10										
LCS Analyzed: 12/28/2010 (G0L230000431C)										
Surrogate: 13C-2,3,7,8-TCDD	0.00171		ug/L	0.002		85	20-175			
Surrogate: 13C-2,3,7,8-TCDF	0.00157		ug/L	0.002		79	22-152			
Surrogate: 13C-OCDD	0.00374		ug/L	0.004		94	13-199			
Surrogate: 37Cl4-2,3,7,8-TCDD	0.000784		ug/L	0.0008		98	31-191			

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits appear in bold on this page.

LabNumber	Analysis	Analyte	Units	Result	MRL	Compliance Limit
ITL2014-01	1664-HEM	Hexane Extractable Material (Oil & Greas	mg/l	0	4.7	15
ITL2014-01	624-Boeing 001/002Q (Fr113+X+Fr1,1-Dichloroethene		ug/l	0	0.50	6
ITL2014-01	624-Boeing 001/002Q (Fr113+X+FrTrichloroethene		ug/l	0	0.50	5
ITL2014-01	Settleable Solids - SM2540F	Total Settleable Solids	ml/l	0	0.10	0.3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits appear in bold on this page.

LabNumber	Analysis	Analyte	Units	Result	MRL	Compliance Limit
ITL2014-02	624-Boeing 001/002Q (Fr113+X+Fr1,1-Dichloroethene		ug/l	0	0.50	6
ITL2014-02	624-Boeing 001/002Q (Fr113+X+FrTrichloroethene		ug/l	0	0.50	5

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits appear in bold on this page.

LabNumber	Analysis	Analyte	Units	Result	MRL	Compliance Limit
ITL2014-03	608-Pest Boeing 001/002 Q (LL)	alpha-BHC	ug/l	0	0.0094	0.03
ITL2014-03	625-Boeing 001/002 Q-LL	2,4,6-Trichlorophenol	ug/l	0	5.66	13
ITL2014-03	625-Boeing 001/002 Q-LL	2,4-Dinitrotoluene	ug/l	0	4.72	18
ITL2014-03	625-Boeing 001/002 Q-LL	Bis(2-ethylhexyl)phthalate	ug/l	0.34	4.72	4
ITL2014-03	625-Boeing 001/002 Q-LL	N-Nitrosodimethylamine	ug/l	0	4.72	16
ITL2014-03	625-Boeing 001/002 Q-LL	Pentachlorophenol	ug/l	0	4.72	16.5
ITL2014-03	Ammonia-N, Titr 4500NH3-C (w/di:Ammonia-N (Distilled)		mg/l	0	0.500	10.1
ITL2014-03	BOD - SM5210B	Biochemical Oxygen Demand	mg/l	1.77	2.0	30
ITL2014-03	Cadmium-200.8	Cadmium	ug/l	0.12	1.0	3.1
ITL2014-03	Chloride - 300.0	Chloride	mg/l	6.90	0.50	150
ITL2014-03	Copper-200.8	Copper	ug/l	4.10	2.00	14
ITL2014-03	Cyanide, Total-4500CN-E (5ppb)	Total Cyanide	ug/l	-1	5.0	8.5
ITL2014-03	Iron-200.7	Iron	mg/l	2.29	0.040	0.3
ITL2014-03	Lead-200.8	Lead	ug/l	1.82	1.0	5.2
ITL2014-03	MBAS - SM5540C	Surfactants (MBAS)	mg/l	0.029	0.10	0.5
ITL2014-03	Mercury - 245.1	Mercury	ug/l	0	0.20	0.1
ITL2014-03	Nitrate-N, 300.0	Nitrate-N	mg/l	1.01	0.11	8
ITL2014-03	Nitrite-N, 300.0	Nitrite-N	mg/l	0	0.15	1
ITL2014-03	Nitrogen, NO3+NO2 -N EPA 300.0	Nitrate/Nitrite-N	mg/l	1.01	0.26	8

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

ITL2014-03	Perchlorate 314.0 - Default	Perchlorate	ug/l	0	4.0	6
ITL2014-03	Selenium-200.8	Selenium	ug/l	0.19	2.0	5
ITL2014-03	Sulfate-300.0	Sulfate	mg/l	38	0.50	300
ITL2014-03	TDS - SM2540C	Total Dissolved Solids	mg/l	112	10	950
ITL2014-03	TSS - SM2540D	Total Suspended Solids	mg/l	22	10	45
ITL2014-03	Zinc-200.7	Zinc	ug/l	19	20.0	119

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

DATA QUALIFIERS AND DEFINITIONS

- B** Method blank contamination. The associated method blank contains the target analyte at a reportable level.
- J** Estimated value. Analyte detected at a level less than the Reporting Limit (RL) and greater than or equal to the Method Detection Limit (MDL). The user of this data should be aware that this data is of limited reliability.
- Jb** The RESULT is less than the RDL (Required Detection Limit) and no U qualifier is assigned.
- MI** The MS and/or MSD were above the acceptance limits due to sample matrix interference. See Blank Spike (LCS).
- MNR1** There was no MS/MSD analyzed with this batch due to insufficient sample volume. See Blank Spike/Blank Spike Duplicate.
- Q** Estimated maximum possible concentration (EMPC).
- U** The RESULT is less than the MDA (Minimum Detectable Activity). If the MDA is blank, the ERROR is used as the limit.
- Z** Due to sample matrix effects, the surrogate recovery was below the acceptance limits.
- ND** Analyte NOT DETECTED at or above the reporting limit or MDL, if MDL is specified.
- RPD** Relative Percent Difference

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
 Quarterly Outfall 018
 Report Number: ITL2014

Sampled: 12/20/10-12/21/10
 Received: 12/20/10

Certification Summary

TestAmerica Irvine

Method	Matrix	Nelac	California
EPA 120.1	Water	X	X
EPA 1664A	Water	X	X
EPA 180.1	Water	X	X
EPA 200.7-Diss	Water	X	X
EPA 200.7	Water	X	X
EPA 200.8-Diss	Water	X	X
EPA 200.8	Water	X	X
EPA 245.1-Diss	Water	X	X
EPA 245.1	Water	X	X
EPA 300.0	Water	X	X
EPA 314.0	Water	X	X
EPA 608	Water	X	X
EPA 624	Water	X	X
EPA 625	Water	X	X
Filtration	Water	N/A	N/A
SM 2540D	Water	X	X
SM2540C	Water	X	
SM2540F	Water	X	X
SM4500CN-E	Water	X	X
SM4500NH3-C	Water	X	X
SM5210B	Water	X	X
SM5540-C	Water	X	X

Nevada and NELAP provide analyte specific accreditations. Analyte specific information for TestAmerica may be obtained by contacting the laboratory or visiting our website at www.testamericainc.com

Subcontracted Laboratories

Aquatic Testing Laboratories-SUB *California Cert #1775*

4350 Transport Street, Unit 107 - Ventura, CA 93003

Analysis Performed: Bioassay-7 dy Chrmc

Samples: ITL2014-03

TestAmerica Irvine

Heather Clark For Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

Eberline Services - SUB

2030 Wright Avenue - Richmond, CA 94804

Analysis Performed: Gamma Spec
Samples: ITL2014-03

Analysis Performed: Gross Alpha
Samples: ITL2014-03

Analysis Performed: Gross Beta
Samples: ITL2014-03

Analysis Performed: Radium, Combined
Samples: ITL2014-03

Analysis Performed: Strontium 90
Samples: ITL2014-03

Analysis Performed: Tritium
Samples: ITL2014-03

Analysis Performed: Uranium, Combined
Samples: ITL2014-03

TestAmerica Buffalo

10 Hazelwood Drive, Suite 106 - Amherst, NY 14228

Method Performed: 8647
Samples: ITL2014-03

Method Performed: 900
Samples: ITL2014-03

Method Performed: 901.1
Samples: ITL2014-03

Method Performed: 903.1
Samples: ITL2014-03

Method Performed: 904
Samples: ITL2014-03

Method Performed: 905
Samples: ITL2014-03

Method Performed: 906
Samples: ITL2014-03

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quarterly Outfall 018 2010
Quarterly Outfall 018
Report Number: ITL2014

Sampled: 12/20/10-12/21/10
Received: 12/20/10

TestAmerica West Sacramento *NELAC Cert #1119CA, Nevada Cert #CA44*

880 Riverside Parkway - West Sacramento, CA 95605

Method Performed: EPA-5 1613B
Samples: ITL2014-03

TestAmerica Irvine

Heather Clark For Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

ITL2014 <Page 52 of 52>



EBERLINE SERVICES

EBERLINE ANALYTICAL CORPORATION
2030 Wright Avenue
Richmond, California 94804-3849
Phone (510) 235-2633 Fax (510) 235-0438
Toll Free (800) 841-5487
www.eberlineservices.com

January 28, 2011

Ms. Debby Wilson
Test America Irvine
17461 Derian Ave., Ste. 100
Irvine, CA 92614

**Reference: Test America-Irvine ITL2014
Eberline Analytical Report S012314-8647
Sample Delivery Group 8647**

Dear Ms. Wilson:

Enclosed is a Level IV CLP-like data package (on CD) for one water sample received under Test America Job No. ITL2014. The sample was received on December 23, 2010.

Please call me, if you have any questions concerning the enclosed report.

Sincerely,

N. Joseph Verville
Client Services Manager

NJV/ljb

Enclosure: Level IV CLP-like Data Package CD

1.0 General Comments

Sample delivery group 8647 consists of the analytical results and supporting documentation for one water sample. Sample ID's and reference dates/times are given in the Sample Summary section of the Summary Data report. The sample was received as stated on the chain-of-custody document. Any discrepancies are noted on the Eberline Analytical Sample Receipt Checklist. No holding times were exceeded.

Tritium and gamma analyses were performed on the sample as received i.e. the sample was not filtered. The analytical volumes for all other analyses were subjected to a full nitric acid/hydrofluoric acid dissolution, and analyses were performed on the dissolution volume.

2.0 Quality Control

Quality Control Samples consisted of laboratory control samples (LCS), method blanks, duplicate analyses and matrix spike analyses. Included in the data package are copies of the Eberline Analytical radiometrics data sheets. The radiometrics data sheets for the QC LCS and QC blank samples indicate Eberline Analytical's standard QC aliquot of 1.0 sample; results for those QC types are calculated as pCi/sample. The QC LCS and QC blank sample results reported in the Summary Data Section have been divided by the appropriate method specific aliquot (see the Lab Method Summaries for specific aliquots) in order to make the results comparable to the field sample results. All QC sample results were within required control limits.

3.0 Method Errors

The error for each result is an estimate of the significant random uncertainties incurred in the measurement process. These are propagated to each final result. They include the counting (Poisson) uncertainty, as well as those intrinsic errors due to carrier or tracer standardization, aliquoting, counter efficiencies, weights, or volumes. The following method errors were propagated to the count error to calculate the 2σ error (Total):

Analysis	Method Error
Gross alpha	20.6%
Gross beta	11.0%
Tritium	10.0%
Sr-90	10.4%
Ra-226	16.4%
Ra-228	10.4%
Uranium, Total	
Gamma Spec.	7.0%

4.0 Analysis Notes

- 4.1 **Gross Alpha/Gross Beta Analysis** – No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.2 **Tritium Analysis** – No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.3 **Strontium-90 Analysis** - No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.4 **Radium-226 Analysis** - No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.5 **Radium-228 Analysis** - No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.6 **Total Uranium Analysis** - No problems were encountered during the processing of the samples. All quality control sample results were within required control limits.
- 4.7 **Gamma Spectroscopy** – The K-40 MDA for the QC blank sample was 54.4 pCi/L, greater than the required detection limit of 25 pCi/L., due to an elevated K40 background in the ROI for K40 on the detector used for the QC blank. No other problems were encountered during the processing of the samples. All other quality control sample results were within required control limits.

5.0 Case Narrative Certification Statement

“I certify that this data package is in compliance with the SOW, both technically and for completeness, for other than the conditions detailed above. Release of the data obtained in this hard copy data package has been authorized by the Laboratory Manager or a designee, as verified by the following signature.”



N. Joseph Verville
Client Services Manager

1/28/11

Date

EBERLINE ANALYTICAL
SDG 8647

SDG 8647
Contact N. Joseph Verville

Client Test America, Inc.
Contract ITL2014

S U M M A R Y D A T A S E C T I O N

T A B L E O F C O N T E N T S				
About this section	.	.	.	1
Sample Summaries	.	.	.	3
Prep Batch Summary	.	.	.	5
Work Summary	.	.	.	6
Method Blanks	.	.	.	8
Lab Control Samples	.	.	.	9
Duplicates	.	.	.	10
Data Sheets	.	.	.	11
Method Summaries	.	.	.	12
Report Guides	.	.	.	20
End of Section	.	.	.	34

UB
Prepared by _____

Reviewed by *N. Joseph Verville*

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-TOC
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2014

ABOUT THE DATA SUMMARY SECTION

The Data Summary Section of a Data Package has all data, in several useful orders, necessary for first level, routine review of the data package for a Sample Delivery Group (SDG). This section follows the Data Package Narrative, which has an overview of the data package and a discussion of special problems. It is followed by the Raw Data Section, which has full details.

The Data Summary Section has several groups of reports:

SAMPLE SUMMARIES

The Sample and QC Summary Reports show all samples, including QC samples, reported in one SDG. These reports cross-reference client and lab sample identifiers.

PREPARATION BATCH SUMMARY

The Preparation Batch Summary Report shows all preparation batches (lab groupings reflecting how work was organized) relevant to the reported SDG with information necessary to check the completeness and consistency of the SDG.

WORK SUMMARY

The Work Summary Report shows all samples and work done on them relevant to the reported SDG.

METHOD BLANKS

The Method Blank Reports, one for each Method Blank relevant to the SDG, show all results and primary supporting information for the blanks.

LAB CONTROL SAMPLES

The Lab Control Sample Reports, one for each Lab Control Sample relevant to the SDG, show all results, recoveries and primary supporting information for these QC samples.

DUPLICATES

REPORT GUIDES

Page 1

SUMMARY DATA SECTION

Page 1

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2014

ABOUT THE DATA SUMMARY SECTION

The Duplicate Reports, one for each Duplicate and Original sample pair relevant to the SDG, show all results, differences and primary supporting information for these QC samples.

MATRIX SPIKES

The Matrix Spike Reports, one for each Spiked and Original sample pair relevant to the SDG, show all results, recoveries and primary supporting information for these QC samples.

DATA SHEETS

The Data Sheet Reports, one for each client sample in the SDG, show all results and primary supporting information for these samples.

METHOD SUMMARIES

The Method Summary Reports, one for each test used in the SDG, show all results, QC and method performance data for one analyte on one or two pages. (A test is a short code for the method used to do certain work to the client's specification.)

REPORT GUIDES

The Report Guides, one for each of the above groups of reports, have documentation on how to read the associated reports.

REPORT GUIDES

Page 2

SUMMARY DATA SECTION

Page 2

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

LAB SAMPLE SUMMARY

SDG 8647
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2014

LAB						CHAIN OF	
SAMPLE ID	CLIENT SAMPLE ID	LOCATION	MATRIX	LEVEL	SAS NO	CUSTODY	COLLECTED
S012314-01	ITL2014-03	Boeing-SSFL	WATER			ITL2014	12/21/10 10:17
S012314-02	Lab Control Sample		WATER				
S012314-03	Method Blank		WATER				
S012314-04	Duplicate (S012314-01)	Boeing-SSFL	WATER				12/21/10 10:17

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
 Contact N. Joseph Verville

QC SUMMARY

Client Test America, Inc.
 Contract ITL2014

QC BATCH	CHAIN OF CUSTODY	CLIENT SAMPLE ID	MATRIX	% MOIST	SAMPLE AMOUNT	BASIS AMOUNT	DAYS SINCE RECEIVED	LAB COLL	LAB SAMPLE ID	DEPARTMENT SAMPLE ID
8647	ITL2014	ITL2014-03	WATER		9.5 L		12/23/10 2	S012314-01		8647-001
		Method Blank	WATER					S012314-03		8647-003
		Lab Control Sample	WATER					S012314-02		8647-002
		Duplicate (S012314-01)	WATER		9.5 L		12/23/10 2	S012314-04		8647-004

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-QS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

PREP BATCH SUMMARY

Client Test America, Inc.
Contract ITL2014

TEST	MATRIX	METHOD	PREPARATION ERROR		PLANCHETS ANALYZED				QUALIFIERS
			BATCH	2σ %	CLIENT	MORE	RE BLANK	LCS	
Beta Counting									
AC	WATER	Radium-228 in Water	7258-160	10.4	1		1	1	1/1
SR	WATER	Strontium-90 in Water	7258-160	10.4	1		1	1	1/1
Gas Proportional Counting									
80A	WATER	Gross Alpha in Water	7258-160	20.6	1		1	1	1/1
80B	WATER	Gross Beta in Water	7258-160	11.0	1		1	1	1/1
Gamma Spectroscopy									
GAM	WATER	Gamma Emitters in Water	7258-160	7.0	1		1	1	1/1
Kinetic Phosphorimetry, ug									
U_T	WATER	Uranium, Total	7258-160		1		1	1	1/1
Liquid Scintillation Counting									
H	WATER	Tritium in Water	7258-160	10.0	1		1	1	1/1
Radon Counting									
RA	WATER	Radium-226 in Water	7258-160	16.4	1		1	1	1/1

Duplicates and Matrix Spikes are those with original (Client) sample in this Sample Delivery Group.
Blank and LCS planchets are those in the same preparation batch as some Client, Duplicate or Spike sample.

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-PBS
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

Client Test America, Inc.
Contract ITL2014

LAB WORK SUMMARY

LAB SAMPLE	CLIENT SAMPLE ID									
COLLECTED	LOCATION	MATRIX		SUF-						
RECEIVED	CUSTODY	SAS no	PLANCHET	TEST	FIX	ANALYZED	REVIEWED	BY	METHOD	
S012314-01	ITL2014-03		8647-001	80A/80		01/05/11	01/06/11	BW	Gross Alpha in Water	
12/21/10	Boeing-SSFL	WATER	8647-001	80B/80		01/05/11	01/06/11	BW	Gross Beta in Water	
12/23/10	ITL2014		8647-001	AC		01/21/11	01/24/11	BW	Radium-228 in Water	
			8647-001	GAM		01/06/11	01/11/11	MWT	Gamma Emitters in Water	
			8647-001	H		01/14/11	01/24/11	BW	Tritium in Water	
			8647-001	RA		01/21/11	01/24/11	BW	Radium-226 in Water	
			8647-001	SR		01/13/11	01/24/11	BW	Strontium-90 in Water	
			8647-001	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S012314-02	Lab Control Sample		8647-002	80A/80		01/05/11	01/06/11	BW	Gross Alpha in Water	
		WATER	8647-002	80B/80		01/05/11	01/06/11	BW	Gross Beta in Water	
			8647-002	AC		01/21/11	01/24/11	BW	Radium-228 in Water	
			8647-002	GAM		01/06/11	01/11/11	MWT	Gamma Emitters in Water	
			8647-002	H		01/14/11	01/24/11	BW	Tritium in Water	
			8647-002	RA		01/21/11	01/24/11	BW	Radium-226 in Water	
			8647-002	SR		01/13/11	01/24/11	BW	Strontium-90 in Water	
			8647-002	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S012314-03	Method Blank		8647-003	80A/80		01/05/11	01/06/11	BW	Gross Alpha in Water	
		WATER	8647-003	80B/80		01/05/11	01/06/11	BW	Gross Beta in Water	
			8647-003	AC		01/21/11	01/24/11	BW	Radium-228 in Water	
			8647-003	GAM		01/06/11	01/11/11	MWT	Gamma Emitters in Water	
			8647-003	H		01/14/11	01/24/11	BW	Tritium in Water	
			8647-003	RA		01/21/11	01/24/11	BW	Radium-226 in Water	
			8647-003	SR		01/13/11	01/24/11	BW	Strontium-90 in Water	
			8647-003	U_T		01/20/11	01/24/11	BW	Uranium, Total	
S012314-04	Duplicate (S012314-01)		8647-004	80A/80		01/05/11	01/06/11	BW	Gross Alpha in Water	
12/21/10	Boeing-SSFL	WATER	8647-004	80B/80		01/05/11	01/06/11	BW	Gross Beta in Water	
12/23/10			8647-004	AC		01/21/11	01/24/11	BW	Radium-228 in Water	
			8647-004	GAM		01/06/11	01/11/11	MWT	Gamma Emitters in Water	
			8647-004	H		01/14/11	01/24/11	BW	Tritium in Water	
			8647-004	RA		01/21/11	01/24/11	BW	Radium-226 in Water	
			8647-004	SR		01/13/11	01/24/11	BW	Strontium-90 in Water	
			8647-004	U_T		01/20/11	01/24/11	BW	Uranium, Total	

WORK SUMMARY

Page 1

SUMMARY DATA SECTION

Page 6

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-LWS
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

WORK SUMMARY, cont.

SDG 8647
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2014

COUNTS OF TESTS BY SAMPLE TYPE

TEST	SAS no	METHOD	REFERENCE	CLIENT	MORE	RE	BLANK	LCS	DUP SPIKE	TOTAL
80A/80		Gross Alpha in Water	900.0	1			1	1	1	4
80B/80		Gross Beta in Water	900.0	1			1	1	1	4
AC		Radium-228 in Water	904.0	1			1	1	1	4
GAM		Gamma Emitters in Water	901.1	1			1	1	1	4
H		Tritium in Water	906.0	1			1	1	1	4
RA		Radium-226 in Water	903.1	1			1	1	1	4
SR		Strontium-90 in Water	905.0	1			1	1	1	4
U_T		Uranium, Total	D5174	1			1	1	1	4
TOTALS				8			8	8	8	32

WORK SUMMARY

Page 2

SUMMARY DATA SECTION

Page 7

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LWS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

8647-003

Method Blank

METHOD BLANK

SDG <u>8647</u>	Client <u>Test America, Inc.</u>
Contact <u>N. Joseph Verville</u>	Contract <u>ITL2014</u>
Lab sample id <u>S012314-03</u>	Client sample id <u>Method Blank</u>
Dept sample id <u>8647-003</u>	Material/Matrix <u>WATER</u>

ANALYTE	CAS NO	RESULT pCi/L	2σ ERR (COUNT)	MDA pCi/L	RDL pCi/L	QUALI- FIERS	TEST
Gross Alpha	12587461	-0.064	0.27	0.642	3.00	U	80A
Gross Beta	12587472	-0.434	0.55	0.952	4.00	U	80B
Tritium	10028178	107	210	345	500	U	H
Radium-226	13982633	0.035	0.34	0.641	1.00	U	RA
Radium-228	15262201	-0.175	0.20	0.544	1.00	U	AC
Strontium-90	10098972	-0.069	0.30	0.735	2.00	U	SR
Uranium, Total		0	0.007	0.017	1.00	U	U_T
Potassium-40	13966002	U		<u>54.4</u>	25.0	U	GAM
Cesium-137	10045973	U		3.09	20.0	U	GAM

QC-BLANK #76684

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-DS</u>
Version <u>3.06</u>
Report date <u>01/26/11</u>

EBERLINE ANALYTICAL

SDG 8647

8647-002

Lab Control Sample

LAB CONTROL SAMPLE

SDG <u>8647</u> Contact <u>N. Joseph Verville</u>	Client <u>Test America, Inc.</u> Contract <u>ITL2014</u>
Lab sample id <u>S012314-02</u> Dept sample id <u>8647-002</u>	Client sample id <u>Lab Control Sample</u> Material/Matrix <u>WATER</u>

ANALYTE	RESULT	2σ ERR	MDA	RDL	QUALI-	ADDED	2σ ERR	REC	2σ LMTS	PROTOCOL
	pCi/L	(COUNT)	pCi/L	pCi/L	FIERS TEST	pCi/L	pCi/L	%	(TOTAL)	LIMITS
Gross Alpha	40.4	2.4	0.611	3.00	80A	40.4	1.6	100	78-122	70-130
Gross Beta	33.8	1.5	1.24	4.00	80B	35.0	1.4	97	88-112	70-130
Tritium	2850	310	343	500	H	2550	100	112	83-117	80-120
Radium-226	61.0	2.5	0.793	1.00	RA	55.7	2.2	110	81-119	80-120
Radium-228	5.39	0.63	0.530	1.00	AC	4.63	0.19	116	81-119	60-140
Strontium-90	17.4	1.2	0.548	2.00	SR	17.5	0.70	99	87-113	80-120
Uranium, Total	56.3	6.8	0.174	1.00	U_T	56.5	2.3	100	87-113	80-120
Cobalt-60	103	5.6	2.28	10.0	GAM	102	4.1	101	90-110	80-120
Cesium-137	118	4.8	3.29	20.0	GAM	110	4.4	107	90-110	80-120

QC-LCS #76683

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-LCS</u>
Version <u>3.06</u>
Report date <u>01/26/11</u>

EBERLINE ANALYTICAL

SDG 8647

ITL2014-03

8647-004

DUPLICATE

SDG <u>8647</u>	Client <u>Test America, Inc.</u>
Contact <u>N. Joseph Verville</u>	Contract <u>ITL2014</u>
DUPLICATE	ORIGINAL
Lab sample id <u>S012314-04</u>	Lab sample id <u>S012314-01</u>
Dept sample id <u>8647-004</u>	Dept sample id <u>8647-001</u>
	Received <u>12/23/10</u>
	Client sample id <u>ITL2014-03</u>
	Location/Matrix <u>Boeing-SSFL</u> <u>WATER</u>
	Collected/Volume <u>12/21/10 10:17</u> <u>9.5 L</u>
	Chain of custody id <u>ITL2014</u>

ANALYTE	DUPLICATE pCi/L	2σ ERR (COUNT)	MDA pCi/L	RDL pCi/L	QUALI- FIERS	TEST	ORIGINAL pCi/L	2σ ERR (COUNT)	MDA pCi/L	QUALI- FIERS	RPD %	3σ TOT	DER σ
Gross Alpha	1.12	0.41	0.446	3.00	J	80A	0.948	0.36	0.399	J	17	90	0.6
Gross Beta	4.03	0.65	0.887	4.00		80B	4.30	0.65	0.868		6	41	0.5
Tritium	155	210	345	500	U	H	144	200	340	U	-		0.1
Radium-226	0.179	0.37	0.641	1.00	U	RA	0.312	0.42	0.710	U	-		0.5
Radium-228	0.010	0.33	0.728	1.00	U	AC	0.125	0.26	0.604	U	-		0.5
Strontium-90	0.168	0.31	0.654	2.00	U	SR	0.018	0.28	0.637	U	-		0.7
Uranium, Total	0.245	0.029	0.017	1.00	J	U_T	0.237	0.028	0.017	J	3	25	0.4
Potassium-40	U		14.3	25.0	U	GAM	U		24.0	U	-		0.7
Cesium-137	U		1.09	20.0	U	GAM	U		1.80	U	-		0.7

QC-DUP#1 76685

DUPLICATES

Page 1

SUMMARY DATA SECTION

Page 10

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-DUP</u>
Version <u>3.06</u>
Report date <u>01/26/11</u>

EBERLINE ANALYTICAL

SDG 8647

8647-001

ITL2014-03

DATA SHEET

SDG <u>8647</u>	Client <u>Test America, Inc.</u>
Contact <u>N. Joseph Verville</u>	Contract <u>ITL2014</u>
Lab sample id <u>S012314-01</u>	Client sample id <u>ITL2014-03</u>
Dept sample id <u>8647-001</u>	Location/Matrix <u>Boeing-SSFL</u> <u>WATER</u>
Received <u>12/23/10</u>	Collected/Volume <u>12/21/10 10:17</u> <u>9.5 L</u>
	Chain of custody id <u>ITL2014</u>

ANALYTE	CAS NO	RESULT pCi/L	2σ ERR (COUNT)	MDA pCi/L	RDL pCi/L	QUALI- FIERS	TEST
Gross Alpha	12587461	0.948	0.36	0.399	3.00	J	80A
Gross Beta	12587472	4.30	0.65	0.868	4.00		80B
Tritium	10028178	144	200	340	500	U	H
Radium-226	13982633	0.312	0.42	0.710	1.00	U	RA
Radium-228	15262201	0.125	0.26	0.604	1.00	U	AC
Strontium-90	10098972	0.018	0.28	0.637	2.00	U	SR
Uranium, Total		0.237	0.028	0.017	1.00	J	U_T
Potassium-40	13966002	U		24.0	25.0	U	GAM
Cesium-137	10045973	U		1.80	20.0	U	GAM

Lab id <u>EAS</u>
Protocol <u>TA</u>
Version <u>Ver 1.0</u>
Form <u>DVD-DS</u>
Version <u>3.06</u>
Report date <u>01/26/11</u>

EBERLINE ANALYTICAL

SDG 8647

LAB METHOD SUMMARY

RADIUM-228 IN WATER

BETA COUNTING

Test AC Matrix WATER
 SDG 8647
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2014

RESULTS

LAB RAW SUF-
 SAMPLE ID TEST FIX PLANCHET CLIENT SAMPLE ID Radium-228

Preparation batch 7258-160

S012314-01	8647-001	ITL2014-03	U
S012314-02	8647-002	Lab Control Sample	ok
S012314-03	8647-003	Method Blank	U
S012314-04	8647-004	Duplicate (S012314-01)	- U

Nominal values and limits from method RDLs (pCi/L) 1.00

METHOD PERFORMANCE

LAB RAW SUF- MDA ALIQ PREP DILU- YIELD EFF COUNT FWHM DRIFT DAYS ANAL-
 SAMPLE ID TEST FIX CLIENT SAMPLE ID pCi/L L FAC TION % % min keV KeV HELD PREPARED YZED DETECTOR

Preparation batch 7258-160 2σ prep error 10.4 % Reference Lab Notebook No. 7258 pg. 160

S012314-01	ITL2014-03	0.604	1.80	82	120	31	01/21/11	01/21	GRB-221
S012314-02	Lab Control Sample	0.530	1.80	93	120		01/21/11	01/21	GRB-222
S012314-03	Method Blank	0.544	1.80	91	120		01/21/11	01/21	GRB-223
S012314-04	Duplicate (S012314-01)	0.728	1.80	76	120	31	01/21/11	01/21	GRB-224

Nominal values and limits from method 1.00 1.80 30-105 50 180

PROCEDURES REFERENCE 904.0
 DWP-894 Sequential Separation of Actinium-228 and Radium-226 in Drinking Water (>1 Liter Aliquot), rev 5

AVERAGES ± 2 SD MDA 0.602 ± 0.180
 FOR 4 SAMPLES YIELD 86 ± 16

METHOD SUMMARIES

Page 1

SUMMARY DATA SECTION

Page 12

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

Test SR Matrix WATER
 SDG 8647
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2014

LAB METHOD SUMMARY

STRONTIUM-90 IN WATER

BETA COUNTING

RESULTS

LAB RAW SUF-
 SAMPLE ID TEST FIX PLANCHET CLIENT SAMPLE ID Strontium-90

Preparation batch 7258-160

S012314-01		8647-001	ITL2014-03	U
S012314-02		8647-002	Lab Control Sample	ok
S012314-03		8647-003	Method Blank	U
S012314-04		8647-004	Duplicate (S012314-01)	- U

Nominal values and limits from method RDLs (pCi/L) 2.00

METHOD PERFORMANCE

LAB RAW SUF- MDA ALIQ PREP DILU- YIELD EFF COUNT FWHM DRIFT DAYS ANAL-
 SAMPLE ID TEST FIX CLIENT SAMPLE ID pCi/L L FAC TION % % min keV KeV HELD PREPARED YZED DETECTOR

Preparation batch 7258-160 2σ prep error 10.4 % Reference Lab Notebook No. 7258 pg. 160

S012314-01		ITL2014-03	0.637	0.500			71	60		23	01/08/11	01/13	GRB-203
S012314-02		Lab Control Sample	0.548	0.500			85	60			01/08/11	01/13	GRB-204
S012314-03		Method Blank	0.735	0.500			73	50			01/08/11	01/13	GRB-204
S012314-04		Duplicate (S012314-01)	0.654	0.500			77	50		23	01/08/11	01/13	GRB-202

Nominal values and limits from method 2.00 0.500 30-105 50 180

PROCEDURES REFERENCE 905.0
 DWP-380 Strontium in Drinking Water, rev 8

AVERAGES ± 2 SD MDA 0.644 ± 0.153
 FOR 4 SAMPLES YIELD 76 ± 12

METHOD SUMMARIES

Page 2

SUMMARY DATA SECTION

Page 13

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

LAB METHOD SUMMARY

GROSS ALPHA IN WATER

GAS PROPORTIONAL COUNTING

Test 80A Matrix WATER
 SDG 8647
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2014

RESULTS

LAB RAW SUF-
 SAMPLE ID TEST FIX PLANCHET CLIENT SAMPLE ID Gross Alpha

Preparation batch 7258-160

S012314-01	80	8647-001	ITL2014-03	0.948 J
S012314-02	80	8647-002	Lab Control Sample	ok
S012314-03	80	8647-003	Method Blank	U
S012314-04	80	8647-004	Duplicate (S012314-01)	ok J

Nominal values and limits from method RDLs (pCi/L) 3.00

METHOD PERFORMANCE

LAB RAW SUF- MDA ALIQ PREP DILU- RESID EFF COUNT FWHM DRIFT DAYS ANAL-
 SAMPLE ID TEST FIX CLIENT SAMPLE ID pCi/L L FAC TION mg % min keV KeV HELD PREPARED YZED DETECTOR

Preparation batch 7258-160 2σ prep error 20.6 % Reference Lab Notebook No. 7258 pg. 160

S012314-01	80	ITL2014-03	0.399	0.300	35	400	15	01/04/11	01/05	GRB-101
S012314-02	80	Lab Control Sample	0.611	0.250	60	400		01/04/11	01/05	GRB-103
S012314-03	80	Method Blank	0.642	0.250	60	400		01/04/11	01/05	GRB-104
S012314-04	80	Duplicate (S012314-01)	0.446	0.300	36	400	15	01/04/11	01/05	GRB-105

Nominal values and limits from method 3.00 0.250 0-200 100 180

PROCEDURES REFERENCE 900.0
 DWP-121 Gross Alpha and Gross Beta in Drinking Water,
 rev 10

AVERAGES ± 2 SD MDA 0.524 ± 0.240
 FOR 4 SAMPLES RESIDUE 48 ± 28

METHOD SUMMARIES

Page 3

SUMMARY DATA SECTION

Page 14

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

LAB METHOD SUMMARY

GROSS BETA IN WATER

GAS PROPORTIONAL COUNTING

Test 80B Matrix WATER
 SDG 8647
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2014

RESULTS

LAB	RAW	SUF-			
SAMPLE ID	TEST FIX	PLANCHET	CLIENT SAMPLE ID		Gross Beta
Preparation batch 7258-160					
S012314-01	80	8647-001	ITL2014-03		4.30
S012314-02	80	8647-002	Lab Control Sample		ok
S012314-03	80	8647-003	Method Blank		U
S012314-04	80	8647-004	Duplicate (S012314-01)		ok
Nominal values and limits from method			RDLs (pCi/L)		4.00

METHOD PERFORMANCE

LAB	RAW	SUF-	MDA	ALIQ	PREP	DILU-	RESID	EFF	COUNT	FWHM	DRIFT	DAYS	ANAL-		
SAMPLE ID	TEST FIX	CLIENT SAMPLE ID	pCi/L	L	FAC	TION	mg	%	min	keV	KeV	HELD	PREPARED	YZED	DETECTOR
Preparation batch 7258-160 2σ prep error 11.0 % Reference Lab Notebook No. 7258 pg. 160															
S012314-01	80	ITL2014-03	0.868	0.300			35		400			15	01/04/11	01/05	GRB-101
S012314-02	80	Lab Control Sample	1.24	0.250			60		400				01/04/11	01/05	GRB-103
S012314-03	80	Method Blank	0.952	0.250			60		400				01/04/11	01/05	GRB-104
S012314-04	80	Duplicate (S012314-01)	0.887	0.300			36		400			15	01/04/11	01/05	GRB-105
Nominal values and limits from method			4.00	0.250			0-200		100						180

PROCEDURES REFERENCE 900.0
 DWP-121 Gross Alpha and Gross Beta in Drinking Water,
 rev 10

AVERAGES ± 2 SD MDA 0.987 ± 0.345
 FOR 4 SAMPLES RESIDUE 48 ± 28

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

Test GAM Matrix WATER
 SDG 8647
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2014

LAB METHOD SUMMARY

GAMMA EMITTERS IN WATER
 GAMMA SPECTROSCOPY

RESULTS

LAB	RAW	SUF-			Cobalt-60	Cesium-137
SAMPLE ID	TEST FIX	PLANCHET	CLIENT SAMPLE ID			
Preparation batch 7258-160						
S012314-01		8647-001	ITL2014-03			U
S012314-02		8647-002	Lab Control Sample	ok		ok
S012314-03		8647-003	Method Blank			U
S012314-04		8647-004	Duplicate (S012314-01)			- U
Nominal values and limits from method			RDLs (pCi/L)	10.0		20.0

METHOD PERFORMANCE

LAB	RAW	SUF-	MDA	ALIQ	PREP	DILU-	YIELD	EFF	COUNT	FWHM	DRIFT	DAYS	ANAL-		
SAMPLE ID	TEST FIX	CLIENT SAMPLE ID	pCi/L	L	FAC	TION	%	%	min	keV	KeV	HELD	PREPARED	YZED	DETECTOR
Preparation batch 7258-160			2σ prep error 7.0 %			Reference Lab Notebook No. 7258 pg. 160									
S012314-01		ITL2014-03	2.00						401			16	12/30/10	01/06	01,04,00
S012314-02		Lab Control Sample	2.00						402				12/30/10	01/06	MB,02,00
S012314-03		Method Blank	2.00						400				12/30/10	01/06	MB,05,00
S012314-04		Duplicate (S012314-01)	2.00						708			16	12/30/10	01/06	MB,08,00
Nominal values and limits from method			6.00	2.00					400			180			

PROCEDURES REFERENCE 901.1
 DWP-100 Preparation of Drinking Water Samples for Gamma Spectroscopy, rev 5

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

LAB METHOD SUMMARY

URANIUM, TOTAL
KINETIC PHOSPHORIMETRY, UG

Test U T Matrix WATER
SDG 8647
Contact N. Joseph Verville

Client Test America, Inc.
Contract ITL2014

RESULTS

LAB	RAW	SUF-		Uranium,	
SAMPLE ID	TEST	FIX	PLANCHET	CLIENT SAMPLE ID	Total
Preparation batch 7258-160					
S012314-01			8647-001	ITL2014-03	0.237 J
S012314-02			8647-002	Lab Control Sample	ok
S012314-03			8647-003	Method Blank	U
S012314-04			8647-004	Duplicate (S012314-01)	ok J
Nominal values and limits from method					
				RDLs (pCi/L)	1.00

METHOD PERFORMANCE

LAB	RAW	SUF-	MDA	ALIQ	PREP	DILU-	YIELD	EFF	COUNT	FWHM	DRIFT	DAYS	ANAL-				
SAMPLE ID	TEST	FIX	CLIENT	SAMPLE ID	pCi/L	L	FAC	TION	%	%	min	keV	KeV	HELD	PREPARED	YZED	DETECTOR
Preparation batch 7258-160 2σ prep error Reference Lab Notebook No. 7258 pg. 160																	
S012314-01			ITL2014-03		0.017	0.0200							30	12/30/10	01/20	KPA-001	
S012314-02			Lab Control Sample		0.174	0.0200								12/30/10	01/20	KPA-001	
S012314-03			Method Blank		0.017	0.0200								12/30/10	01/20	KPA-001	
S012314-04			Duplicate (S012314-01)		0.017	0.0200							30	12/30/10	01/20	KPA-001	
Nominal values and limits from method																	
					1.00	0.0200								180			

PROCEDURES REFERENCE D5174

AVERAGES ± 2 SD MDA 0.056 ± 0.157
FOR 4 SAMPLES YIELD _____ ± _____

METHOD SUMMARIES

Page 6

SUMMARY DATA SECTION

Page 17

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-LMS
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

LAB METHOD SUMMARY

TRITIUM IN WATER

LIQUID SCINTILLATION COUNTING

Test H Matrix WATER
 SDG 8647
 Contact N. Joseph Verville

Client Test America, Inc.
 Contract ITL2014

RESULTS

LAB RAW SUF- Tritium
 SAMPLE ID TEST FIX PLANCHET CLIENT SAMPLE ID

Preparation batch 7258-160

S012314-01	8647-001	ITL2014-03	U
S012314-02	8647-002	Lab Control Sample	ok
S012314-03	8647-003	Method Blank	U
S012314-04	8647-004	Duplicate (S012314-01)	- U

Nominal values and limits from method RDLs (pCi/L) 500

METHOD PERFORMANCE

LAB RAW SUF- MDA ALIQ PREP DILU- YIELD EFF COUNT FWHM DRIFT DAYS ANAL-
 SAMPLE ID TEST FIX CLIENT SAMPLE ID pCi/L L FAC TION % % min keV KeV HELD PREPARED YZED DETECTOR

Preparation batch 7258-160 2σ prep error 10.0 % Reference Lab Notebook No. 7258 pg. 160

S012314-01	ITL2014-03	340	0.0100	100	<u>50</u>	24	01/13/11	01/14	LSC-005
S012314-02	Lab Control Sample	343	0.100	10	<u>50</u>		01/13/11	01/14	LSC-005
S012314-03	Method Blank	345	0.100	10	<u>50</u>		01/13/11	01/14	LSC-005
S012314-04	Duplicate (S012314-01)	345	0.0100	100	<u>50</u>	24	01/13/11	01/14	LSC-005

Nominal values and limits from method 500 0.0100 100 180

PROCEDURES REFERENCE 906.0
 DWP-212 Tritium in Drinking Water by Distillation, rev 8

AVERAGES ± 2 SD MDA 343 ± 4.73
 FOR 4 SAMPLES YIELD 55 ± 104

METHOD SUMMARIES

Page 7

SUMMARY DATA SECTION

Page 18

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-LMS
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

LAB METHOD SUMMARY

RADIUM-226 IN WATER

RADON COUNTING

Test RA Matrix WATER
SDG 8647
Contact N. Joseph Verville

Client Test America, Inc.
Contract ITL2014

RESULTS

LAB RAW SUF-
SAMPLE ID TEST FIX PLANCHET CLIENT SAMPLE ID Radium-226

Preparation batch 7258-160

S012314-01	8647-001	ITL2014-03	U
S012314-02	8647-002	Lab Control Sample	ok
S012314-03	8647-003	Method Blank	U
S012314-04	8647-004	Duplicate (S012314-01)	- U

Nominal values and limits from method RDLs (pCi/L) 1.00

METHOD PERFORMANCE

LAB RAW SUF- MDA ALIQ PREP DILU- YIELD EFF COUNT FWHM DRIFT DAYS ANAL-
SAMPLE ID TEST FIX CLIENT SAMPLE ID pCi/L L FAC TION % % min keV KeV HELD PREPARED YZED DETECTOR

Preparation batch 7258-160 2σ prep error 16.4 % Reference Lab Notebook No. 7258 pg. 160

S012314-01	ITL2014-03	0.710	0.100	100	86	31	01/21/11	01/21	RN-010
S012314-02	Lab Control Sample	0.793	0.100	100	102		01/21/11	01/21	RN-009
S012314-03	Method Blank	0.641	0.100	100	86		01/21/11	01/21	RN-013
S012314-04	Duplicate (S012314-01)	0.641	0.100	100	86	31	01/21/11	01/21	RN-011

Nominal values and limits from method 1.00 0.100 100 180

PROCEDURES REFERENCE 903.1
DWP-881A Ra-226 Screening in Drinking Water, rev 6

AVERAGES ± 2 SD MDA 0.696 ± 0.144
FOR 4 SAMPLES YIELD 100 ± 0

METHOD SUMMARIES

Page 8

SUMMARY DATA SECTION

Page 19

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-LMS
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2014

SAMPLE SUMMARY

The Sample and QC Summary Reports show all samples, including QC samples, reported in one Sample Delivery Group (SDG).

The Sample Summary Report fully identifies client samples and gives the corresponding lab sample identification. The QC Summary Report shows at the sample level how the lab organized the samples into batches and generated QC samples. The Preparation Batch and Method Summary Reports show this at the analysis level.

The following notes apply to these reports:

- * LAB SAMPLE ID is the lab's primary identification for a sample.
- * DEPARTMENT SAMPLE ID is an alternate lab id, for example one assigned by a radiochemistry department in a lab.
- * CLIENT SAMPLE ID is the client's primary identification for a sample. It includes any sample preparation done by the client that is necessary to identify the sample.
- * QC BATCH is a lab assigned code that groups samples to be processed and QCed together. These samples should have similar matrices.

QC BATCH is not necessarily the same as SDG, which reflects samples received and reported together.

- * All Lab Control Samples, Method Blanks, Duplicates and Matrix Spikes are shown that QC any of the samples. Due to possible reanalyses, not all results for all these QC samples may be relevant to the SDG. The Lab Control Sample, Method Blank, Duplicate, Matrix Spike and Method Summary Reports detail these relationships.

REPORT GUIDES

Page 1

SUMMARY DATA SECTION

Page 20

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2014

PREPARATION BATCH SUMMARY

The Preparation Batch Summary Report shows all preparation batches in one Sample Delivery Group (SDG) with information necessary to check the completeness and consistency of the SDG.

The following notes apply to this report:

- * The preparation batches are shown in the same order as the Method Summary Reports are printed.
- * Only analyses of planchets relevant to the SDG are included.
- * Each preparation batch should have at least one Method Blank and LCS in it to validate client sample results.
- * The QUALIFIERS shown are all qualifiers other than U, J, B, L and H that occur on any analysis in the preparation batch. The Method Summary Report has these qualifiers on a per sample basis.

These qualifiers should be reviewed as follows:

- X Some data has been manually entered or modified. Transcription errors are possible.
- P One or more results are 'preliminary'. The data is not ready for final reporting.
- 2 There were two or more results for one analyte on one planchet imported at one time. The results in DVD may not be the same as on the raw data sheets.

Other lab defined qualifiers may occur. In general, these should be addressed in the SDG narrative.

REPORT GUIDES

Page 2

SUMMARY DATA SECTION

Page 21

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2014

WORK SUMMARY

The Work Summary Report shows all samples, including QC samples, and all relevant analyses in one Sample Delivery Group (SDG). This report is often useful as supporting documentation for an invoice.

The following notes apply to this report:

- * TEST is a code for the method used to measure associated analytes. Results and related information for each analyte are on the Data Sheet Report. In special cases, a test code used in the summary data section is not the same as in associated raw data. In this case, both codes are shown on the Work Summary.
- * SUFFIX is the lab's code to distinguish multiple analyses (recounts, reworks, reanalyses) of a fraction of the sample. The suffix indicates which result is being reported. An empty suffix normally identifies the first attempt to analyze the sample.
- * The LAB SAMPLE ID, TEST and SUFFIX uniquely identify all supporting data for a result. The Method Summary Report for each TEST has method performance data, such as yield, for each lab sample id and suffix and procedures used in the method.
- * PLANCHET is an alternate lab identifier for work done for one test. It, combined with the TEST and SUFFIX, may be the best link to raw data.
- * For QC samples, only analyses that directly QC some regular sample are shown. The Lab Control Sample, Method Blank, Duplicate, Matrix Spike and Method Summary Reports detail these relationships.
- * The SAS (Special Analytical Services) Number is a client or lab assigned code that reflects special processing for samples, such as rapid turn around. Counts of tests done are lists by SAS number since it is likely to affect prices.

REPORT GUIDES

Page 3

SUMMARY DATA SECTION

Page 22

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
 Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
 Contract ITL2014

DATA SHEET

The Data Sheet Report shows all results and primary supporting information for one client sample or Method Blank. This report corresponds to both the CLP Inorganics and Organics Data Sheet.

The following notes apply to this report:

- * TEST is a code for the method used to measure an analyte. If the TEST is empty, no data is available; the analyte was not analyzed for.
- * The LAB SAMPLE ID and TEST uniquely identify work within the Summary Data Section of a Data Package. The Work Summary and Method Summary Reports further identify raw data that underlies this work.

The Method Summary Report for each TEST has method performance data, such as yield, for each Lab Sample ID and a list of procedures used in the method.

- * ERRORS can be labeled TOTAL or COUNT. TOTAL implies a preparation (non-counting method) error has been added, as square root of sum of squares, to the counting error denoted by COUNT. The preparation errors, which may vary by preparation batch, are shown on the Method Summary Report.
- * A RESULT can be 'N.R.' (Not Reported). This means the lab did this work but chooses not to report it now, possibly because it was reported at another time.
- * When reporting a Method Blank, a RESULT can be 'N.A.' (Not Applicable). This means there is no reported client sample work in the same preparation batch as the Blank's result. This is likely to occur when the Method Blank is associated with reanalyses of selected work for a few samples in the SDG.

The following qualifiers are defined by the DVD system:

- U The RESULT is less than the MDA (Minimum Detectable Activity). If the MDA is blank, the ERROR is used as the limit.

REPORT GUIDES

Page 4

SUMMARY DATA SECTION

Page 23

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-RG
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2014

DATA SHEET

J The RESULT is less than the RDL (Required Detection Limit) and no U qualifier is assigned.

B A Method Blank associated with this sample had a result without a U flag and, after correcting for possibly different aliquots, that result is greater than or equal to the MDA for this sample.

Normally, B is not assigned if U is. When method blank subtraction is shown on this report, B flags are assigned based on the unsubtracted values while U's are assigned based on the subtracted ones. Both flags can be assigned in this case.

For each sample result, all Method Blank results in the same preparation batch are compared. The Method Summary Report documents this and other QC relationships.

L Some Lab Control Sample that QC's this sample had a low recovery. The lab can disable assignment of this qualifier.

H Similar to 'L' except the recovery was high.

P The RESULT is 'preliminary'.

X Some data necessary to compute the RESULT, ERROR or MDA was manually entered or modified.

2 There were two or more results available for this analyte. The reported result may not be the same as in the raw data.

Other qualifiers are lab defined. Definitions should be in the SDG narrative.

The following values are underlined to indicate possible problems:

- * An MDA is underlined if it is bigger than its RDL.
- * An ERROR is underlined if the 1.645 sigma counting error is bigger than both the MDA and the RESULT, implying that the MDA

REPORT GUIDES

Page 5

SUMMARY DATA SECTION

Page 24

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2014

DATA SHEET

may not be a good estimate of the 'real' minimum detectable activity.

- * A negative RESULT is underlined if it is less than the negative of its 2 sigma counting ERROR.
- * When reporting a Method Blank, a RESULT is underlined if greater than its MDA. If the MDA is blank, the 2 sigma counting error is used in the comparison.

REPORT GUIDES

Page 6

SUMMARY DATA SECTION

Page 25

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2014

LAB CONTROL SAMPLE

The Lab Control Sample Report shows all results, recoveries and primary supporting information for one Lab Control Sample.

The following notes apply to this report:

- * All fields in common with the Data Sheet Report have similar usage. Refer to its Report Guide for details.
- * An amount ADDED is the lab's value for the actual amount spiked into this sample with its ERROR an estimate of the error of this amount.

An amount added is underlined if its ratio to the corresponding RDL is outside protocol specified limits.

- * REC (Recovery) is RESULT divided by ADDED expressed as a percent.

- * The first, computed limits for the recovery reflect:

1. The error of RESULT, including that introduced by rounding the result prior to printing.

If the limits are labeled (TOTAL), they include preparation error in the result. If labeled (COUNT), they do not.

2. The error of ADDED.

3. A lab specified, per analyte bias. The bias changes the center of the computed limits.

- * The second limits are protocol defined upper and lower QC limits for the recovery.
- * The recovery is underlined if it is outside either of these ranges.

REPORT GUIDES

Page 7

SUMMARY DATA SECTION

Page 26

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
 Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
 Contract ITL2014

DUPLICATE

The Duplicate Report shows all results, differences and primary supporting information for one Duplicate and associated Original sample.

The following notes apply to this report:

- * All fields in common with the Data Sheet Report have similar usage. This applies both to the Duplicate and Original sample data. Refer to the Data Sheet Report Guide for details.

If the Duplicate has data for a TEST and the lab did not do this test to the Original, the Original's RESULTS are underlined.

- * The RPD (Relative Percent Difference) is the absolute value of the difference of the RESULTS divided by their average expressed as a percent.

If both RESULTS are less than their MDAs, no RPD is computed and a '-' is printed.

For an analyte, if the lab did work for both samples but has data for only one, the MDA from the sample with data is used as the other's result in the RPD.

- * The first, computed limit is the sum, as square root of sum of squares, of the errors of the results divided by the average result as a percent, hence the relative error of the difference rather than the error of the relative difference. The errors include those introduced by rounding the RESULTS prior to printing.

If this limit is labeled TOT, it includes the preparation error in the RESULTS. If labeled CNT, it does not.

This value reported for this limit is at most 999.

- * The second limit for the RPD is the larger of:
 1. A fixed percentage specified in the protocol.

REPORT GUIDES

Page 8

SUMMARY DATA SECTION

Page 27

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-RG
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2014

DUPLICATE

2. A protocol factor (typically 2) times the average MDA as a percent of the average result. This limit applies when the results are close to the MDAs.

- * The RPD is underlined if it is greater than either limit.
- * If specified by the lab, the second limit column is replaced by the Difference Error Ratio (DER), which is the absolute value of the difference of the results divided by the quadratic sum of their one sigma errors, the same errors as used in the first limit.

Except for differences due to rounding, the DER is the same as the RPD divided by the first RPD limit with the limit scaled to 1 sigma.

- * The DER is underlined if it is greater than the sigma factor, typically 2 or 3, shown in the header for the first RPD limit.

REPORT GUIDES

Page 9

SUMMARY DATA SECTION

Page 28

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2014

MATRIX SPIKE

The Matrix Spike Report shows all results, recoveries and primary supporting information for one Matrix Spike and associated Original sample.

The following notes apply to this report:

- * All fields in common with the Data Sheet Report have similar usage. This applies both to the Spiked and Original sample data. Refer to the Data Sheet Report Guide for details.

If the Spike has data for a TEST and the lab did not do this test to the Original, the Original's RESULTS are underlined.

- * An amount ADDED is the lab's value for the actual amount spiked into the Spike sample with its ERROR an estimate of the error of this amount.

An amount is underlined if its ratio to the corresponding RDL is outside protocol specified limits.

- * REC (Recovery) is the Spike RESULT minus the Original RESULT divided by ADDED expressed as a percent.

- * The first, computed limits for the recovery reflect:

1. The errors of the two RESULTS, including those introduced by rounding them prior to printing.

If the limits are labeled (TOTAL), they include preparation error in the result. If labeled (COUNT), they do not.

2. The error of ADDED.

3. A lab specified, per analyte bias. The bias changes the center of the computed limits.

- * The second limits are protocol defined upper and lower QC limits for the recovery.

REPORT GUIDES

Page 10

SUMMARY DATA SECTION

Page 29

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2014

MATRIX SPIKE

These limits are left blank if the Original RESULT is more than a protocol defined factor (typically 4) times ADDED. This is a way of accounting for that when the spike is small compared to the amount in the original sample, the recovery is unreliable.

- * The recovery is underlined (out of spec) if it is outside either of these ranges.

REPORT GUIDES

Page 11

SUMMARY DATA SECTION

Page 30

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

REPORT GUIDE

Client Test America, Inc.
Contract ITL2014

METHOD SUMMARY

The Method Summary Report has two tables. One shows up to five results measured using one method. The other has performance data for the method. There is one report for each TEST, as used on the Data Sheet Report.

The following notes apply to this report:

- * Each table is subdivided into sections, one for each preparation batch. A preparation batch is a group of aliquots prepared at roughly the same time in one work area of the lab using the same method.

There should be Lab Control Sample and Method Blank results in each preparation batch since this close correspondence makes the QC meaningful. Depending on lab policy, Duplicates need not occur in each batch since they QC sample dependencies such as matrix effects.

- * The RAW TEST column shows the test code used in the raw data to identify a particular analysis if it is different than the test code in the header of the report. This occurs in special cases due to method specific details about how the lab labels work.

The Lab Sample or Planchet ID combined with the (Raw) Test Code and Suffix uniquely identify the raw data for each analysis.

- * If a result is less than both its MDA and RDL, it is replaced by just 'U' on this report. If it is greater than or equal to the RDL but less than the MDA, the result is shown with a 'U' flag.

The J and X flags are as on the data sheet.

- * Non-U results for Method Blanks are underlined to indicate possible contamination of other samples in the preparation batch. The Method Blank Report has supporting data.

- * Lab Control Sample and Matrix Spike results are shown as: ok, No data, LOW or HIGH, with the last two underlined. 'No data' means no amount ADDED was specified. 'LOW' and 'HIGH'

REPORT GUIDES

Page 12

SUMMARY DATA SECTION

Page 31

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-RG
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
 Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
 Contract ITL2014

METHOD SUMMARY

correspond to when the recovery is underlined on the Lab Control Sample or Matrix Spike Report. See these reports for supporting data.

* Duplicate sample results are shown as: ok, No data, or OUT, with the last two underlined. 'No data' means there was no original sample data found for this duplicate. 'OUT' corresponds to when the RPD is underlined on the Duplicate Report. See this report for supporting data.

* If the MDA column is labeled 'MAX MDA', there was more than one result measured by the reported method and the MDA shown is the largest MDA. If not all these results have the same RDL, the MAX MDA reflects only those results with RDL equal to the smallest one.

MDAs are underlined if greater than the printed RDL.

* Aliquots are underlined if less than the nominal value specified for the method.

* Preparation factors are underlined if greater than the nominal value specified for the method.

* Dilution factors are underlined if greater than the nominal value specified for the method.

* Residues are underlined if outside the range specified for the method. Residues are not printed if yields are.

* Yields, which may be gravimetric, radiometric or some type of recovery depending on the method, are underlined if outside the range specified for the method.

* Efficiencies are underlined if outside the range specified for the method. Efficiencies are detector and geometry dependent so this test is only approximate.

* Count times are underlined if less than the nominal value

REPORT GUIDES

Page 13

SUMMARY DATA SECTION

Page 32

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-RG
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2014

METHOD SUMMARY

specified for the method.

- * Resolutions (as FWHM; Full Width at Half Max) are underlined if greater than the method specified limit.
- * Tracer drifts are underlined if their absolute values are greater than the method specified limit. Tracer drifts are not printed if percent moistures are.
- * Days Held are underlined if greater than the holding time specified in the protocol.
- * Analysis dates are underlined if before their planchet's preparation date or, if a limit is specified, too far after it.

For some methods, ratios as percentages and error estimates for them are computed for pairs of results. A ratio column header like '1+3' means the ratio of the first result column and the third result column.

Ratios are not computed for Lab Control Sample, Method Blank or Matrix Spike results since their matrices are not necessarily similar to client samples'.

The error estimate for a ratio of results from one planchet reflects only counting errors since other errors should be correlated. For a ratio involving different planchets, if QC limits are computed based on total errors, the error for the ratio allows for the preparation errors for the planchets.

The ratio is underlined (out of spec) if the absolute value of its difference from the nominal value is greater than its error estimate. If no nominal value is specified, this test is not done.

For Gross Alpha or Gross Beta results, there may be a column showing the sum of other Alpha or Beta emitters. This sum includes all relevant results in the DVD database, whether reported or not. Results in the sum are weighted by a particles/decay value specified by the lab for each relevant analyte. Results less than their MDA are not included.

REPORT GUIDES

Page 14

SUMMARY DATA SECTION

Page 33

Lab id EAS
 Protocol TA
 Version Ver 1.0
 Form DVD-RG
 Version 3.06
 Report date 01/26/11

EBERLINE ANALYTICAL

SDG 8647

SDG 8647
Contact N. Joseph Verville

GUIDE, cont.

Client Test America, Inc.
Contract ITL2014

METHOD SUMMARY

No sums are computed for Lab Control, Method Blank or Matrix Spike samples since their various planchets may not be physically related.

If a ratio of total isotopic to Gross Alpha or Beta is shown, the error for the ratio reflects both the error in the Gross result and the sum, as square root of sum of squares, of the errors in the isotopic results.

For total elemental uranium or thorium results, there may be a column showing the total weight computed from associated isotopic results. Ignoring results less than their MDAs, this is a weighted sum of the isotopic results. The weights depend on the molecular weight and half-life of each isotope so as to convert activities (decays) to weight (atoms).

If a ratio of total computed to measured elemental uranium or thorium is shown, the error for the ratio reflects the errors in all the measurements.

REPORT GUIDES

Page 15

SUMMARY DATA SECTION

Page 34

Lab id EAS
Protocol TA
Version Ver 1.0
Form DVD-RG
Version 3.06
Report date 01/26/11

**SUBCONTRACT ORDER
TestAmerica Irvine**

ITL2014

8647


SENDING LABORATORY:


TestAmerica Irvine
17461 Derian Avenue, Suite 100
Irvine, CA 92614
Phone: (949) 261-1022
Fax: (949) 260-3297
Project Manager: Debby Wilson

RECEIVING LABORATORY:

Eberline Services
2030 Wright Avenue
Richmond, CA 94804
Phone : (510) 235-2633
Fax: (510) 235-0438
Project Location: California
Receipt Temperature: _____ °C Ice: Y / N

Analysis	Units	Due	Expires	Comments
Sample ID: ITL2014-03 (Outfall 018 (Composite) - Water)				
			Sampled: 12/21/10 10:17	
Gamma Spec-O	mg/kg	12/28/10	12/21/11 10:17	Out St Louis, k-40 and cs-137 only, DO NOT FILTER!
Gross Alpha-O	pCi/L	12/28/10	06/19/11 10:17	Out St Louis, Boeing permit, DO NOT FILTER!
Gross Beta-O	pCi/L	12/28/10	06/19/11 10:17	Out St Louis, Boeing permit, DO NOT FILTER!
Level 4 Data Package - Out	N/A	12/28/10	01/18/11 10:17	
Radium, Combined-O	pCi/L	12/28/10	12/21/11 10:17	Out St Louis, Boeing permit, DO NOT FILTER!
Strontium 90-O	pCi/L	12/28/10	12/21/11 10:17	Out St Louis, Boeing permit, DO NOT FILTER!
Tritium-O	pCi/L	12/28/10	12/21/11 10:17	Out St Louis, Boeing permit, DO NOT FILTER!
Uranium, Combined-O	pCi/L	12/28/10	12/21/11 10:17	Out St Louis, Boeing permit, DO NOT FILTER!
<i>Containers Supplied:</i>				
2.5 gal Poly (T)	500 mL Amber (U)			



Released By


Released By

12/22/10 17:00

Date/Time
12/23/10

Date/Time



Received By


Received By

12/22/10 17:00

Date/Time
12/23/10 12:00

Date/Time



RICHMOND, CA LABORATORY

SAMPLE RECEIPT CHECKLIST

Client: TEST AMERICA City IRVINE State CA

Date/Time received 12/23/10 12:00 CoC No. ITL 2014 2015

Container I.D. No. N/A Requested TAT (Days) STAND P.O. Received Yes [] No []

INSPECTION

1. Custody seals on shipping container intact? Yes [✓] No [] N/A []
2. Custody seals on shipping container dated & signed? Yes [✓] No [] N/A []
3. Custody seals on sample containers intact? Yes [✓] No [] N/A []
4. Custody seals on sample containers dated & signed? Yes [] No [] N/A [✓]
5. Packing material is: Wet [] Dry [] N/A ✓
6. Number of samples in shipping container: 2 Sample Matrix WATER
7. Number of containers per sample: 2 (Or see CoC _____)
8. Samples are in correct container Yes [✓] No []
9. Paperwork agrees with samples? Yes [✓] No []
10. Samples have: Tape [] Hazard labels [] Rad labels [] Appropriate sample labels [✓]
11. Samples are: In good condition [✓] Leaking [] Broken Container [] Missing []
12. Samples are: Preserved [✓] Not preserved [] pH 2 Preservative _____
13. Describe any anomalies:

14. Was P.M. notified of any anomalies? Yes [] No [] Date _____
15. Inspected by JK Date: 12/27/10 Time: 09:50

Customer Sample No.	Beta/Gamma cpm	Ion Chamber mR/hr	Wipe	Customer Sample No.	Beta/Gamma cpm	Ion Chamber mR/hr	wipe
<u>All samples</u>	<u>< 60</u>						

Ion Chamber Ser. No. _____
 Alpha Meter Ser. No. _____
 Beta/Gamma Meter Ser. No. 100482

Calibration date _____
 Calibration date _____
 Calibration date 24 Sep. 2010

LABORATORY REPORT



"dedicated to providing quality aquatic toxicity testing"

4350 Transport Street, Unit 107
Ventura, CA 93003
(805) 650-0546 FAX (805) 650-0756
CA DOHS ELAP Cert. No.: 1775

Date: December 29, 2010

Client: TestAmerica, Irvine
17461 Derian Ave., Suite 100
Irvine, CA 92614
Attn: Debby Wilson

Laboratory No.: A-10122103-001
Sample I.D.: ITL2014-03 (Outfall 018)

Sample Control: The sample was received by ATL within the recommended hold time, chilled and with the chain of custody record attached. Testing conducted on only one sample per client instruction (rain runoff sample).


Date Sampled: 12/21/10 - composite
Date Received: 12/21/10
Temp. Received: 5.5°C
Chlorine (TRC): 0.0 mg/l
Date Tested: 12/21/10 to 12/27/10

Sample Analysis: The following analyses were performed on your sample:
Ceriodaphnia dubia Survival and Reproduction Test (EPA Method 1002).
Attached are the test data generated from the analysis of your sample.

Result Summary:

	<u>NOEC</u>	<u>TUc</u>
<i>Ceriodaphnia</i> Survival:	100%	1.0
<i>Ceriodaphnia</i> Reproduction:	100%	1.0

Quality Control: Reviewed and approved by:



Joseph A. LeMay
Laboratory Director

**CERIODAPHNIA CHRONIC BIOASSAY
EPA METHOD 1002.0**



Lab No.: A-10122103-001
Client/ID: Test America – ITL2014-03 (Outfall 018)

Date Tested: 12/21/10 to 12/27/10

TEST SUMMARY

Test type: Daily static-renewal.
Species: *Ceriodaphnia dubia*.
Age: < 24 hrs; all released within 8 hrs.
Test vessel size: 30 ml.
Number of test organisms per vessel: 1.
Temperature: 25 +/- 1°C.
Dilution water: Mod. hard reconstituted (MHRW).
QA/QC Batch No.: RT-101207.

Endpoints: Survival and Reproduction.
Source: In-laboratory culture.
Food: .1 ml YTC, algae per day.
Test solution volume: 15 ml.
Number of replicates: 10.
Photoperiod: 16/8 hrs. light/dark cycle.
Test duration: 6 days.
Statistics: ToxCalc computer program.

RESULTS SUMMARY

Sample Concentration	Percent Survival	Mean Number of Young Per Female
Control	100%	22.4
100% Sample	100%	25.7
* Sample not statistically significantly less than Control.		

CHRONIC TOXICITY

Survival NOEC	100%
Survival TUC	1.0
Reproduction NOEC	100%
Reproduction TUC	1.0

QA/QC TEST ACCEPTABILITY

Parameter	Result
Control survival ≥80%	Pass (100% survival)
≥ 15 young per surviving control female	Pass (22.4 young)
≥60% surviving controls had 3 broods	Pass (80% with 3 broods)
PMSD <47% for reproduction; if >47% and no toxicity at IWC, the test must be repeated	Pass (PMSD = 17.6%)
Statistically significantly different concentrations relative difference > 13%	Pass (no concentration significantly different)
Concentration response relationship acceptable	Pass (no significant response at concentration tested)

Ceriodaphnia Survival and Reproduction Test-Survival Day 6


Start Date: 12/21/2010 15:00 Test ID: 10122103c Sample ID: Outfall 018
 End Date: 12/27/2010 15:00 Lab ID: CAATL-Aquatic Testing Labs Sample Type: EFF2-Industrial
 Sample Date: 12/21/2010 10:17 Protocol: FWCH EPA Test Species: CD-Ceriodaphnia dubia
 Comments:

Conc-%	1	2	3	4	5	6	7	8	9	10
D-Control	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
100	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000

Conc-%	Mean	N-Mean	Resp	Not Resp	Total	N	Fisher's Exact P	1-Tailed Critical	Isotonic Mean	N-Mean
D-Control	1.0000	1.0000	0	10	10	10			1.0000	1.0000
100	1.0000	1.0000	0	10	10	10	1.0000	0.0500	1.0000	1.0000

Hypothesis Test (1-tail, 0.05)	NOEC	LOEC	ChV	TU
Fisher's Exact Test	100	>100		1
Treatments vs D-Control				

Point	%	SD	Linear Interpolation (200 Resamples)	
			95% CL	Skew
IC05	>100			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			



Ceriodaphnia Survival and Reproduction Test-Reproduction

Start Date: 12/21/2010 15:00 Test ID: 10122103c Sample ID: Outfall 018
 End Date: 12/27/2010 15:00 Lab ID: CAATL-Aquatic Testing Labs Sample Type: EFF2-Industrial
 Sample Date: 12/21/2010 10:17 Protocol: FWCH EPA Test Species: CD-Ceriodaphnia dubia
 Comments:

Conc-%	1	2	3	4	5	6	7	8	9	10
D-Control	11.000	27.000	20.000	29.000	24.000	15.000	23.000	26.000	25.000	24.000
100	26.000	29.000	28.000	25.000	25.000	26.000	14.000	31.000	28.000	25.000

Conc-%	Mean	N-Mean	Transform: Untransformed					Rank Sum	1-Tailed Critical	Isotonic	
			Mean	Min	Max	CV%	N			Mean	N-Mean
D-Control	22.400	1.0000	22.400	11.000	29.000	24.918	10			24.050	1.0000
100	25.700	1.1473	25.700	14.000	31.000	17.789	10	128.00	82.00	24.050	1.0000

Auxiliary Tests	Statistic	Critical	Skew	Kurt
Shapiro-Wilk's Test indicates non-normal distribution (p <= 0.05)	0.85244	0.905	-1.3548	1.47429
F-Test indicates equal variances (p = 0.56)	1.4907	6.54109		


Hypothesis Test (1-tail, 0.05)

Wilcoxon Two-Sample Test indicates no significant differences

Treatments vs D-Control

Linear Interpolation (200 Resamples)

Point	%	SD	95% CL	Skew
IC05	>100			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			



CERIODAPHNIA DUBIA CHRONIC BIOASSAY
EPA METHOD 1002.0 Raw Data Sheet



Lab No.: A-10122103-001

Client ID: TestAmerica - Outfall 018

Start Date: 12/21/2010

		DAY 1		DAY 2		DAY 3		DAY 4		DAY 5		DAY 6		DAY 7	
		0 hr	24hr												
Analyst Initials:		Ru	Ru	-	-										
Time of Readings:		1500	1500	1500	1400	1400	1500	1500	1430	1430	1500	1500	1500	-	-
Control	DO	8.8	8.3	8.0	8.4	8.0	8.2	8.6	8.1	8.4	8.0	8.3	8.0	-	-
	pH	8.2	8.2	8.2	8.1	8.2	8.1	8.2	8.2	8.2	8.2	8.2	8.2	-	-
	Temp	24.3	24.7	25.1	24.8	24.2	24.6	24.2	24.3	24.2	24.1	24.2	24.4	-	-
100%	DO	9.7	7.7	8.1	8.6	10.1	7.6	9.9	7.7	10.2	7.4	9.8	8.0	-	-
	pH	6.6	7.9	7.5	7.8	6.7	8.0	7.0	8.0	7.0	7.9	7.4	8.1	-	-
	Temp	24.6	24.2	24.7	25.3	24.3	24.3	24.8	24.3	24.2	24.3	24.2	24.5	-	-

Additional Parameters	Control	100% Sample
Conductivity (umohms)	310	144
Alkalinity (mg/l CaCO ₃)	77	16
Hardness (mg/l CaCO ₃)	88	40
Ammonia (mg/l NH ₃ -N)	<0.1	0.2

Source of Neonates											
Replicate:	A	B	C	D	E	F	G	H	I	J	
Brood ID:	3A	1B	1C	3D	1E	2F	1G	1H	3I	2J	

Sample	Day	Number of Young Produced										Total Live Young	No. Live Adults	Analyst Initials
		A	B	C	D	E	F	G	H	I	J			
Control	1	0	0	0	0	0	0	0	0	0	0	0	10	Ru
	2	0	0	0	0	0	0	0	0	0	0	0	10	Ru
	3	0	0	4	3	0	0	3	0	4	0	14	10	Ru
	4	4	3	0	0	4	5	5	4	0	5	30	10	Ru
	5	7	9	6	10	7	10	15	10	7	6	87	10	Ru
	6	0	15	10	16	13	0	0	12	14	13	93	10	Ru
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	11	27	20	29	24	15	23	26	25	24	224	10	Ru
100%	1	0	0	0	0	0	0	0	0	0	0	10	Ru	
	2	0	0	0	0	0	0	0	0	0	0	10	Ru	
	3	3	0	0	0	3	4	4	0	0	14	10	Ru	
	4	0	4	5	4	0	0	0	6	5	4	28	10	Ru
	5	7	9	8	9	7	7	10	11	7	8	83	10	Ru
	6	16	16	15	12	15	15	0	14	16	13	132	10	Ru
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	26	29	28	25	25	26	14	31	28	25	257	10	Ru

Circled fourth brood not used in statistical analysis.

7th day only used if <60% of the surviving control females have produced their third brood.



***CHAIN
OF
CUSTODY***

SUBCONTRACT ORDER

TestAmerica Irvine

ITL2014

SENDING LABORATORY:

TestAmerica Irvine
17461 Derian Avenue, Suite 100
Irvine, CA 92614
Phone: (949) 261-1022
Fax: (949) 260-3297
Project Manager: Debby Wilson

RECEIVING LABORATORY:

Aquatic Testing Laboratories-SUB
4350 Transport Street, Unit 107
Ventura, CA 93003
Phone : (805) 650-0546
Fax: (805) 650-0756

Analysis	Due	Expires	Laboratory ID	Comments
Sample ID: ITL2014-03	Water	Sampled: 12/21/10 10:17		
Bioassay-7 dy Chrnrc	12/28/10 15:00	12/22/10 22:17		Cerio, EPA/821-R02-013, Sub to Aquatic testing
Containers Supplied: 1 gal Poly (W)				Outfall 018

Released By _____ Date _____ Received By *[Signature]* Date 12-21-10 10:17

Released By _____ Date _____ Received By _____ Date _____



***REFERENCE
TOXICANT
DATA***

CERIODAPHNIA CHRONIC BIOASSAY
EPA METHOD 1002.0
REFERENCE TOXICANT - NaCl



QA/QC Batch No.: RT-101207

Date Tested: 12/07/10 to 12/13/10

TEST SUMMARY

Test type: Daily static-renewal.
 Species: *Ceriodaphnia dubia*.
 Age: < 24 hrs; all released within 8 hrs.
 Test vessel size: 30 ml.
 Number of test organisms per vessel: 1.
 Temperature: 25 +/- 1°C.
 Dilution water: Mod. hard reconstituted (MHRW).
 Reference Toxicant: Sodium chloride (NaCl).

Endpoints: Survival and Reproduction.
 Source: In-laboratory culture.
 Food: .1 ml YTC, algae per day.
 Test solution volume: 20 ml.
 Number of replicates: 10.
 Photoperiod: 16/8 hrs. light/dark cycle.
 Test duration: 6 days.
 Statistics: ToxCalc computer program.

RESULTS SUMMARY

Sample Concentration	Percent Survival		Mean Number of Young Per Female	
Control	100%		23.3	
0.25 g/l	100%		25.2	
0.5 g/l	100%		23.7	
1.0 g/l	100%		16.0	*
2.0 g/l	100%		2.9	*
4.0 g/l	0%	*	0	**

* Statistically significantly less than control at P = 0.05 level
 ** Reproduction data from concentrations greater than survival NOEC are excluded from statistical analysis.

CHRONIC TOXICITY

Survival LC50	2.8 g/l
Reproduction IC25	0.86 mg/l

QA/QC TEST ACCEPTABILITY

Parameter	Result
Control survival ≥ 80%	Pass (100% Survival)
≥ 15 young per surviving control female	Pass (23.3 young)
≥ 60% surviving controls had 3 broods	Pass (80% with 3 broods)
PMSD < 47% for reproduction	Pass (PMSD = 18.9%)
Stat. sig. diff. conc. relative difference > 13%	Pass (Stat. sig. diff. conc. Relative difference = 31.3%)
Concentration response relationship acceptable	Pass (Response curve normal)

Ceriodaphnia Survival and Reproduction Test-Survival Day 6

Start Date: 12/7/2010 14:00 Test ID: RT101207c Sample ID: REF-Ref Toxicant
 End Date: 12/13/2010 14:00 Lab ID: CAATL-Aquatic Testing Labs Sample Type: NACL-Sodium chloride
 Sample Date: 12/6/2010 Protocol: FWCH EPA Test Species: CD-Ceriodaphnia dubia

Comments:

Conc-gm/L	1	2	3	4	5	6	7	8	9	10
D-Control	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.25	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
0.5	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
1	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
2	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
4	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000


Conc-gm/L	Mean	N-Mean	Resp	Not Resp	Total	N	Fisher's Exact P	1-Tailed Critical	Number Resp	Total Number
D-Control	1.0000	1.0000	0	10	10	10			0	10
0.25	1.0000	1.0000	0	10	10	10	1.0000	0.0500	0	10
0.5	1.0000	1.0000	0	10	10	10	1.0000	0.0500	0	10
1	1.0000	1.0000	0	10	10	10	1.0000	0.0500	0	10
2	1.0000	1.0000	0	10	10	10	1.0000	0.0500	0	10
4	0.0000	0.0000	10	0	10	10			10	10

Hypothesis Test (1-tail, 0.05)	NOEC	LOEC	ChV	TU
Fisher's Exact Test	2	4	2.82843	
Treatments vs D-Control				

Graphical Method


Trim Level	EC50
0.0%	2.8284

2.8284



Ceriodaphnia Chronic Survival Laboratory Control Chart

CV% = 8.41



Ceriodaphnia Survival and Reproduction Test-Reproduction

Start Date: 12/7/2010 14:00 Test ID: RT101207c Sample ID: REF-Ref Toxicant
 End Date: 12/13/2010 14:00 Lab ID: CAATL-Aquatic Testing Labs Sample Type: NACL-Sodium chloride
 Sample Date: 12/6/2010 Protocol: FWCH EPA Test Species: CD-Ceriodaphnia dubia
 Comments:


Conc-gm/L	1	2	3	4	5	6	7	8	9	10
D-Control	22.000	11.000	28.000	27.000	26.000	28.000	21.000	28.000	27.000	15.000
0.25	28.000	29.000	21.000	21.000	28.000	28.000	28.000	25.000	25.000	19.000
0.5	25.000	17.000	20.000	26.000	24.000	29.000	29.000	23.000	25.000	19.000
1	10.000	10.000	20.000	22.000	20.000	11.000	15.000	12.000	24.000	16.000
2	0.000	2.000	7.000	4.000	2.000	4.000	0.000	5.000	2.000	3.000
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conc-gm/L	Transform: Untransformed							t-Stat	1-Tailed Critical	MSD	Isotonic	
	Mean	N-Mean	Mean	Min	Max	CV%	N				Mean	N-Mean
D-Control	23.300	1.0000	23.300	11.000	28.000	25.913	10				24.250	1.0000
0.25	25.200	1.0815	25.200	19.000	29.000	14.466	10	-0.959	2.223	4.404	24.250	1.0000
0.5	23.700	1.0172	23.700	17.000	29.000	17.000	10	-0.202	2.223	4.404	23.700	0.9773
*1	16.000	0.6867	16.000	10.000	24.000	32.676	10	3.686	2.223	4.404	16.000	0.6598
*2	2.900	0.1245	2.900	0.000	7.000	75.285	10	10.299	2.223	4.404	2.900	0.1196
4	0.000	0.0000	0.000	0.000	0.000	0.000	10				0.000	0.0000

Auxiliary Tests	Statistic	Critical	Skew	Kurt						
Shapiro-Wilk's Test indicates normal distribution (p > 0.05)	0.96459	0.947	-0.5938	0.09413						
Bartlett's Test indicates equal variances (p = 0.06)	8.97697	13.2767								
Hypothesis Test (1-tail, 0.05)	NOEC	LOEC	ChV	TU	MSDu	MSDp	MSB	MSE	F-Prob	df
Dunnett's Test Treatments vs D-Control	0.5	1	0.70711		4.40372	0.189	860.47	19.6156	5.6E-15	4, 45


Linear Interpolation (200 Resamples)

Point	gm/L	SD	95% CL	Skew
IC05	0.5430	0.1060	0.2194 0.6041	-1.2164
IC10	0.6218	0.0833	0.4101 0.7081	-1.1699
IC15	0.7005	0.0819	0.5141 0.8292	-0.4850
IC20	0.7792	0.0859	0.5998 0.9452	0.1951
IC25	0.8580	0.0903	0.6963 1.0439	0.3636
IC40	1.1107	0.1011	0.9055 1.2772	-0.0498
IC50	1.2958	0.0936	1.0659 1.4429	-0.4534



Ceriodaphnia Chronic Reproduction Laboratory Control Chart

CV% = 10.1



CERIODAPHNIA DUBIA CHRONIC BIOASSAY
Reference Toxicant - NaCl
Reproduction and Survival Raw Data Sheet



QA/QC No.: RT-101207

Start Date: 12/07/2010

Sample	Day	Number of Young Produced										Total Live Young	No. Live Adults	Analyst Initials
		A	B	C	D	E	F	G	H	I	J			
Control	1	0	0	0	0	0	0	0	0	0	0	0	10	R
	2	0	0	0	0	0	0	0	0	0	0	0	10	R
	3	0	0	4	0	0	0	0	0	0	0	4	10	R
	4	3	3	0	5	4	2	3	4	4	3	31	10	R
	5	9	8	6	7	8	9	6	9	7	0	69	10	R
	6	10	0	18	15	14	17	12	15	16	12	129	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	22	11	28	27	26	28	21	28	27	15	233	10	R
0.25 g/l	1	0	0	0	0	0	0	0	0	0	0	10	R	
	2	0	0	0	0	0	0	0	0	0	0	10	R	
	3	0	0	4	0	0	0	0	0	0	4	10	R	
	4	4	3	0	4	5	4	4	3	4	4	35	10	R
	5	6	9	7	0	8	10	9	7	7	0	63	10	R
	6	18	17	10	17	15	14	15	15	14	15	150	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	28	29	21	21	28	28	28	25	25	19	252	10	R
0.5 g/l	1	0	0	0	0	0	0	0	0	0	0	10	R	
	2	0	0	0	0	0	0	0	0	0	0	10	R	
	3	0	0	0	4	0	0	0	0	0	4	10	R	
	4	4	3	4	0	5	4	4	3	3	4	34	10	R
	5	6	0	6	8	7	9	7	6	7	0	56	10	R
	6	15	14	10	14	12	16	18	14	15	15	143	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	25	17	20	26	24	29	29	23	25	19	237	10	R

Circled fourth brood not used in statistical analysis.

7th day only used if <60% of the surviving control females have produced their third brood.

CERIODAPHNIA DUBIA CHRONIC BIOASSAY
Reference Toxicant - NaCl
Reproduction and Survival Raw Data Sheet



QA/QC No.: RT-101207

Start Date: 12/07/2010

Sample	Day	Number of Young Produced										Total Live Young	No. Live Adults	Analyst Initials
		A	B	C	D	E	F	G	H	I	J			
1.0 g/l	1	0	0	0	0	0	0	0	0	0	0	0	10	R
	2	0	0	0	0	0	0	0	0	0	0	0	10	R
	3	0	0	0	0	0	0	0	0	0	0	0	10	R
	4	4	3	4	4	5	4	3	4	4	3	38	10	R
	5	0	7	6	6	7	0	0	0	6	6	38	10	R
	6	6	0	10	12	8	7	12	8	14	7	84	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	10	10	20	22	20	11	15	12	24	16	160	10	R
2.0 g/l	1	0	0	0	0	0	0	0	0	0	0	10	R	
	2	0	0	0	0	0	0	0	0	0	0	10	R	
	3	0	0	0	0	0	0	0	0	0	0	10	R	
	4	0	0	0	0	2	0	0	2	0	0	4	10	R
	5	0	2	3	0	0	4	0	0	2	0	11	10	R
	6	0	0	4	4	0	0	0	3	0	3	14	10	R
	7	-	-	-	-	-	-	-	-	-	-	-	-	-
	Total	0	2	7	4	2	4	0	5	2	3	29	10	R
4.0 g/l	1	X	X	X	X	X	X	X	X	X	0	0	R	
	2	-	-	-	-	-	-	-	-	-	-	-	-	
	3	-	-	-	-	-	-	-	-	-	-	-	-	
	4	-	-	-	-	-	-	-	-	-	-	-	-	
	5	-	-	-	-	-	-	-	-	-	-	-	-	
	6	-	-	-	-	-	-	-	-	-	-	-	-	
	7	-	-	-	-	-	-	-	-	-	-	-	-	
	Total	0	0	0	0	0	0	0	0	0	0	0	0	R

Circled fourth brood not used in statistical analysis.
 7th day only used if <60% of the surviving control females have produced their third brood.

CERIODAPHNIA DUBIA CHRONIC BIOASSAY

Reference Toxicant - NaCl

Water Chemistries Raw Data Sheet



QA/QC No.: RT-101207

Start Date: 12/07/2010

		DAY 1		DAY 2		DAY 3		DAY 4		DAY 5		DAY 6		DAY 7		
		Initial	Final													
Analyst Initials:		R	R	R	R	R	R	R	R	R	R	R	R	R	R	
Time of Readings:		1400	1500	1500	1400	1400	1400	1400	1300	1300	1330	1330	1330	1400	—	—
Control	DO	8.4	8.7	8.4	8.6	8.7	8.3	8.2	8.4	8.1	7.9	8.2	7.6	—	—	
	pH	8.2	8.3	8.4	7.9	8.2	8.0	8.2	8.0	8.1	7.9	8.2	8.2	—	—	
	Temp	25.0	24.3	25.0	24.5	25.0	24.6	24.8	24.7	25.1	24.0	25.3	24.2	—	—	
0.25 g/l	DO	8.4	8.8	8.4	8.6	8.6	8.3	8.2	8.4	8.2	7.9	8.2	7.7	—	—	
	pH	8.2	8.3	8.3	7.9	8.2	8.0	8.2	8.0	8.1	8.1	8.2	8.2	—	—	
	Temp	25.0	24.6	25.0	24.8	25.0	25.0	24.8	24.8	25.1	24.0	25.2	24.2	—	—	
0.5 g/l	DO	8.5	8.8	8.4	8.7	8.6	8.4	8.2	8.3	8.2	7.9	8.3	7.6	—	—	
	pH	8.2	8.2	8.3	7.9	8.2	8.0	8.2	8.0	8.1	7.4	8.2	8.1	—	—	
	Temp	25.0	24.7	25.1	24.8	25.0	25.1	24.9	24.9	25.0	24.1	24.6	25.1	—	—	
1.0 g/l	DO	8.5	8.7	8.4	8.7	8.5	8.4	8.2	8.3	8.2	8.3	8.3	7.7	—	—	
	pH	8.2	8.2	8.3	7.9	8.2	8.0	8.2	8.0	8.2	7.4	8.2	8.1	—	—	
	Temp	24.9	24.6	25.1	24.9	25.1	25.0	24.9	24.9	25.0	24.0	24.5	24.9	—	—	
2.0 g/l	DO	8.6	8.6	8.5	8.8	8.3	8.4	8.2	8.5	8.2	8.2	8.2	7.4	—	—	
	pH	8.2	8.2	8.3	7.9	8.1	8.0	8.2	8.0	8.2	7.4	8.2	8.1	—	—	
	Temp	24.8	24.8	25.2	24.8	25.2	24.9	25.0	24.8	24.9	24.4	24.5	25.2	—	—	
4.0 g/l	DO	8.7	8.8	—	—	—	—	—	—	—	—	—	—	—	—	
	pH	8.1	8.2	—	—	—	—	—	—	—	—	—	—	—	—	
	Temp	24.6	24.8	—	—	—	—	—	—	—	—	—	—	—	—	

Dissolved Oxygen (DO) readings are in mg/l O₂; Temperature (Temp) readings are in °C.

Additional Parameters	Control			High Concentration		
	Day 1	Day 3	Day 5	Day 1	Day 3	Day 5
Conductivity (µS)	325	329	322	6470	3690	3430
Alkalinity (mg/l CaCO ₃)	74	73	73	73	74	74
Hardness (mg/l CaCO ₃)	87	88	89	90	89	89

Source of Neonates


Replicate:	A	B	C	D	E	F	G	H	I	J
Brood ID:	1A	2A	3A	3B	1G	1H	2I	1J	2J	3J

Test Temperature Chart

Test No: RT-101207

Date Tested: 12/07/10 to 12/13/10

Acceptable Range: 25 \pm 1 $^{\circ}$ C



THIS PAGE LEFT INTENTIONALLY BLANK

APPENDIX G

Section 39

Arroyo Simi Receiving Water – November 10, 2010

MEC^X Data Validation Report

THIS PAGE LEFT INTENTIONALLY BLANK



DATA VALIDATION REPORT

Boeing SSFL NPDES

SAMPLE DELIVERY GROUP: ITK1155

Prepared by

MEC^x, LP
12269 East Vassar Drive
Aurora, CO 80014

I. INTRODUCTION

Task Order Title: Boeing SSFL NPDES
Contract Task Order: 1261.100D.00
Sample Delivery Group: ITK1155
Project Manager: B. Kelly
Matrix: Water
QC Level: IV
No. of Samples: 1
No. of Reanalyses/Dilutions: 0
Laboratory: TestAmerica-Irvine

Table 1. Sample Identification

Client ID	Laboratory ID	Sub-Laboratory ID	Matrix	Collected	Method
Arroyo Simi-FP	ITK1155-01	NA	Water	11/10/2010 11:45:00 AM	EPA 200.7, EPA 525.2, SM2340B

II. Sample Management

No anomalies were observed regarding sample management. The samples in this SDG were received at the laboratory within the temperature limits of 4°C ±2°C. According to the case narrative for this SDG, the samples were received intact, on ice, and properly preserved, if applicable. The COCs were appropriately signed and dated by field and/or laboratory personnel. As the samples were couriered to the laboratory, custody seals were not required. If necessary, the client ID was added to the sample result summary by the reviewer.

Data Qualifier Reference Table

Qualifier	Organics	Inorganics
U	The analyte was analyzed for, but was not detected above the reported sample quantitation limit. The associated value is the quantitation limit or the estimated detection limit for dioxins or PCB congeners.	The material was analyzed for, but was not detected above the level of the associated value. The associated value is either the sample quantitation limit or the sample detection limit. The associated value is the sample detection limit or the quantitation limit for perchlorate only.
J	The analyte was positively identified; the associated numerical value is the approximate concentration of the analyte in the sample.	The associated value is an estimated quantity.
N	The analysis indicates the presence of an analyte for which there is presumptive evidence to make a "tentative identification."	Not applicable.
NJ	The analysis indicates the presence of an analyte that has been "tentatively identified" and the associated numerical value represents its approximate concentration.	Not applicable.
UJ	The analyte was not deemed above the reported sample quantitation limit. However, the reported quantitation limit is approximate and may or may not represent the actual limit of quantitation necessary to accurately and precisely measure the analyte in the sample.	The material was analyzed for, but was not detected. The associated value is an estimate and may be inaccurate or imprecise.
R	The data are unusable. The sample results are rejected due to serious deficiencies in the ability to analyze the sample and to meet quality control criteria. The presence or absence of the analyte cannot be verified.	The data are unusable. The sample results are rejected due to serious deficiencies in the ability to analyze the sample and to meet quality control criteria. The presence or absence of the analyte cannot be verified.

Qualification Code Reference Table

Qualifier	Organics	Inorganics
H	Holding times were exceeded.	Holding times were exceeded.
S	Surrogate recovery was outside QC limits.	The sequence or number of standards used for the calibration was incorrect
C	Calibration %RSD or %D was noncompliant.	Correlation coefficient is <0.995.
R	Calibration RRF was <0.05.	%R for calibration is not within control limits.
B	Presumed contamination as indicated by the preparation (method) blank results.	Presumed contamination as indicated by the preparation (method) or calibration blank results.
L	Laboratory Blank Spike/Blank Spike Duplicate %R was not within control limits.	Laboratory Control Sample %R was not within control limits.
Q	MS/MSD recovery was poor or RPD high.	MS recovery was poor.
E	Not applicable.	Duplicates showed poor agreement.
I	Internal standard performance was unsatisfactory.	ICP ICS results were unsatisfactory.
A	Not applicable.	ICP Serial Dilution %D were not within control limits.
M	Tuning (BFB or DFTPP) was noncompliant.	Not applicable.
T	Presumed contamination as indicated by the trip blank results.	Not applicable.
+	False positive – reported compound was not present.	Not applicable.
-	False negative – compound was present but not reported.	Not applicable.
F	Presumed contamination as indicated by the FB or ER results.	Presumed contamination as indicated by the FB or ER results.
\$	Reported result or other information was incorrect.	Reported result or other information was incorrect.
?	TIC identity or reported retention time has been changed.	Not applicable.

Qualification Code Reference Table Cont.

D	The analysis with this flag should not be used because another more technically sound analysis is available.	The analysis with this flag should not be used because another more technically sound analysis is available.
P	Instrument performance for pesticides was poor.	Post Digestion Spike recovery was not within control limits.
DNQ	The reported result is above the method detection limit but is less than the reporting limit.	The reported result is above the method detection limit but is less than the reporting limit.
*II, *III	Unusual problems found with the data that have been described in Section II, "Sample Management," or Section III, "Method Analyses." The number following the asterisk (*) will indicate the report section where a description of the problem can be found.	Unusual problems found with the data that have been described in Section II, "Sample Management," or Section III, "Method Analyses." The number following the asterisk (*) will indicate the report section where a description of the problem can be found.

III. Method Analyses

A. EPA METHOD 200.7—Metals

Reviewed By: P. Meeks

Date Reviewed: December 7, 2010

The sample listed in Table 1 for these analyses was validated based on the guidelines outlined in the *MEC^x Data Validation Procedure for Metals (DVP-5, Rev. 0 and DVP-21, Rev. 0)*, *EPA Method 200.7*, *Standard Method 2340B*, and the *National Functional Guidelines for Inorganic Data Review (7/02)*.

- Holding Times: The analytical holding time, six months for ICP metals, was met.
- Tuning: Not applicable to this analysis.
- Calibration: Calibration criteria were met. The initial and continuing calibration recoveries were within 90-110% and the CRDL recoveries were within the control limits of 70-130%.
- Blanks: The method blank and CCBs had no detects.
- Interference Check Samples: Recoveries were within the method-established control limits of 80-120%. There were no target compounds present in the ICSA solution at concentrations indicative of matrix interference.
- Blank Spikes and Laboratory Control Samples: Recoveries were within laboratory-established QC limits.
- Laboratory Duplicates: No laboratory duplicate analyses were performed on the sample in this SDG.
- Matrix Spike/Matrix Spike Duplicate: There were no MS/MSD analyses performed on the sample in this SDG. Method accuracy was evaluated based on LCS results.
- Serial Dilution: No serial dilution analyses were performed on the sample in this SDG.
- Internal Standards Performance: Not applicable to this analysis.

- **Sample Result Verification:** Calculations were verified and the sample results reported on the sample result summary were verified against the raw data. No transcription errors or calculation errors were noted. When the sample results were qualified and the reviewer was able to clearly determine bias, detected results were qualified as either “J+” or “J-”; otherwise, bias was not indicated in the qualification. Any detects between the method detection limit and the reporting limit were qualified as estimated, “J,” and coded with “DNQ,” in order to comply with the NPDES permit. Reported nondetects are valid to the MDL.
- **Field QC Samples:** Field QC samples were evaluated, and if necessary, qualified based on method blanks and other laboratory QC results affecting the usability of the field QC data. Any remaining detects were used to evaluate the associated site samples. Following are findings associated with field QC samples:
 - **Field Blanks and Equipment Rinsates:** This SDG had no identified field blank or equipment rinsate samples.
 - **Field Duplicates:** There were no field duplicate samples identified for this SDG.

B. EPA METHOD 525.2—Semivolatile Organic Compounds (SVOCs)

Reviewed By: L. Calvin

Date Reviewed: December 7, 2010

The sample listed in Table 1 for this analysis was validated based on the guidelines outlined in the *MEC^X Data Validation Procedure for Semivolatile Organics (DVP-3, Rev. 0)*, *EPA Method 525.2*, and the *National Functional Guidelines for Organic Data Review (10/99)*.

- **Holding Times:** Extraction and analytical holding times were met. The water sample was extracted within 24 hours of collection and analyzed within 30 days of extraction.
- **GC/MS Tuning:** The DFTPP tunes met the method abundance criteria. The sample was analyzed within 12 hours of the DFTPP injection time.
- **Calibration:** Calibration criteria were met. The initial calibration average RRFs were ≥ 0.05 and $\%RSD \leq 30\%$. The ICV and continuing calibration RRFs were ≥ 0.05 and recoveries were within the method QC limits of 70-130%.
- **Blanks:** The method blank had no target compound detects above the MDL.
- **Blank Spikes and Laboratory Control Samples:** The recoveries and RPDs were within laboratory-established QC limits.
- **Surrogate Recovery:** Recoveries were within laboratory-established QC limits.

- Matrix Spike/Matrix Spike Duplicate: No MS/MSD analyses were performed on the sample in this SDG due to insufficient sample volume. Method accuracy and precision were evaluated based on the LCS/LCSD results.
- Field QC Samples: Field QC samples were evaluated, and if necessary, qualified based on method blanks and other laboratory QC results affecting the usability of the field QC data. Any remaining detects were used to evaluate the associated site samples. Following are findings associated with field QC samples:
 - Field Blanks and Equipment Rinsates: This SDG had no identified field blank or equipment rinsate samples.
 - Field Duplicates: There were no field duplicate samples identified for this SDG.
- Internal Standards Performance: The internal standard area counts and retention times were within the method control limits established by the continuing calibration standards of $\pm 30\%$ for area counts and \pm five seconds for retention times.
- Compound Identification: Compound identification was verified. The laboratory analyzed for chlorpyrifos and diazinon by Method 525.2. Review of the sample chromatogram, retention times, and spectra indicated no problems with target compound identification.
- Compound Quantification and Reported Detection Limits: Compound quantification was verified. The reporting limits were supported by the low point of the initial calibration and the laboratory MDLs. Any detects between the method detection limit and the reporting limit were qualified as estimated, "J," and coded with "DNQ," in order to comply with the NPDES permit. Reported nondetects are valid to the reporting limit.
- Tentatively Identified Compounds: TICs were not reported by the laboratory for this analysis.
- System Performance: Review of the raw data indicated no problems with system performance.

Validated Sample Result Forms ITK1155

Analysis Method *EPA 200.7*

Sample Name	Arroyo Simi	Matrix Type:	Water	Validation Level:	IV			
Lab Sample Name	ITK1155-01	Sample Date:	11/10/2010 11:45:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Calcium	7440-70-2	190	0.10	0.050	mg/l			
Magnesium	7439-95-4	58	0.020	0.012	mg/l			

Analysis Method *EPA 525.2*

Sample Name	Arroyo Simi	Matrix Type:	Water	Validation Level:	IV			
Lab Sample Name	ITK1155-01	Sample Date:	11/10/2010 11:45:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Chlorpyrifos	2921-88-2	ND	1.0	0.010	ug/l		U	
Diazinon	333-41-5	ND	0.25	0.10	ug/l		U	

Analysis Method *SM2340B*

Sample Name	Arroyo Simi	Matrix Type:	Water	Validation Level:	IV			
Lab Sample Name	ITK1155-01	Sample Date:	11/10/2010 11:45:00 AM					
Analyte	CAS No	Result Value	RL	MDL	Result Units	Lab Qualifier	Validation Qualifier	Validation Notes
Hardness (as CaCO3)	NA	720	0.33	0.17	mg/l			

THIS PAGE LEFT INTENTIONALLY BLANK

APPENDIX G

Section 40

Arroyo Simi Receiving Water - November 10, 2010

Test America Analytical Laboratory Report

THIS PAGE LEFT INTENTIONALLY BLANK

LABORATORY REPORT

Prepared For: MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project: Quartely Arroyo Simi-Frontier
Park
Quarterly Arroyo Simi-Frontier
Sampled: 11/10/10
Received: 11/10/10
Issued: 11/24/10 16:41

NELAP #01108CA California ELAP#2706 CSDLAC #10256 AZ #AZ0671 NV #CA01531

The results listed within this Laboratory Report pertain only to the samples tested in the laboratory. The analyses contained in this report were performed in accordance with the applicable certifications as noted. All soil samples are reported on a wet weight basis unless otherwise noted in the report. This Laboratory Report is confidential and is intended for the sole use of TestAmerica and its client. This report shall not be reproduced, except in full, without written permission from TestAmerica. The Chain of Custody, 1 page, is included and is an integral part of this report.

This entire report was reviewed and approved for release.

CASE NARRATIVE

SAMPLE RECEIPT: Samples were received intact, at 3°C, on ice and with chain of custody documentation.

HOLDING TIMES: All samples were analyzed within prescribed holding times and/or in accordance with the TestAmerica Sample Acceptance Policy unless otherwise noted in the report.

PRESERVATION: Samples requiring preservation were verified prior to sample analysis.

QA/QC CRITERIA: All analyses met method criteria, except as noted in the report with data qualifiers.

COMMENTS: Results that fall between the MDL and RL are 'J' flagged.

SUBCONTRACTED: No analyses were subcontracted to an outside laboratory.

LABORATORY ID

ITK1155-01

CLIENT ID


Arroyo Simi-FP

MATRIX

Water

I certify under penalty of perjury that the information contained in this report and all attachments was produced in accordance with the indicated methods and laboratory standard operating procedures, except as noted, and are complete and accurate to the best of my knowledge and belief. Subcontract laboratory reports that are attached have been evaluated for completeness and quality control acceptability.

Reviewed By:



TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
 Quarterly Arroyo Simi-Frontier Park
 Report Number: ITK1155

Sampled: 11/10/10
 Received: 11/10/10

ORGANIC COMPOUNDS BY GC/MS (EPA 525.2)

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITK1155-01 (Arroyo Simi-FP - Water)									
Reporting Units: ug/l									
Chlorpyrifos	EPA 525.2	10K1460	0.010	1.0	ND	1	PM	11/18/10	
Diazinon	EPA 525.2	10K1460	0.10	0.25	ND	1	PM	11/18/10	
<i>Surrogate: 1,3-Dimethyl-2-nitrobenzene (70-130%)</i>					101 %				
<i>Surrogate: 1,3-Dimethyl-2-nitrobenzene (70-130%)</i>					101 %				
<i>Surrogate: Triphenylphosphate (70-130%)</i>					94 %				
<i>Surrogate: Triphenylphosphate (70-130%)</i>					94 %				
<i>Surrogate: Perylene-d12 (70-130%)</i>					93 %				
<i>Surrogate: Perylene-d12 (70-130%)</i>					93 %				

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
 Quarterly Arroyo Simi-Frontier Park
 Report Number: ITK1155

Sampled: 11/10/10
 Received: 11/10/10

ORGANOCHLORINE PESTICIDES (EPA 608)

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITK1155-01 (Arroyo Simi-FP - Water) - cont.									
Reporting Units: ug/l									
4,4'-DDD	EPA 608	10K1417	0.0038	0.0047	ND	0.943	CN	11/12/10	
4,4'-DDE	EPA 608	10K1417	0.0028	0.0047	ND	0.943	CN	11/12/10	
4,4'-DDT	EPA 608	10K1417	0.0038	0.0094	ND	0.943	CN	11/12/10	
Dieldrin	EPA 608	10K1417	0.0019	0.0047	ND	0.943	CN	11/12/10	
Chlordane	EPA 608	10K1417	0.075	0.094	ND	0.943	CN	11/12/10	
Toxaphene	EPA 608	10K1417	0.24	0.47	ND	0.943	CN	11/12/10	
<i>Surrogate: Decachlorobiphenyl (45-120%)</i>					86 %				
<i>Surrogate: Tetrachloro-m-xylene (35-115%)</i>					78 %				

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
 Quarterly Arroyo Simi-Frontier Park
 Report Number: ITK1155

Sampled: 11/10/10
 Received: 11/10/10

TOTAL PCBS (EPA 608)

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITK1155-01 (Arroyo Simi-FP - Water) - cont.									
Reporting Units: ug/l									
Aroclor 1016	EPA 608	10K1417	0.24	0.47	ND	0.943	JSM	11/12/10	
Aroclor 1221	EPA 608	10K1417	0.24	0.47	ND	0.943	JSM	11/12/10	
Aroclor 1232	EPA 608	10K1417	0.24	0.47	ND	0.943	JSM	11/12/10	
Aroclor 1242	EPA 608	10K1417	0.24	0.47	ND	0.943	JSM	11/12/10	
Aroclor 1248	EPA 608	10K1417	0.24	0.47	ND	0.943	JSM	11/12/10	
Aroclor 1254	EPA 608	10K1417	0.24	0.47	ND	0.943	JSM	11/12/10	
Aroclor 1260	EPA 608	10K1417	0.24	0.47	ND	0.943	JSM	11/12/10	
<i>Surrogate: Decachlorobiphenyl (45-120%)</i>					73 %				

TestAmerica Irvine

Debby Wilson
 Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
Quarterly Arroyo Simi-Frontier Park
Report Number: ITK1155

Sampled: 11/10/10
Received: 11/10/10

METALS

Analyte	Method	Batch	MDL Limit	Reporting Limit	Sample Result	Dilution Factor	Analyst	Date Analyzed	Data Qualifiers
Sample ID: ITK1155-01 (Arroyo Simi-FP - Water) - cont.									
Reporting Units: mg/l									
Hardness (as CaCO ₃)	SM2340B	[CALC]		0.33	720	1	LL	11/17/10	
Calcium	EPA 200.7	10K2188	0.050	0.10	190	1	LL	11/17/10	
Magnesium	EPA 200.7	10K2188	0.012	0.020	58	1	LL	11/17/10	

TestAmerica Irvine

Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

ITK1155 <Page 5 of 12>

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
Quarterly Arroyo Simi-Frontier Park
Report Number: ITK1155

Sampled: 11/10/10
Received: 11/10/10

SHORT HOLD TIME DETAIL REPORT

	Hold Time (in days)	Date/Time Sampled	Date/Time Received	Date/Time Extracted	Date/Time Analyzed
Sample ID: Arroyo Simi-FP (ITK1155-01) - Water EPA 525.2	1	11/10/2010 11:45	11/10/2010 18:17	11/11/2010 10:27	11/18/2010 11:51

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
Quarterly Arroyo Simi-Frontier Park
Report Number: ITK1155

Sampled: 11/10/10
Received: 11/10/10

METHOD BLANK/QC DATA

ORGANIC COMPOUNDS BY GC/MS (EPA 525.2)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC %REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10K1460 Extracted: 11/11/10										
Blank Analyzed: 11/18/2010 (10K1460-BLK1)										
Chlorpyrifos	ND	1.0	ug/l							
Diazinon	ND	0.25	ug/l							
Surrogate: 1,3-Dimethyl-2-nitrobenzene	5.14		ug/l	5.00		103	70-130			
Surrogate: 1,3-Dimethyl-2-nitrobenzene	5.14		ug/l	5.00		103	70-130			
Surrogate: Triphenylphosphate	5.10		ug/l	5.00		102	70-130			
Surrogate: Triphenylphosphate	5.10		ug/l	5.00		102	70-130			
Surrogate: Perylene-d12	4.50		ug/l	5.00		90	70-130			
Surrogate: Perylene-d12	4.50		ug/l	5.00		90	70-130			
LCS Analyzed: 11/18/2010 (10K1460-BS1)										
Chlorpyrifos	5.65	1.0	ug/l	5.00		113	70-130			MNR1
Diazinon	5.72	0.25	ug/l	5.00		114	70-130			
Surrogate: 1,3-Dimethyl-2-nitrobenzene	4.89		ug/l	5.00		98	70-130			
Surrogate: 1,3-Dimethyl-2-nitrobenzene	4.89		ug/l	5.00		98	70-130			
Surrogate: Triphenylphosphate	4.91		ug/l	5.00		98	70-130			
Surrogate: Triphenylphosphate	4.91		ug/l	5.00		98	70-130			
Surrogate: Perylene-d12	4.35		ug/l	5.00		87	70-130			
Surrogate: Perylene-d12	4.35		ug/l	5.00		87	70-130			
LCS Dup Analyzed: 11/18/2010 (10K1460-BSD1)										
Chlorpyrifos	5.60	1.0	ug/l	5.00		112	70-130	1	30	
Diazinon	4.46	0.25	ug/l	5.00		89	70-130	25	30	
Surrogate: 1,3-Dimethyl-2-nitrobenzene	5.22		ug/l	5.00		104	70-130			
Surrogate: 1,3-Dimethyl-2-nitrobenzene	5.22		ug/l	5.00		104	70-130			
Surrogate: Triphenylphosphate	4.93		ug/l	5.00		99	70-130			
Surrogate: Triphenylphosphate	4.93		ug/l	5.00		99	70-130			
Surrogate: Perylene-d12	4.16		ug/l	5.00		83	70-130			
Surrogate: Perylene-d12	4.16		ug/l	5.00		83	70-130			

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
Quarterly Arroyo Simi-Frontier Park
Report Number: ITK1155

Sampled: 11/10/10
Received: 11/10/10

METHOD BLANK/QC DATA

ORGANOCHLORINE PESTICIDES (EPA 608)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10K1417 Extracted: 11/11/10										
Blank Analyzed: 11/11/2010 (10K1417-BLK1)										
4,4'-DDD	ND	0.0050	ug/l							
4,4'-DDE	ND	0.0050	ug/l							
4,4'-DDT	ND	0.010	ug/l							
Dieldrin	ND	0.0050	ug/l							
Chlordane	ND	0.10	ug/l							
Toxaphene	ND	0.50	ug/l							
Surrogate: Decachlorobiphenyl	0.438		ug/l	0.500		88	45-120			
Surrogate: Tetrachloro-m-xylene	0.381		ug/l	0.500		76	35-115			
LCS Analyzed: 11/11/2010 (10K1417-BS1)										
4,4'-DDD	0.446	0.0050	ug/l	0.500		89	55-120			
4,4'-DDE	0.411	0.0050	ug/l	0.500		82	50-120			
4,4'-DDT	0.487	0.010	ug/l	0.500		97	55-120			
Dieldrin	0.454	0.0050	ug/l	0.500		91	55-115			
Surrogate: Decachlorobiphenyl	0.418		ug/l	0.500		84	45-120			
Surrogate: Tetrachloro-m-xylene	0.368		ug/l	0.500		74	35-115			
Matrix Spike Analyzed: 11/12/2010 (10K1417-MS1) Source: ITK0956-01										
4,4'-DDD	0.429	0.0047	ug/l	0.472	ND	91	50-125			
4,4'-DDE	0.397	0.0047	ug/l	0.472	ND	84	45-125			
4,4'-DDT	0.450	0.0094	ug/l	0.472	ND	95	50-125			
Dieldrin	0.438	0.0047	ug/l	0.472	ND	93	50-120			
Surrogate: Decachlorobiphenyl	0.394		ug/l	0.472		83	45-120			
Surrogate: Tetrachloro-m-xylene	0.365		ug/l	0.472		77	35-115			
Matrix Spike Dup Analyzed: 11/12/2010 (10K1417-MSD1) Source: ITK0956-01										
4,4'-DDD	0.447	0.0047	ug/l	0.472	ND	95	50-125	4	30	
4,4'-DDE	0.421	0.0047	ug/l	0.472	ND	89	45-125	6	30	
4,4'-DDT	0.479	0.0094	ug/l	0.472	ND	101	50-125	6	30	
Dieldrin	0.463	0.0047	ug/l	0.472	ND	98	50-120	5	30	
Surrogate: Decachlorobiphenyl	0.421		ug/l	0.472		89	45-120			
Surrogate: Tetrachloro-m-xylene	0.391		ug/l	0.472		83	35-115			

TestAmerica Irvine

Debby Wilson
Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
 Quarterly Arroyo Simi-Frontier Park
 Report Number: ITK1155

Sampled: 11/10/10
 Received: 11/10/10

METHOD BLANK/QC DATA

TOTAL PCBS (EPA 608)

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10K1417 Extracted: 11/11/10										
Blank Analyzed: 11/11/2010 (10K1417-BLK1)										
Aroclor 1016	ND	0.50	ug/l							
Aroclor 1221	ND	0.50	ug/l							
Aroclor 1232	ND	0.50	ug/l							
Aroclor 1242	ND	0.50	ug/l							
Aroclor 1248	ND	0.50	ug/l							
Aroclor 1254	ND	0.50	ug/l							
Aroclor 1260	ND	0.50	ug/l							
Surrogate: Decachlorobiphenyl	0.378		ug/l	0.500		76	45-120			
LCS Analyzed: 11/11/2010 (10K1417-BS2)										
Aroclor 1016	3.57	0.50	ug/l	4.00		89	50-115			
Aroclor 1260	3.49	0.50	ug/l	4.00		87	60-120			
Surrogate: Decachlorobiphenyl	0.401		ug/l	0.500		80	45-120			
Matrix Spike Analyzed: 11/11/2010 (10K1417-MS2) Source: ITK0956-01										
Aroclor 1016	3.16	0.47	ug/l	3.77	ND	84	45-120			
Aroclor 1260	3.09	0.47	ug/l	3.77	ND	82	55-125			
Surrogate: Decachlorobiphenyl	0.349		ug/l	0.472		74	45-120			
Matrix Spike Dup Analyzed: 11/11/2010 (10K1417-MSD2) Source: ITK0956-01										
Aroclor 1016	3.46	0.47	ug/l	3.79	ND	91	45-120	9	30	
Aroclor 1260	3.40	0.47	ug/l	3.79	ND	90	55-125	9	25	
Surrogate: Decachlorobiphenyl	0.390		ug/l	0.474		82	45-120			

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
 618 Michillinda Avenue, Suite 200
 Arcadia, CA 91007
 Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
 Quarterly Arroyo Simi-Frontier Park
 Report Number: ITK1155

Sampled: 11/10/10
 Received: 11/10/10

METHOD BLANK/QC DATA

METALS

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC %REC	%REC Limits	RPD	RPD Limit	Data Qualifiers
Batch: 10K2188 Extracted: 11/17/10										
Blank Analyzed: 11/17/2010 (10K2188-BLK1)										
Calcium	ND	0.10	mg/l							
Magnesium	ND	0.020	mg/l							
LCS Analyzed: 11/17/2010 (10K2188-BS1)										
Calcium	2.30	0.10	mg/l	2.50		92	85-115			
Magnesium	2.40	0.020	mg/l	2.50		96	85-115			
Matrix Spike Analyzed: 11/17/2010 (10K2188-MS1) Source: ITK1716-01										
Calcium	24.5	0.10	mg/l	2.50	22.3	89	70-130			MHA
Magnesium	9.51	0.020	mg/l	2.50	7.20	92	70-130			
Matrix Spike Dup Analyzed: 11/17/2010 (10K2188-MSD1) Source: ITK1716-01										
Calcium	24.3	0.10	mg/l	2.50	22.3	78	70-130	1	20	MHA
Magnesium	9.29	0.020	mg/l	2.50	7.20	84	70-130	2	20	

TestAmerica Irvine

Debby Wilson
 Project Manager

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
Quarterly Arroyo Simi-Frontier Park
Report Number: ITK1155

Sampled: 11/10/10
Received: 11/10/10

DATA QUALIFIERS AND DEFINITIONS

- MHA** Due to high levels of analyte in the sample, the MS/MSD calculation does not provide useful spike recovery information. See Blank Spike (LCS).
- MNR1** There was no MS/MSD analyzed with this batch due to insufficient sample volume. See Blank Spike/Blank Spike Duplicate.
- ND** Analyte NOT DETECTED at or above the reporting limit or MDL, if MDL is specified.
- RPD** Relative Percent Difference

TestAmerica Irvine

Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

ITK1155 <Page 11 of 12>

MWH-Pasadena/Boeing
618 Michillinda Avenue, Suite 200
Arcadia, CA 91007
Attention: Bronwyn Kelly

Project ID: Quartely Arroyo Simi-Frontier Park
Quarterly Arroyo Simi-Frontier Park
Report Number: ITK1155

Sampled: 11/10/10
Received: 11/10/10

Certification Summary

TestAmerica Irvine

Method	Matrix	Nelac	California
EDD + Level 4	Water	N/A	N/A
EPA 200.7	Water	X	X
EPA 525.2	Water		
EPA 608	Water	X	X
SM2340B	Water	X	X

Nevada and NELAP provide analyte specific accreditations. Analyte specific information for TestAmerica may be obtained by contacting the laboratory or visiting our website at www.testamericainc.com

TestAmerica Irvine

Debby Wilson
Project Manager

The results pertain only to the samples tested in the laboratory. This report shall not be reproduced, except in full, without written permission from TestAmerica.

THIS PAGE LEFT INTENTIONALLY BLANK