

Changes in the Attached Tentative Permit Relative to Order R4-2009-0058

1. The format has been updated as per the Standardized Permit format.
2. The discussion regarding previous appeals and associated decisions has been deleted.
3. The tentative order includes all of the limitations and benchmarks that are included in the current Order (R4-2009-0058).
4. The tentative order includes a new limitation for 1,2-dichloroethane at Outfalls 011 and 018. The limitation has also been implemented at Outfall 019 utilizing Best Professional Judgment and it is included as a benchmark at Outfalls 001 and 002.
5. The tentative order includes a new limitation for cyanide at Outfalls 003 through 010.
6. The wastewater and storm water only discharges have been separated by relocating Outfall 019, treated groundwater discharge which must comply with all water quality standards, downstream of Outfall 001.
7. The monitoring for Outfall 019 has been separated since the system is scheduled to operate continuously.
8. The method of calculation of the dioxin-TEQs has been updated to include a factor to evaluate the ability of the pollutant to bioaccumulate in aquatic life to levels that are harmful to aquatic life or to human receptors. The protocol was developed for the Great Lakes Region but most recently it was implemented in the San Francisco Bay Region in a number of permits.
9. Benchmarks are proposed for Outfalls 008 and 009 through June 3, 2012. During this time additional Interim Source Removal Actions will occur as per the work plan submitted in response to the Section 13304 Order issued on December 3, 2008.